

HOKMARKSBERGET, Sweden

WMO: 022920

Lat: 64.4358N

Lon: 21.2800E

Elev: 302

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.0	-1.2	-10.7	3.1	-2.8	-5.9	4.0	0.7	16.6	27.5	15.3	27.4	3.5	0	0.612

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	77.1	61.3	73.6	59.4	70.6	58.3	64.7	71.4	62.8	68.8	61.2	66.8	6.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.5	85.5	65.9	60.7	80.2	64.0	59.1	75.5	62.8	29.9	72.0	28.5	68.7	27.4	66.8	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	14.8	13.2	11.7	DB	-9.5	81.9	5.5	3.7	-13.4	84.5	-16.6	86.6	-19.7	88.7	-23.7	91.4
(5)				WB	-8.5	66.2	6.1	2.5	-12.9	68.0	-16.5	69.5	-19.9	70.9	-24.4	72.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	39.5	19.9	19.9	28.6	36.7	46.5	55.8	61.8	59.4	50.4	39.2	30.6	24.2
	DBStd	16.41	10.32	11.24	7.86	6.16	6.61	5.66	5.10	5.38	5.87	6.90	7.73	10.06
	HDD50	4791	933	843	664	401	150	11	0	3	67	336	583	800
	HDD65	9343	1398	1263	1129	850	574	282	127	186	437	799	1033	1265
	CDD50	969	0	0	0	1	42	185	365	294	80	2	0	0
	CDD65	45	0	0	0	0	0	6	27	12	0	0	0	0
	CDH74	281	0	0	0	0	3	55	165	58	0	0	0	0
	CDH80	41	0	0	0	0	0	8	30	3	0	0	0	0
Wind	WSAvg	5.3	4.9	5.8	5.7	5.6	5.8	5.3	5.4	4.8	4.9	5.1	5.4	5.2
Precipitation	PrecAvg	25.1	1.8	1.4	1.5	1.3	1.5	1.8	2.4	3.0	2.8	2.8	2.8	2.0
	PrecMax	35.4	4.0	3.3	4.5	5.0	4.0	5.8	6.5	6.9	6.3	7.3	5.4	6.7
	PrecMin	15.6	0.2	0.1	0.0	0.0	0.2	0.2	0.4	0.6	0.6	0.7	0.5	0.1
	PrecStd	4.1	0.9	0.9	0.8	1.0	0.9	1.1	1.5	1.8	1.3	1.4	1.1	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.8	43.9	51.3	61.5	72.8	79.6	83.5	79.6	68.4	57.0	48.7	42.5
		MCWB	37.8	37.8	40.4	47.7	54.3	58.8	65.2	64.5	56.4	48.7	45.5	36.3
	2%	DB	38.2	40.1	46.3	54.9	66.7	74.2	78.5	75.0	64.1	52.9	45.1	40.1
		MCWB	34.7	35.1	37.7	43.7	52.3	57.6	62.3	60.5	54.8	48.3	43.2	37.3
	5%	DB	35.0	36.0	42.9	50.6	62.0	70.4	74.4	71.8	61.4	50.5	42.7	38.0
		MCWB	33.8	32.2	36.1	40.1	48.8	55.4	60.6	59.5	53.4	47.5	41.0	36.4
	10%	DB	32.5	33.0	39.2	47.1	57.9	66.5	71.3	68.7	59.0	48.8	40.7	36.0
		MCWB	31.9	31.6	34.0	38.4	46.5	53.2	59.6	59.0	53.2	46.3	39.4	34.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.1	38.6	41.2	48.1	57.3	64.1	68.2	67.5	60.2	51.7	46.5	40.1
		MCDB	41.6	42.9	48.5	60.2	69.1	76.3	78.3	74.9	62.8	53.0	48.7	40.4
	2%	WB	35.8	35.8	38.8	44.4	53.9	60.3	65.5	64.1	58.0	49.9	43.8	38.3
		MCDB	37.3	39.1	45.1	53.5	64.0	67.9	73.1	69.2	60.9	51.5	44.8	39.0
	5%	WB	33.9	33.5	36.6	41.7	50.4	58.0	63.6	62.4	56.2	48.3	41.6	36.4
		MCDB	34.8	35.0	41.5	48.5	59.2	64.6	69.8	67.3	58.7	50.2	42.4	37.4
	10%	WB	32.1	31.8	34.7	39.0	48.0	56.0	61.9	61.0	54.8	46.5	39.7	34.8
		MCDB	32.6	32.9	38.0	45.3	56.0	62.5	67.8	65.9	57.2	48.7	40.4	35.9
Mean Daily Temperature Range	5% DB	MDBR	8.9	10.4	12.1	13.2	14.5	15.2	14.3	13.5	12.4	9.8	7.4	8.3
		MCDBR	8.6	11.8	15.5	18.9	19.7	21.1	19.1	17.9	15.6	11.5	7.5	8.3
		MCWBR	8.0	9.4	9.7	10.1	10.3	9.8	8.8	8.2	8.2	8.0	7.0	7.7
	5% WB	MCDBR	8.4	9.7	14.2	18.3	18.3	16.5	15.8	14.9	11.9	9.9	7.2	7.5
		MCWBR	8.0	8.4	9.7	10.6	10.9	9.3	8.8	8.3	7.9	7.8	7.1	7.5
Clear-Sky Solar Irradiance	taub	N/A	0.276	0.303	0.336	0.341	0.344	0.360	0.349	0.321	0.303	0.344	0.348	
	taud	N/A	2.164	2.227	2.295	2.464	2.506	2.480	2.507	2.560	2.397	2.611	2.624	
	Ebn at Noon	N/A	198	246	265	276	278	268	261	246	193	100	49	
	Edh at Noon	N/A	19	27	32	30	30	30	26	20	15	7	4	
All-Sky Solar Radiation	RadAvg	38	215	679	1193	1577	1758	1615	1219	713	275	62	15	
	RadStd	3	39	72	110	158	140	150	112	89	50	11	1	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page