

BJUROKLUBB, Sweden

WMO: 022970

Lat: 64.4799N

Lon: 21.5754E

Elev: 115

StdP: 14.64

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-4.9	0.5	-9.4	3.3	-4.9	-3.4	4.6	0.8	41.4	31.2	36.8	29.2	8.6	240	0.820

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	73.2	63.6	69.8	61.8	67.2	60.3	65.4	70.7	63.4	68.1	61.6	65.9	9.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.3	87.3	68.2	61.3	81.4	66.0	59.5	76.2	63.9	30.3	70.4	28.8	68.3	27.5	65.9	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.0	30.8	27.3	-8.6	79.5	7.0	4.2	-13.6	82.5	-17.7	85.0	-21.7	87.3	-26.7	90.3		
(5)			-9.0	67.2	6.7	2.5	-13.9	69.0	-17.8	70.5	-21.6	71.9	-26.5	73.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	39.5	21.2	20.9	27.2	35.2	44.5	53.6	60.7	59.0	50.9	40.3	32.0	26.8	(6)
(7)		DBStd	15.33	9.73	11.07	7.96	5.02	5.88	5.03	4.85	4.68	4.97	5.71	6.34	8.32	(7)
(8)		HDD50	4680	892	816	707	444	191	21	0	1	49	301	540	718	(8)
(9)		HDD65	9343	1357	1236	1172	893	635	344	152	194	422	765	990	1183	(9)
(10)		CDD50	839	0	0	0	0	21	128	331	281	77	1	0	0	(10)
(11)		CDD65	29	0	0	0	0	0	1	19	9	0	0	0	0	(11)
(12)		CDH74	77	0	0	0	0	0	5	54	18	0	0	0	0	(12)
(13)		CDH80	7	0	0	0	0	0	0	6	1	0	0	0	0	(13)
(14)	Wind	WSAvg	13.5	14.9	14.3	14.6	13.0	12.5	11.8	11.1	11.7	13.3	14.5	15.1	15.3	(14)
(15)	Precipitation	PrecAvg	23.1	1.8	1.4	1.3	1.2	1.5	1.8	2.2	2.7	2.4	2.4	2.4	2.0	(15)
(16)		PrecMax	32.0	3.8	2.6	2.7	3.5	3.9	3.5	5.8	5.3	5.0	6.8	4.9	3.9	(16)
(17)		PrecMin	17.2	0.2	0.2	0.4	0.3	0.5	0.5	0.3	0.7	0.6	0.4	0.7	0.4	(17)
(18)		PrecStd	3.6	0.9	0.7	0.6	0.8	0.9	0.9	1.2	1.3	1.0	1.4	1.2	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.8	42.7	47.0	54.3	66.8	72.9	79.6	76.5	65.2	54.5	47.1	41.9	(19)
(20)			MCWB	37.7	38.3	39.8	45.0	53.7	58.7	65.5	65.7	57.4	49.2	44.0	38.5	(20)
(21)		2%	DB	36.9	39.4	43.3	49.6	61.2	67.9	74.7	71.5	62.2	51.4	44.1	39.6	(21)
(22)			MCWB	35.1	35.8	37.3	41.9	50.7	56.7	64.8	63.5	56.0	48.4	42.9	37.7	(22)
(23)		5%	DB	34.9	35.8	40.2	46.4	57.4	64.6	71.3	68.4	60.0	49.8	42.3	37.9	(23)
(24)			MCWB	33.8	33.1	35.4	39.6	48.5	54.8	62.8	62.1	55.2	47.5	40.9	36.4	(24)
(25)		10%	DB	33.1	33.1	37.1	43.3	53.8	61.6	68.5	66.1	58.0	48.0	40.6	36.3	(25)
(26)			MCWB	32.2	32.1	33.3	37.9	46.5	53.7	61.5	60.5	54.2	45.9	39.4	35.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.3	38.6	40.5	46.1	55.0	61.1	68.8	67.6	59.8	51.3	44.9	40.1	(27)
(28)			MCDWB	40.4	42.1	45.8	53.8	64.0	70.5	74.6	73.2	62.3	52.7	45.9	40.8	(28)
(29)		2%	WB	35.7	36.0	37.9	42.7	51.5	58.0	66.5	64.8	57.7	49.5	43.3	38.2	(29)
(30)			MCDWB	36.4	39.0	42.6	48.4	59.6	64.8	72.2	69.3	60.3	50.7	44.2	39.2	(30)
(31)		5%	WB	34.0	33.8	35.7	40.2	49.2	56.4	64.3	63.3	56.3	47.7	41.3	36.7	(31)
(32)			MCDWB	34.8	35.0	39.2	45.3	56.0	62.0	69.7	67.3	58.8	49.2	42.0	37.7	(32)
(33)		10%	WB	32.3	32.4	34.0	38.2	47.2	54.9	62.4	61.6	54.9	46.1	39.5	35.1	(33)
(34)			MCDWB	33.0	33.1	36.4	42.4	53.0	59.8	67.3	65.3	57.1	47.6	40.4	36.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.5	9.4	10.2	10.1	11.0	10.8	10.7	9.9	9.1	6.9	6.3	7.4	(35)
(36)			MCDBR	7.3	10.7	12.8	15.6	16.8	15.8	14.7	13.2	11.7	8.8	6.6	7.4	(36)
(37)			MCWBR	6.8	8.6	8.8	9.4	9.2	8.2	7.2	7.1	7.2	6.6	6.3	7.0	(37)
(38)		5% WB	MCDBR	7.2	8.5	11.8	14.7	15.3	13.2	12.7	11.0	9.8	7.5	6.3	7.2	(38)
(39)			MCWBR	6.8	7.1	8.5	9.3	9.2	7.7	7.2	6.5	6.7	6.2	6.2	7.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.279	0.305	0.339	0.344	0.347	0.364	0.352	0.325	0.307	0.343	0.348	(40)	
(41)		taud	N/A	2.147	2.198	2.258	2.455	2.503	2.477	2.503	2.554	2.385	2.581	2.597	(41)	
(42)		Ebn at Noon	N/A	195	245	263	275	276	267	260	245	190	97	46	(42)	
(43)		Edh at Noon	N/A	19	28	33	30	30	30	26	20	15	7	4	(43)	
(44)	All-Sky Solar Radiation	RadAvg	37	214	680	1197	1584	1765	1619	1222	711	273	61	14	(44)	
(45)		RadStd	3	39	73	110	157	141	150	111	89	49	11	1	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (50 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page