

BJUROKLUBB, Sweden

WMO: 022970

Lat: 64.4799N

Lon: 21.5754E

Elev: 35

StdP: 100.91

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-20.5	-17.5	-23.0	0.5	-20.5	-19.7	0.7	-17.3	18.5	-0.5	16.5	-1.6	3.8	240	0.820

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.9	22.9	17.6	21.0	16.6	19.6	15.7	18.5	21.5	17.4	20.0	16.4	18.9	4.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.4	12.5	20.1	16.3	11.6	18.9	15.3	10.9	17.7	52.6	21.4	49.2	20.2	46.2	18.9	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.6	13.8	12.2	-22.6	26.4	3.9	2.3	-25.4	28.1	-27.6	29.4	-29.8	30.7	-32.6	32.4		
			-22.8	19.6	3.7	1.4	-25.5	20.6	-27.7	21.4	-29.8	22.1	-32.5	23.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.2	-6.0	-6.2	-2.7	1.8	7.0	12.0	15.9	15.0	10.5	4.6	0.0	-2.9		
	DBStd	8.52	5.40	6.15	4.42	2.79	3.26	2.80	2.70	2.60	2.76	3.17	3.52	4.62		
	HDD10.0	2600	496	453	393	247	106	12	0	1	27	167	300	399		
	HDD18.3	5191	754	687	651	496	353	191	84	108	234	425	550	657		
	CDD10.0	466	0	0	0	0	12	71	184	156	43	1	0	0		
	CDD18.3	16	0	0	0	0	0	1	11	5	0	0	0	0		
	CDH23.3	43	0	0	0	0	0	3	30	10	0	0	0	0		
	CDH26.7	4	0	0	0	0	0	0	3	1	0	0	0	0		
(14) Wind	WSAvg	6.0	6.7	6.4	6.5	5.8	5.6	5.3	5.0	5.2	5.9	6.5	6.8	6.8		
(15) Precipitation	PrecAvg	588	45	35	34	31	38	46	56	69	60	62	61	50		
	PrecMax	813	97	67	68	88	100	88	147	134	128	173	125	99		
	PrecMin	437	6	6	11	7	13	13	8	17	14	10	19	10		
	PrecStd	92	22	18	16	21	23	22	30	32	25	35	30	23		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.9	5.9	8.3	12.4	19.3	22.7	26.4	24.7	18.5	12.5	8.4	5.5		
		MCWB	3.2	3.5	4.3	7.2	12.1	14.8	18.6	18.7	14.1	9.5	6.7	3.6		
	2%	DB	2.7	4.1	6.3	9.8	16.2	19.9	23.7	21.9	16.8	10.8	6.7	4.2		
		MCWB	1.7	2.1	3.0	5.5	10.4	13.7	18.2	17.5	13.3	9.1	6.1	3.2		
	5%	DB	1.6	2.1	4.6	8.0	14.1	18.1	21.8	20.2	15.6	9.9	5.7	3.3		
		MCWB	1.0	0.6	1.9	4.2	9.2	12.6	17.1	16.7	12.9	8.6	4.9	2.5		
	10%	DB	0.6	0.6	2.8	6.3	12.1	16.5	20.3	19.0	14.5	8.9	4.8	2.4		
		MCWB	0.1	0.1	0.7	3.3	8.1	12.0	16.4	15.8	12.3	7.7	4.1	1.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.5	3.7	4.7	7.8	12.8	16.1	20.5	19.8	15.5	10.7	7.2	4.5		
		MCDB	4.7	5.6	7.7	12.1	17.8	21.4	23.7	22.9	16.8	11.5	7.7	4.9		
	2%	WB	2.0	2.2	3.3	5.9	10.9	14.5	19.2	18.2	14.3	9.7	6.3	3.5		
		MCDB	2.5	3.9	5.9	9.1	15.3	18.2	22.3	20.7	15.7	10.4	6.8	4.0		
	5%	WB	1.1	1.0	2.1	4.6	9.6	13.5	17.9	17.4	13.5	8.7	5.2	2.6		
		MCDB	1.6	1.7	4.0	7.4	13.3	16.7	21.0	19.6	14.9	9.6	5.6	3.2		
	10%	WB	0.2	0.2	1.1	3.4	8.4	12.7	16.9	16.4	12.7	7.8	4.2	1.7		
		MCDB	0.5	0.6	2.4	5.8	11.7	15.4	19.6	18.5	14.0	8.7	4.7	2.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	5.2	5.7	5.6	6.1	6.0	5.9	5.5	5.0	3.8	3.5	4.1		
		MCDBR	4.1	5.9	7.1	8.6	9.4	8.8	8.2	7.3	6.5	4.9	3.7	4.1		
	5% WB	MCWBR	3.8	4.8	4.9	5.2	5.1	4.5	4.0	4.0	4.0	3.7	3.5	3.9		
		MCDWR	4.0	4.7	6.6	8.2	8.5	7.3	7.1	6.1	5.4	4.2	3.5	4.0		
(40) Clear-Sky Solar Irradiance	taub		N/A	0.279	0.305	0.339	0.344	0.347	0.364	0.352	0.325	0.307	0.343	0.348		
		taud	N/A	2.147	2.198	2.258	2.455	2.503	2.477	2.503	2.554	2.385	2.581	2.597		
	Ebn at Noon		N/A	616	771	830	867	871	842	819	772	598	307	146		
		Edh at Noon	N/A	59	87	105	95	93	93	83	64	48	23	13		
(44) All-Sky Solar Radiation	RadAvg		0.12	0.68	2.14	3.77	4.99	5.56	5.10	3.85	2.24	0.86	0.19	0.04		
	RadStd		0.01	0.12	0.23	0.35	0.49	0.44	0.47	0.35	0.28	0.15	0.03	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (50 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page