

STORBO, Sweden

WMO: 023020

Lat: 61.8403N

Lon: 12.2880E

Elev: 661

StdP: 93.63

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-30.7	-27.7	-33.0	0.2	-30.6	-29.9	0.3	-27.6	9.3	-0.2	8.3	-0.8	0.7	270	0.700

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	23.1	13.7	21.4	13.3	19.3	12.4	15.3	19.8	14.4	18.6	13.6	17.4	2.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.8	10.7	16.0	12.8	10.0	15.3	11.9	9.4	14.8	45.2	20.2	42.5	18.5	40.1	17.6	19.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.5	6.4	5.6	-35.1	25.2	2.0	2.3	-36.6	26.8	-37.8	28.1	-38.9	29.4	-40.3	31.1
			-34.9	16.2	2.7	1.7	-36.9	17.4	-38.5	18.4	-40.0	19.3	-41.9	20.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.1	-10.2	-9.5	-5.2	0.4	5.5	10.7	13.2	11.9	7.3	1.6	-3.8	-9.1
	DBStd	9.68	7.36	6.39	5.90	3.73	3.60	3.42	2.76	2.82	3.17	4.29	5.53	7.90
	HDD10.0	3483	627	544	472	289	146	31	4	13	91	261	414	591
	HDD18.3	6285	885	778	730	539	397	231	162	199	332	518	664	849
	CDD10.0	241	0	0	0	0	8	50	102	72	9	1	0	0
	CDD18.3	2	0	0	0	0	0	1	1	0	0	0	0	0
	CDH23.3	44	0	0	0	0	0	20	23	1	0	0	0	0
	CDH26.7	2	0	0	0	0	0	0	2	0	0	0	0	0
Wind	WSAvg	2.4	2.2	2.1	2.6	2.5	2.7	2.6	2.3	2.2	2.5	2.4	2.1	2.0
Precipitation	PrecAvg	648	46	29	31	38	51	74	76	87	63	61	55	39
	PrecMax	914	83	58	60	100	113	150	139	145	91	139	160	65
	PrecMin	530	11	4	7	4	9	7	22	31	28	16	25	6
	PrecStd	90	21	12	14	24	30	31	28	36	22	32	30	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.0	4.3	9.0	13.5	21.9	25.4	25.9	23.3	18.6	12.8	8.2	5.3
		MCWB	1.9	1.6	4.0	6.7	11.4	13.3	14.4	15.3	10.5	7.8	6.5	3.2
	2%	DB	2.4	2.7	6.4	11.2	18.3	23.1	23.4	21.6	16.2	10.7	6.2	3.9
		MCWB	0.9	1.0	2.6	5.3	9.8	13.0	13.9	14.7	9.9	7.2	4.8	2.1
	5%	DB	1.1	1.4	4.7	9.3	15.1	20.9	21.3	19.5	14.3	9.2	4.6	2.7
		MCWB	-0.3	-0.2	1.5	4.4	8.3	12.3	13.3	13.5	10.2	6.7	3.3	1.3
	10%	DB	-0.2	-0.2	3.0	7.3	12.2	18.1	19.1	17.4	12.7	7.9	3.0	1.2
		MCWB	-1.4	-1.6	0.6	3.3	7.0	11.3	12.8	12.8	9.2	6.0	1.7	-0.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.2	2.2	4.3	7.9	12.1	15.1	17.0	16.7	13.1	9.5	6.8	3.7
		MCDB	3.4	3.5	7.5	11.2	19.5	21.6	21.5	20.4	14.9	11.2	8.1	4.6
	2%	WB	1.1	1.2	3.0	6.0	10.5	14.1	15.6	15.3	11.7	8.1	5.0	2.2
		MCDB	2.1	2.7	6.2	10.4	16.1	20.4	19.9	19.4	14.6	9.7	6.1	3.5
	5%	WB	-0.1	-0.1	1.8	4.7	9.2	13.0	14.5	14.5	10.6	7.1	3.5	1.3
		MCDB	0.9	1.1	4.2	8.5	13.9	19.0	18.4	18.1	13.0	8.8	4.5	2.7
	10%	WB	-1.4	-1.5	0.7	3.6	7.8	11.8	13.6	13.6	9.6	6.1	1.8	-0.1
		MCDB	-0.2	-0.3	2.8	6.7	11.8	17.1	17.5	16.5	12.0	7.7	2.8	1.0
Mean Daily Temperature Range	5% DB	MDBR	9.5	11.5	11.8	9.9	9.1	9.3	8.7	8.2	8.1	7.1	6.9	8.7
		MCDBR	7.4	9.6	11.6	13.4	15.2	14.8	12.7	12.1	11.4	8.9	6.9	7.2
		MCWBR	6.7	8.1	8.3	8.0	7.3	5.6	4.8	5.9	6.3	6.2	6.0	6.6
	5% WB	MCDBR	7.4	8.8	10.3	11.7	12.7	12.2	10.0	9.9	7.8	6.9	6.3	7.0
		MCWBR	7.0	7.6	7.5	7.3	6.8	5.1	4.9	5.5	5.4	5.4	5.7	6.6
Clear-Sky Solar Irradiance	taub	0.203	0.254	0.284	0.318	0.328	0.323	0.339	0.329	0.300	0.284	0.218	N/A	
	taud	2.102	2.255	2.257	2.304	2.457	2.508	2.473	2.487	2.555	2.485	2.178	N/A	
	Ebn at Noon	531	734	835	873	894	904	878	858	828	705	501	N/A	
	Edh at Noon	34	61	88	103	97	94	95	86	67	50	31	N/A	
All-Sky Solar Radiation	RadAvg	0.27	0.92	2.46	4.17	4.73	5.15	4.69	3.64	2.35	1.04	0.33	0.14	
	RadStd	0.03	0.17	0.23	0.38	0.41	0.45	0.59	0.33	0.28	0.17	0.07	0.01	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (51 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page