

IDRE FJALL, Sweden

WMO: 023070

Lat: 61.8886N

Lon: 12.8521E

Elev: 869

StdP: 91.31

Time Zone: 1.00 (EUC)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.8	-15.9	-21.6	0.6	-12.7	-19.5	0.7	-13.4	16.6	-4.5	14.9	-4.3	4.1	130	0.844

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.6	21.4	13.3	19.6	12.7	17.7	11.9	14.9	19.0	14.0	17.7	13.0	16.2	4.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.4	10.7	15.7	12.4	10.0	15.0	11.4	9.3	14.3	44.7	19.1	42.0	17.7	39.3	16.2	18.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 14.2	12.3	10.9		-18.8	23.6	3.4	2.3	-21.2	25.3	-23.2	26.6	-25.1	27.9	-27.5	29.6	
(5)			DB	-18.9	16.0	3.1	1.0	-21.1	16.7	-22.9	17.3	-24.7	17.9	-26.9	18.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.6	-6.8	-7.0	-4.9	0.1	5.2	9.5	12.4	10.9	6.9	1.2	-3.3	-5.6
	DBStd	7.95	4.15	4.72	4.09	3.86	4.45	4.00	3.58	3.17	3.24	3.69	3.96	4.32
	HDD10.0	3272	519	476	462	296	162	56	14	27	103	273	399	485
	HDD18.3	6111	778	709	720	546	407	266	187	232	343	531	649	743
	CDD10.0	206	0	0	0	0	13	41	89	53	9	0	0	0
	CDD18.3	5	0	0	0	0	0	1	3	1	0	0	0	0
	CDH23.3	10	0	0	0	0	0	3	7	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	5.4	5.7	5.7	6.0	5.4	5.4	5.2	4.8	4.8	5.3	5.5	5.6	5.9
(15) Precipitation	PrecAvg	693	46	31	28	39	56	80	87	98	63	62	57	43
	PrecMax	935	94	55	57	95	118	158	152	159	121	149	166	73
	PrecMin	560	9	6	2	7	12	6	20	36	6	9	23	6
	PrecStd	88	23	12	15	24	27	31	34	33	31	33	30	16
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.6	3.8	5.5	12.3	20.7	23.2	24.4	21.7	17.1	11.5	7.4	3.6
		MCWB	-0.3	0.2	2.5	6.5	11.1	12.2	15.1	14.0	11.5	9.5	5.1	2.4
	2%	DB	1.3	1.8	3.7	9.6	17.3	20.5	22.0	19.3	14.8	8.7	4.9	2.4
		MCWB	-0.4	0.0	1.2	4.8	9.7	11.6	14.1	13.0	10.3	7.0	3.8	1.4
	5%	DB	0.1	0.5	2.3	7.5	14.7	18.1	20.2	17.5	12.9	7.5	3.2	1.2
		MCWB	-0.9	-0.8	0.4	3.7	8.5	10.9	13.7	12.5	9.5	6.1	2.5	0.4
	10%	DB	-1.2	-0.9	0.7	5.7	12.0	15.8	18.2	15.6	11.3	6.2	1.7	0.0
		MCWB	-1.9	-1.9	-0.9	2.6	7.2	10.1	12.7	11.9	8.7	5.1	1.2	-0.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.2	1.6	3.1	7.6	11.8	14.6	16.3	15.6	12.9	10.3	5.9	3.1
		MCDB	1.8	2.7	4.9	10.4	17.3	18.4	21.1	18.6	14.7	11.4	6.5	3.2
	2%	WB	0.2	0.3	1.7	5.4	10.6	13.0	15.4	14.4	11.5	7.7	3.9	1.7
		MCDB	0.8	1.3	3.3	8.8	16.1	17.3	20.2	17.2	13.7	8.3	4.6	2.3
	5%	WB	-0.8	-0.7	0.6	4.1	9.1	11.8	14.5	13.5	10.4	6.3	2.6	0.7
		MCDB	-0.2	0.4	2.1	7.1	13.1	17.2	19.0	16.3	12.2	7.0	3.3	1.2
	10%	WB	-1.9	-1.8	-0.6	2.9	7.7	10.7	13.6	12.5	9.4	5.2	1.2	-0.6
		MCDB	-1.2	-1.0	0.7	5.4	11.6	15.5	17.4	15.1	10.9	5.9	1.6	0.0
(35) Mean Daily Temperature Range	MDBR		3.9	4.1	4.7	5.0	6.8	7.1	6.6	5.9	5.1	3.8	3.4	3.6
	5% DB	MCDBR	4.6	4.9	5.9	7.1	10.0	9.5	8.8	7.7	7.3	5.1	4.9	4.7
		MCWBR	4.1	4.2	4.3	4.3	4.9	4.1	3.9	3.7	4.1	4.1	4.4	4.6
	5% WB	MCDBR	4.2	4.5	5.7	6.7	9.1	8.4	8.0	6.5	6.5	4.4	4.7	4.6
		MCWBR	4.0	4.2	4.4	4.3	5.1	4.2	4.1	3.8	4.2	4.0	4.5	4.6
(40) Clear-Sky Solar Irradiance	taub		0.194	0.245	0.271	0.304	0.314	0.311	0.324	0.315	0.288	0.272	0.209	N/A
	taud		2.119	2.286	2.295	2.359	2.500	2.541	2.506	2.520	2.580	2.511	2.197	N/A
	Ebn at Noon		552	754	855	892	911	918	894	874	844	725	522	N/A
	Edh at Noon		32	58	84	97	93	91	92	83	65	48	30	N/A
(44) All-Sky Solar Radiation	RadAvg		0.26	0.90	2.44	4.14	4.72	5.15	4.69	3.64	2.35	1.04	0.32	0.14
	RadStd		0.03	0.16	0.23	0.38	0.41	0.44	0.60	0.33	0.28	0.17	0.07	0.01

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (50 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page