

KLOVSJOHOJDEN, Sweden

WMO: 023250

Lat: 62.4952N

Lon: 14.1542E

Elev: 803

StdP: 92.04

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-19.1	-16.8	-21.8	0.6	-16.7	-19.6	0.7	-14.4	14.0	-0.6	12.7	-1.7	2.7	350	0.777

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.3	22.2	13.9	20.3	13.3	18.4	12.7	15.5	19.9	14.5	18.3	13.5	16.8	3.4	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.9	10.9	16.4	12.9	10.2	15.5	11.9	9.6	14.8	46.0	19.9	43.0	18.4	40.3	16.7	23.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.7	10.2	9.0	DB	-21.2	24.3	2.8	2.2	-23.3	25.9	-24.9	27.2	-26.5	28.4	-28.6	30.0	(4)
(5)			WB	-21.3	17.0	2.7	2.4	-23.2	18.7	-24.8	20.1	-26.3	21.5	-28.3	23.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	1.9	-6.7	-6.7	-4.3	0.5	5.4	9.8	12.8	11.3	6.8	1.3	-3.1	-5.3	(6)
(7)		DBStd	8.03	4.59	4.96	4.29	3.85	4.50	4.00	3.67	3.29	3.20	3.85	4.25	4.73	(7)
(8)		HDD10.0	3202	517	467	444	285	158	52	13	23	105	272	394	473	(8)
(9)		HDD18.3	6021	776	701	702	534	401	258	177	221	346	529	644	732	(9)
(10)		CDD10.0	229	0	0	0	0	15	44	99	62	9	1	0	0	(10)
(11)		CDD18.3	6	0	0	0	0	0	1	4	1	0	0	0	0	(11)
(12)		CDH23.3	17	0	0	0	0	0	2	14	1	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	4.4	5.0	5.0	4.9	4.3	4.0	4.0	3.5	3.5	4.2	4.6	4.8	5.3	(14)
(15)	Precipitation	PrecAvg	670	34	29	32	37	54	83	95	87	67	62	49	36	(15)
(16)		PrecMax	877	75	55	60	82	92	146	188	139	150	156	134	61	(16)
(17)		PrecMin	499	2	11	7	10	12	23	34	46	27	18	21	7	(17)
(18)		PrecStd	107	19	12	15	19	23	31	44	30	32	40	28	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.5	4.9	6.9	12.9	21.7	23.3	25.0	22.7	16.9	12.6	7.7	5.0	(19)
(20)			MCWB	1.2	0.9	2.3	6.7	11.4	13.2	15.7	15.1	11.5	10.1	4.9	3.0	(20)
(21)		2%	DB	1.7	2.5	4.6	10.3	18.1	21.2	22.9	20.3	14.8	9.5	5.9	3.3	(21)
(22)			MCWB	0.4	0.2	1.8	5.1	10.4	12.1	15.2	14.3	10.7	7.3	3.5	2.0	(22)
(23)		5%	DB	0.7	1.1	2.9	8.0	15.2	18.8	20.9	18.1	13.0	8.1	3.9	2.0	(23)
(24)			MCWB	-0.4	-0.4	0.8	3.9	9.1	11.7	14.2	13.1	10.2	6.4	3.0	0.7	(24)
(25)		10%	DB	-0.6	-0.2	1.5	6.2	12.7	16.4	18.9	16.3	11.4	6.6	2.3	0.7	(25)
(26)			MCWB	-1.8	-1.3	-0.2	2.8	8.0	10.6	13.4	12.5	9.2	5.1	1.6	-0.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.7	2.2	3.3	7.7	12.7	15.2	17.2	16.3	12.9	10.7	6.2	3.7	(27)
(28)			MCDWB	2.7	3.6	5.2	12.1	18.3	20.0	22.3	20.2	15.0	12.0	6.8	4.2	(28)
(29)		2%	WB	0.7	0.6	2.1	5.7	11.3	13.5	16.0	15.1	11.6	7.9	4.2	2.0	(29)
(30)			MCDWB	1.5	1.8	4.2	9.3	16.5	17.9	20.7	18.4	13.5	9.0	5.1	3.1	(30)
(31)		5%	WB	-0.2	-0.3	1.0	4.3	9.9	12.3	15.0	14.1	10.5	6.6	3.0	0.9	(31)
(32)			MCDWB	0.7	1.0	2.7	7.4	14.5	17.4	19.6	16.8	12.3	7.7	4.0	1.7	(32)
(33)		10%	WB	-1.5	-1.4	-0.2	3.1	8.3	11.3	14.0	13.1	9.5	5.4	1.6	-0.3	(33)
(34)			MCDWB	-0.7	-0.1	1.3	5.7	12.4	16.1	18.0	15.7	11.2	6.5	2.3	0.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.2	4.5	5.0	5.8	7.1	7.7	7.3	6.4	5.4	4.2	3.6	3.8	(35)
(36)			MCDBR	4.4	5.2	5.7	7.6	10.4	10.4	9.4	8.3	7.5	6.2	4.7	5.1	(36)
(37)			MCWBR	3.9	4.4	4.2	4.4	5.2	4.9	4.3	4.2	4.5	4.4	3.9	4.8	(37)
(38)		5% WB	MCDWR	4.3	4.9	5.6	7.3	9.6	9.4	8.6	7.3	6.6	5.5	4.5	4.8	(38)
(39)			MCWBR	4.1	4.3	4.4	4.4	5.6	5.1	4.6	4.3	4.5	4.4	4.1	4.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.194	0.249	0.276	0.307	0.315	0.312	0.325	0.316	0.288	0.273	0.207	0.337	(40)	
(41)		taud	2.105	2.304	2.364	2.450	2.509	2.545	2.513	2.528	2.592	2.512	2.178	2.892	(41)	
(42)		Ebn at Noon	519	737	848	888	907	915	891	871	840	712	491	357	(42)	
(43)		Edh at Noon	30	56	78	89	91	90	91	82	63	47	28	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.22	0.83	2.29	3.97	4.68	5.23	4.76	3.66	2.30	1.01	0.30	0.11	(44)	
(45)		RadStd	0.02	0.12	0.21	0.32	0.43	0.42	0.58	0.33	0.26	0.16	0.06	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (45 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page