

HARJEDALEN SVEG, Sweden

WMO: 023270

Lat: 62.0462N

Lon: 14.4069E

Elev: 1188

StdP: 14.08

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.5	-12.0	-23.2	1.6	-18.4	-16.0	2.4	-11.9	22.6	30.8	18.9	29.6	2.9	280	0.662

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.2	78.7	61.4	75.0	59.6	71.3	58.0	63.6	73.9	61.6	71.2	59.7	68.2	7.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.1	81.0	65.2	58.0	75.0	64.1	56.0	69.8	62.7	29.4	74.4	28.0	70.7	26.7	68.4	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	15.9	13.3	-26.9	83.0	6.5	3.9	-31.6	85.8	-35.4	88.1	-39.1	90.2	-43.9	93.0
			-27.3	65.2	6.1	3.3	-31.7	67.6	-35.3	69.6	-38.7	71.5	-43.1	73.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	36.9	16.4	19.1	26.6	36.2	45.6	53.1	59.0	55.3	47.6	36.6	26.7	19.0	(6)
(7)		DBStd	17.11	13.28	12.42	9.56	6.81	7.38	5.91	5.91	5.57	5.90	6.99	9.45	13.06	(7)
(8)		HDD50	5460	1042	864	725	415	179	32	4	14	110	417	698	960	(8)
(9)		HDD65	10283	1507	1284	1190	863	601	358	201	306	521	879	1148	1425	(9)
(10)		CDD50	671	0	0	0	1	43	125	283	177	39	3	0	0	(10)
(11)		CDD65	21	0	0	0	0	0	2	15	4	0	0	0	0	(11)
(12)		CDH74	404	0	0	0	0	22	45	274	63	0	0	0	0	(12)
(13)		CDH80	54	0	0	0	0	0	5	46	3	0	0	0	0	(13)
(14)	Wind	WSAvg	5.4	4.8	5.1	6.1	5.6	6.1	6.6	5.6	5.1	5.3	5.1	4.7	4.6	(14)
(15)	Precipitation	PrecAvg	24.8	1.4	1.1	1.3	1.6	1.9	2.7	3.5	3.0	2.5	2.1	2.0	1.7	(15)
(16)		PrecMax	36.1	3.3	3.0	3.1	4.3	3.9	7.0	8.8	7.2	5.6	5.4	4.0	4.8	(16)
(17)		PrecMin	18.0	0.1	0.2	0.0	0.2	0.4	0.4	0.5	0.8	0.6	0.4	0.6	0.2	(17)
(18)		PrecStd	4.2	0.8	0.6	0.7	1.0	0.9	1.5	1.9	1.5	1.2	1.2	0.9	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.5	42.9	50.3	63.9	77.2	79.7	84.5	79.6	68.8	58.6	49.6	43.8	(19)
(20)		MCWB	36.7	37.4	41.4	49.1	56.5	59.8	63.3	61.9	56.3	52.4	45.9	40.4	(20)	
(21)		2%	DB	38.3	40.2	45.5	58.1	71.4	74.5	80.5	75.4	64.8	53.6	45.6	40.4	(21)
(22)		MCWB	35.3	35.8	38.5	46.0	54.9	58.1	62.9	60.7	55.1	48.3	42.7	37.5	(22)	
(23)		5%	DB	36.0	37.6	42.4	53.0	65.9	69.9	76.9	71.6	61.3	50.3	41.4	38.0	(23)
(24)		MCWB	33.5	34.1	36.5	43.3	52.7	55.9	61.4	58.7	53.6	46.1	39.3	35.3	(24)	
(25)		10%	DB	33.3	35.0	39.9	48.7	60.5	65.9	72.8	67.5	58.2	47.7	38.5	35.7	(25)
(26)		MCWB	31.2	32.1	34.8	40.5	49.4	53.9	59.5	57.5	51.9	44.2	36.4	33.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.5	38.5	42.3	50.5	58.9	62.5	66.7	65.1	59.1	53.0	46.5	40.9	(27)
(28)		MADB	39.7	42.0	48.8	60.6	70.5	74.4	77.2	72.8	64.9	57.1	49.4	43.4	(28)	
(29)		2%	WB	35.7	36.0	39.2	46.7	56.0	59.4	64.7	62.5	56.5	49.2	42.8	37.8	(29)
(30)		MADB	37.8	39.4	44.4	56.7	67.9	69.8	76.1	70.1	62.2	52.4	45.3	39.8	(30)	
(31)		5%	WB	33.7	34.4	37.2	43.9	53.5	57.3	62.8	60.7	54.6	46.8	39.6	35.6	(31)
(32)		MADB	35.7	37.3	41.6	52.0	64.3	67.2	73.8	68.7	59.9	49.8	41.4	37.6	(32)	
(33)		10%	WB	31.4	32.3	35.1	41.3	50.4	55.3	60.9	58.7	52.6	44.6	36.7	33.5	(33)
(34)		MADB	33.2	34.7	39.5	47.8	59.7	64.6	70.6	65.4	57.3	47.3	38.1	35.3	(34)	
(35)	Mean Daily Temperature Range	MDBR	14.8	15.7	18.3	18.3	19.8	18.6	20.2	19.4	16.1	12.7	10.6	13.4	(35)	
(36)		5% DB	MADB	12.7	13.1	18.2	26.8	30.3	26.8	28.9	27.7	22.6	16.8	12.3	13.4	(36)
(37)		MCWBR	11.2	10.5	12.6	16.1	15.8	13.0	13.2	14.0	13.6	12.5	10.8	12.1	(37)	
(38)		5% WB	MADB	12.7	12.9	17.5	24.4	27.3	23.3	26.1	22.2	18.6	14.8	12.1	13.4	(38)
(39)		MCWBR	11.5	10.8	12.7	15.1	14.8	12.2	12.7	12.2	12.2	11.6	10.9	12.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.218	0.271	0.300	0.335	0.342	0.337	0.353	0.343	0.311	0.296	0.234	0.341	(40)	
(41)		taud	2.125	2.271	2.328	2.392	2.449	2.490	2.458	2.476	2.552	2.479	2.198	2.766	(41)	
(42)		Ebn at Noon	157	224	259	272	279	282	274	267	258	216	148	107	(42)	
(43)		Edh at Noon	10	19	26	30	31	30	31	28	21	16	10	6	(43)	
(44)	All-Sky Solar Radiation	RadAvg	75	281	763	1260	1482	1681	1531	1172	748	337	99	40	(44)	
(45)		RadStd	10	45	72	113	152	131	187	105	94	54	22	4	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (45 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page