

HUNGE, Sweden

WMO: 023310

Lat: 62.7504N

Lon: 15.0845E

Elev: 1125

StdP: 14.11

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.0	-11.8	-23.5	1.6	-17.9	-16.5	2.3	-11.8	20.4	30.1	18.1	29.6	0.4	0	0.665

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.3	76.7	61.3	73.3	60.2	69.8	58.7	64.1	72.5	62.1	69.9	60.2	67.1	6.1	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.8	83.1	67.2	59.0	77.7	65.1	57.3	72.9	63.5	29.9	72.4	28.4	70.1	27.1	67.2	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.3	14.9	13.1	-23.1	80.7	6.4	3.7	-27.7	83.3	-31.5	85.5	-35.1	87.5	-39.8	90.2
			-23.7	65.8	6.0	3.0	-28.0	67.9	-31.5	69.7	-34.8	71.3	-39.2	73.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	36.6	17.1	18.4	24.8	35.2	45.1	53.0	58.1	55.2	46.9	36.6	27.4	20.1	(6)
(7)		DBStd	16.68	12.39	11.93	10.05	6.22	6.65	5.85	5.51	5.30	5.73	6.49	8.73	12.38	(7)
(8)		HDD50	5506	1019	884	782	445	182	33	3	13	123	417	679	926	(8)
(9)		HDD65	10381	1484	1304	1247	895	616	362	225	304	543	881	1129	1391	(9)
(10)		CDD50	614	0	0	0	0	31	122	253	176	30	2	0	0	(10)
(11)		CDD65	14	0	0	0	0	0	1	11	2	0	0	0	0	(11)
(12)		CDH74	230	0	0	0	0	6	45	149	30	0	0	0	0	(12)
(13)		CDH80	18	0	0	0	0	0	1	16	1	0	0	0	0	(13)
(14)	Wind	WSAvg	5.5	5.2	5.4	5.9	5.6	6.1	6.1	5.4	5.2	5.6	5.8	5.3	5.0	(14)
(15)	Precipitation	PrecAvg	24.2	1.4	1.0	1.1	1.4	1.8	2.9	3.7	3.3	2.2	2.1	1.8	1.5	(15)
(16)		PrecMax	33.0	2.6	2.1	2.3	4.2	3.1	5.1	7.8	5.4	4.6	5.5	3.9	2.7	(16)
(17)		PrecMin	18.0	0.2	0.1	0.2	0.1	0.7	0.8	0.8	1.3	0.7	0.8	0.6	0.3	(17)
(18)		PrecStd	3.8	0.7	0.5	0.5	0.9	0.8	1.1	1.9	1.2	1.1	1.2	0.8	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.9	43.2	48.0	62.5	74.5	78.5	82.1	77.9	66.6	57.0	47.9	42.8	(19)
(20)			MCWB	37.5	37.3	40.3	48.3	56.3	59.5	64.6	63.0	56.9	51.7	45.7	39.3	(20)
(21)		2%	DB	37.5	40.1	43.9	56.2	69.4	74.6	78.4	73.2	63.0	52.6	43.7	40.1	(21)
(22)			MCWB	35.0	36.0	38.1	45.1	54.0	58.5	63.3	62.0	55.6	48.5	41.9	37.3	(22)
(23)		5%	DB	35.1	37.3	40.9	51.4	64.2	70.1	74.4	69.6	59.8	49.7	40.5	37.8	(23)
(24)			MCWB	33.2	34.6	36.2	42.5	51.8	57.3	61.5	59.9	54.0	46.4	39.0	35.6	(24)
(25)		10%	DB	32.8	34.3	38.4	47.2	58.9	65.5	70.8	66.2	57.0	47.4	38.2	35.0	(25)
(26)			MCWB	31.2	32.1	34.5	40.0	49.3	54.9	60.1	59.0	52.5	44.9	36.8	33.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.6	38.1	41.2	49.7	58.6	62.9	67.4	65.7	59.1	52.4	45.7	40.0	(27)
(28)			MCDWB	40.1	41.8	47.0	60.2	69.9	73.6	77.4	73.6	64.3	55.4	47.7	42.1	(28)
(29)		2%	WB	35.6	36.4	38.6	46.0	55.6	60.2	65.0	63.7	56.6	49.2	42.2	37.7	(29)
(30)			MCDWB	37.3	39.7	43.1	54.6	65.7	69.6	74.3	70.4	61.1	51.4	43.6	39.9	(30)
(31)		5%	WB	33.4	34.5	36.5	43.2	53.1	58.3	62.9	61.7	54.8	47.2	39.1	35.6	(31)
(32)			MCDWB	34.7	37.1	40.4	49.9	62.4	67.6	71.8	67.5	58.9	49.4	40.1	37.4	(32)
(33)		10%	WB	31.3	32.3	34.7	40.6	50.4	56.2	61.2	59.7	53.0	44.9	36.9	33.5	(33)
(34)			MCDWB	32.7	34.3	38.0	46.4	58.4	64.6	69.2	64.9	56.5	47.4	38.1	34.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.8	16.1	18.4	18.3	19.4	18.2	18.3	17.1	15.5	12.4	10.5	13.5	(35)
(36)			MCDBR	13.6	13.9	17.4	27.3	30.3	26.6	25.1	23.5	20.5	17.1	11.6	13.0	(36)
(37)			MCWBR	12.4	11.1	12.7	16.8	16.0	12.7	12.0	13.0	13.5	12.7	10.2	11.3	(37)
(38)		5% WB	MCDWB	12.9	12.9	16.5	24.2	26.2	23.1	22.3	20.4	18.2	15.4	11.1	12.9	(38)
(39)			MCWBR	12.0	10.4	12.3	15.6	14.7	11.8	11.5	12.0	12.6	12.1	10.1	11.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.212	0.270	0.297	0.331	0.338	0.333	0.348	0.339	0.308	0.293	0.225	0.344	(40)	
(41)		taud	2.080	2.258	2.331	2.411	2.465	2.505	2.477	2.496	2.566	2.486	2.161	2.759	(41)	
(42)		Ebn at Noon	146	219	258	272	279	283	274	267	257	214	139	93	(42)	
(43)		Edh at Noon	10	19	25	30	30	30	30	27	21	15	9	6	(43)	
(44)	All-Sky Solar Radiation	RadAvg	63	256	706	1219	1473	1688	1542	1171	724	318	90	32	(44)	
(45)		RadStd	6	35	69	98	149	128	182	102	81	49	16	2	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page