

DELSBO, Sweden

WMO: 023470

Lat: 61.8264N

Lon: 16.5385E

Elev: 72

StdP: 100.46

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.4	-18.7	-24.2	0.4	-21.1	-21.3	0.6	-18.7	8.0	1.7	7.2	1.3	0.8	270	0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	26.2	18.5	24.2	17.3	22.4	16.3	19.5	24.2	18.3	22.6	17.2	21.0	2.8	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.7	12.8	21.2	16.7	12.0	20.2	15.6	11.1	19.1	55.8	24.2	52.0	22.7	48.7	21.0	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.7	5.7	5.0	-25.1	28.5	3.1	2.1	-27.3	30.0	-29.1	31.2	-30.8	32.4	-33.0	33.9		
(5)			-25.4	20.8	2.7	1.6	-27.4	22.0	-29.0	22.9	-30.5	23.8	-32.5	24.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.8	-5.9	-5.3	-1.3	3.8	9.2	13.5	16.3	15.0	10.5	4.6	0.0	-3.7	(6)
(7)		DBStd	8.78	5.97	6.01	4.82	3.23	3.41	2.94	2.64	2.77	3.04	3.60	4.09	5.82	(7)
(8)		HDD10.0	2447	494	428	351	187	56	5	0	1	30	169	301	425	(8)
(9)		HDD18.3	4968	752	662	609	436	282	148	74	110	236	424	551	683	(9)
(10)		CDD10.0	540	0	0	0	1	32	109	197	154	44	3	0	0	(10)
(11)		CDD18.3	19	0	0	0	0	0	2	13	5	0	0	0	0	(11)
(12)		CDH23.3	259	0	0	0	0	11	49	145	53	0	0	0	0	(12)
(13)		CDH26.7	34	0	0	0	0	1	6	24	3	0	0	0	0	(13)
(14)	Wind	WSAvg	2.0	1.9	1.8	2.2	2.1	2.2	2.1	1.9	1.7	1.7	1.9	1.9	1.9	(14)
(15)	Precipitation	PrecAvg	602	36	28	30	33	42	57	80	80	52	61	53	46	(15)
(16)		PrecMax	833	76	49	72	91	89	117	177	143	137	142	155	77	(16)
(17)		PrecMin	425	0	5	4	3	12	10	19	26	8	13	13	6	(17)
(18)		PrecStd	92	22	12	15	26	23	29	38	34	35	31	34	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.4	7.8	12.3	19.8	24.7	27.3	29.3	27.1	22.1	16.0	11.7	8.8	(19)
(20)			MCWB	4.2	4.1	7.0	11.6	14.6	16.8	19.5	19.3	15.6	12.7	9.6	6.5	(20)
(21)		2%	DB	4.9	6.0	9.5	15.6	21.3	24.6	27.0	24.9	19.7	13.7	9.3	6.5	(21)
(22)			MCWB	3.1	3.3	5.3	9.3	13.6	16.5	19.0	18.4	14.7	10.7	7.5	4.6	(22)
(23)		5%	DB	3.5	4.5	7.5	12.9	19.3	22.4	24.8	22.8	17.7	12.0	7.1	5.2	(23)
(24)			MCWB	1.9	2.3	3.9	7.5	12.4	15.2	18.3	17.2	13.8	9.7	5.7	3.4	(24)
(25)		10%	DB	1.8	2.7	5.8	10.8	16.9	20.4	22.8	20.9	16.1	10.5	5.6	3.6	(25)
(26)			MCWB	0.6	1.0	2.8	6.1	11.1	14.3	16.9	16.3	12.6	8.6	4.6	2.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.5	4.7	7.2	12.3	16.3	18.6	21.4	20.9	16.6	13.1	9.9	6.8	(27)
(28)			MCD B	6.0	7.0	11.6	18.0	22.6	24.6	26.3	24.9	20.2	15.4	11.9	8.6	(28)
(29)		2%	WB	3.2	3.6	5.6	9.8	14.5	17.1	20.0	19.2	15.3	11.3	7.5	4.9	(29)
(30)			MCD B	4.6	5.7	9.1	15.1	19.9	22.7	24.9	23.1	18.7	12.9	9.0	6.3	(30)
(31)		5%	WB	2.1	2.5	4.2	8.0	13.0	16.0	18.8	18.0	14.3	10.1	6.0	3.5	(31)
(32)			MCD B	3.4	4.4	7.1	12.2	18.2	21.3	23.7	21.5	17.0	11.7	6.9	4.8	(32)
(33)		10%	WB	0.7	1.1	2.9	6.5	11.6	14.8	17.7	16.9	13.2	8.8	4.9	2.2	(33)
(34)			MCD B	1.6	2.6	5.5	10.2	16.3	19.4	21.7	20.0	15.5	10.3	5.6	3.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.0	7.6	9.1	10.6	11.1	10.7	10.6	10.2	9.3	7.4	5.4	6.1	(35)
(36)			MCD BR	7.4	7.4	11.0	15.6	16.1	15.2	14.0	13.4	12.0	9.9	7.3	7.3	(36)
(37)			MCWBR	6.4	5.6	7.4	9.6	9.1	8.1	7.3	7.5	7.6	7.2	6.1	6.3	(37)
(38)		5% WB	MCD BR	7.3	7.1	10.5	14.2	14.7	13.9	12.6	11.3	10.9	9.1	6.8	7.2	(38)
(39)			MCWBR	6.4	5.5	7.3	9.1	8.7	7.8	7.0	6.8	7.3	7.0	5.8	6.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.240	0.294	0.317	0.353	0.356	0.350	0.368	0.361	0.327	0.313	0.259	0.344	(40)	
(41)		taud	2.142	2.264	2.347	2.379	2.430	2.476	2.444	2.460	2.539	2.457	2.209	2.639	(41)	
(42)		Ebn at Noon	468	675	799	838	865	876	848	823	793	661	437	307	(42)	
(43)		Edh at Noon	34	62	82	97	100	97	98	89	69	52	32	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.22	0.86	2.36	3.83	4.89	5.56	5.17	3.93	2.49	1.12	0.32	0.13	(44)	
(45)		RadStd	0.03	0.16	0.27	0.33	0.51	0.37	0.54	0.34	0.31	0.19	0.07	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-105	N/A	N/A	N/A

Nomenclature: See separate page