

SILLRE, Sweden

WMO: 023490

Lat: 62.7628N

Lon: 16.7392E

Elev: 673

StdP: 14.34

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.1	-11.0	-22.1	1.7	-13.4	-15.9	2.4	-8.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.6	76.6	60.4	72.8	58.5	69.6	57.5	63.3	69.7	61.4	67.4	59.5	65.4	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.0	82.2	65.5	59.1	76.6	62.9	57.2	71.7	61.6	29.1	70.7	27.7	67.3	26.4	65.0	69.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
N/A	N/A	N/A	-20.6	81.4	6.6	3.4	-25.3	83.9	-29.2	85.9	-32.9	87.8	-37.7	90.3		
			-20.9	66.2	6.1	2.6	-25.3	68.0	-28.9	69.5	-32.4	71.0	-36.8	72.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.0	16.2	18.0	26.8	36.8	45.7	52.8	58.6	55.7	47.2	36.5	28.4	20.0		
	DBStd	16.73	13.05	12.11	9.10	5.54	5.81	5.03	4.77	5.01	5.70	6.62	8.93	12.83		
	HDD50	5366	1049	896	718	396	162	25	0	7	118	418	647	930		
	HDD65	10229	1514	1316	1183	846	599	365	207	291	533	883	1097	1395		
	CDD50	623	0	0	0	0	28	110	266	184	35	0	0	0		
	CDD65	11	0	0	0	0	0	0	8	3	0	0	0	0		
	CDH74	218	0	0	0	0	4	59	125	30	0	0	0	0		
	CDH80	21	0	0	0	0	0	5	15	1	0	0	0	0		
	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	PrecAvg	24.4	1.6	1.0	1.2	1.5	1.5	2.5	3.7	3.1	2.2	2.3	2.0	1.7		
	PrecMax	36.1	3.2	2.4	2.6	3.8	3.8	4.8	8.6	6.6	6.3	5.4	5.4	3.3		
	PrecMin	18.4	0.2	0.1	0.4	0.3	0.4	0.9	0.3	1.2	0.7	0.8	0.5	0.1		
	PrecStd	4.8	0.8	0.6	0.6	0.9	0.8	1.1	2.2	1.8	1.3	1.2	1.3	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.7	42.9	49.9	64.4	73.9	80.1	82.4	78.3	67.1	55.6	49.0	43.1		
		MCWB	36.8	37.9	41.4	49.6	55.4	58.3	64.0	62.5	57.1	49.3	46.1	38.8		
	2%	DB	36.6	39.2	45.3	57.5	68.4	74.4	77.7	73.0	63.2	51.9	45.4	40.4		
		MCWB	34.0	35.3	38.2	45.7	52.3	56.3	61.4	61.5	54.7	48.0	42.8	37.2		
	5%	DB	33.8	36.5	42.3	53.0	63.8	69.6	73.8	69.4	60.1	49.5	41.7	38.0		
		MCWB	32.1	33.4	36.5	42.4	50.5	54.9	59.3	60.0	53.3	46.8	40.3	35.7		
	10%	DB	32.0	33.6	39.6	49.2	59.2	65.7	70.6	66.0	57.2	47.2	39.3	34.9		
		MCWB	31.1	31.6	34.8	40.4	48.1	53.6	58.4	58.9	52.1	44.7	38.0	33.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.3	38.3	41.8	50.0	58.1	61.3	65.5	66.5	59.9	51.3	47.0	40.1		
		MCDB	39.4	41.5	48.4	64.0	68.1	68.8	74.2	73.5	64.5	53.4	48.9	42.1		
	2%	WB	34.6	36.0	39.0	46.2	54.6	58.5	63.5	63.7	56.5	48.9	43.2	37.6		
		MCDB	36.1	38.7	43.9	55.9	63.6	68.2	71.7	68.5	60.0	50.9	44.8	39.7		
	5%	WB	32.3	33.8	36.9	43.9	51.4	56.6	61.7	61.6	54.7	47.0	40.6	35.8		
		MCDB	33.3	35.8	41.5	51.7	61.3	67.6	69.2	65.9	58.6	49.1	41.5	37.9		
	10%	WB	31.0	31.6	35.1	41.1	49.3	54.9	59.9	59.6	52.8	45.0	38.2	33.3		
		MCDB	32.0	33.4	39.2	47.8	58.4	64.4	66.7	64.0	56.2	47.2	39.2	34.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.3	15.0	17.4	18.6	20.3	20.3	18.6	16.8	15.8	12.5	8.9	11.8		
		MCDBR	11.1	13.0	18.0	27.7	29.1	28.5	25.2	22.0	19.3	15.9	11.4	13.5		
		MCWBR	10.2	10.4	12.0	15.8	14.6	13.1	11.5	12.1	12.0	12.4	9.8	11.3		
	5% WB	MCDBR	10.8	13.1	16.9	25.9	25.6	24.2	19.6	17.3	16.6	15.2	11.0	12.8		
		MCWBR	10.2	11.0	11.9	15.5	13.7	12.2	10.8	10.9	11.6	12.5	9.9	11.1		
(40) Clear-Sky Solar Irradiance	taub		0.222	0.281	0.305	0.341	0.344	0.340	0.355	0.346	0.315	0.301	0.236	0.345		
	taud		2.085	2.251	2.338	2.398	2.453	2.493	2.467	2.486	2.560	2.473	2.166	2.690		
	Ebn at Noon		140	213	255	269	277	280	272	265	254	210	133	86		
	Edh at Noon		10	19	25	30	31	30	30	27	21	16	9	6		
(44) All-Sky Solar Radiation	RadAvg		61	265	729	1200	1516	1747	1594	1210	753	327	91	31		
	RadStd		8	42	81	101	160	113	172	103	91	57	18	3		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page