

SILLRE, Sweden

WMO: 023490

Lat: 62.7628N

Lon: 16.7392E

Elev: 205

StdP: 98.89

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.3	-23.9	-30.1	0.2	-25.2	-26.6	0.3	-22.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	24.8	15.8	22.6	14.7	20.9	14.2	17.4	21.0	16.3	19.7	15.3	18.5	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.1	11.7	18.6	15.0	10.9	17.2	14.0	10.2	16.4	49.7	21.5	46.5	19.6	43.4	18.3	20.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	DB	-29.2	27.4	3.7	1.9	-31.9	28.8	-34.0	29.9	-36.1	31.0	-38.7	32.4	(4)
(5)			WB	-29.4	19.0	3.4	1.4	-31.8	20.0	-33.8	20.9	-35.8	21.6	-38.2	22.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.8	-8.8	-7.8	-2.9	2.7	7.6	11.6	14.8	13.2	8.5	2.5	-2.0	-6.7
	DBStd	9.30	7.25	6.73	5.05	3.08	3.23	2.79	2.65	2.79	3.17	3.68	4.96	7.13
	HDD10.0	2981	583	498	399	220	90	14	0	4	66	232	359	517
	HDD18.3	5683	841	731	657	470	333	203	115	162	296	491	609	775
	CDD10.0	346	0	0	0	0	16	61	148	102	19	0	0	0
	CDD18.3	6	0	0	0	0	0	0	4	2	0	0	0	0
	CDH23.3	121	0	0	0	0	2	33	69	17	0	0	0	0
	CDH26.7	12	0	0	0	0	0	3	8	1	0	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	620	41	25	30	39	39	63	94	79	56	59	51	44
	PrecMax	916	82	62	65	96	97	122	219	167	161	136	138	83
	PrecMin	468	4	3	10	8	10	24	8	31	18	20	13	3
	PrecStd	123	21	16	14	23	21	29	55	45	34	31	34	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.9	6.0	10.0	18.0	23.3	26.7	28.0	25.7	19.5	13.1	9.4	6.2
		MCWB	2.7	3.3	5.2	9.8	13.0	14.6	17.8	17.0	14.0	9.6	7.8	3.8
	2%	DB	2.6	4.0	7.4	14.1	20.2	23.5	25.4	22.8	17.3	11.1	7.4	4.7
		MCWB	1.1	1.8	3.4	7.6	11.3	13.5	16.3	16.4	12.6	8.9	6.0	2.9
	5%	DB	1.0	2.5	5.7	11.7	17.7	20.9	23.2	20.8	15.6	9.7	5.4	3.4
		MCWB	0.0	0.8	2.5	5.8	10.3	12.7	15.2	15.5	11.8	8.2	4.6	2.1
	10%	DB	0.0	0.9	4.2	9.6	15.1	18.7	21.5	18.9	14.0	8.4	4.1	1.6
		MCWB	-0.5	-0.2	1.6	4.6	8.9	12.0	14.7	15.0	11.2	7.1	3.3	0.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.0	3.5	5.4	10.0	14.5	16.3	18.6	19.1	15.5	10.7	8.3	4.5
		MCDB	4.1	5.3	9.1	17.8	20.1	20.4	23.5	23.0	18.0	11.9	9.4	5.6
	2%	WB	1.5	2.2	3.9	7.9	12.6	14.7	17.5	17.6	13.6	9.4	6.2	3.1
		MCDB	2.3	3.7	6.6	13.3	17.6	20.1	22.1	20.3	15.6	10.5	7.1	4.3
	5%	WB	0.2	1.0	2.7	6.6	10.8	13.6	16.5	16.4	12.6	8.3	4.8	2.1
		MCDB	0.7	2.1	5.3	10.9	16.3	19.8	20.7	18.8	14.8	9.5	5.3	3.3
	10%	WB	-0.6	-0.2	1.7	5.1	9.6	12.7	15.5	15.3	11.6	7.2	3.4	0.7
		MCDB	0.0	0.8	4.0	8.8	14.7	18.0	19.3	17.8	13.4	8.4	4.0	1.4
Mean Daily Temperature Range	5% DB	MDBR	7.4	8.3	9.7	10.3	11.3	11.3	10.3	9.3	8.8	6.9	5.0	6.6
		MCDBR	6.2	7.2	10.0	15.4	16.2	15.8	14.0	12.2	10.7	8.8	6.3	7.5
		MCWBR	5.6	5.8	6.7	8.8	8.1	7.3	6.4	6.7	6.7	6.9	5.5	6.3
	5% WB	MCDBR	6.0	7.3	9.4	14.4	14.2	13.4	10.9	9.6	9.2	8.4	6.1	7.1
		MCWBR	5.6	6.1	6.6	8.6	7.6	6.8	6.0	6.0	6.4	6.9	5.5	6.1
Clear-Sky Solar Irradiance	taub	0.222	0.281	0.305	0.341	0.344	0.340	0.355	0.346	0.315	0.301	0.236	0.345	
	taud	2.085	2.251	2.338	2.398	2.453	2.493	2.467	2.486	2.560	2.473	2.166	2.690	
	Ebn at Noon	441	672	804	847	874	884	858	835	801	661	418	272	
	Edh at Noon	31	60	80	94	97	95	95	86	66	49	28	19	
All-Sky Solar Radiation	RadAvg	0.19	0.83	2.30	3.78	4.78	5.51	5.02	3.81	2.38	1.03	0.29	0.10	
	RadStd	0.03	0.13	0.26	0.32	0.51	0.36	0.54	0.32	0.29	0.18	0.06	0.01	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page