

BLOMSKOG, Sweden

WMO: 024080

Lat: 59.2213N

Lon: 12.0754E

Elev: 561

StdP: 14.40

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 1.5	(c) 6.9	(d) -2.7	(e) 4.9	(f) 3.9	(g) 2.7	(h) 6.4	(i) 9.7	(j) 14.0	(k) 36.0	(l) 12.5	(m) 34.2	(n) 1.5	(o) 300	(p) 0.566

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 17.0	(c) 77.7	(d) 62.8	(e) 74.5	(f) 61.5	(g) 71.2	(h) 60.1	(i) 65.4	(j) 73.2	(k) 63.7	(l) 70.7	(m) 62.1	(n) 68.3	(o) 4.8	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.8	87.4	67.1	61.1	82.2	65.7	59.5	77.5	64.4	30.5	73.3	29.3	70.9	28.1	68.4	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.9	(b) 10.5	(c) 9.5	(e) -4.8	(f) 81.3	(g) 5.7	(h) 3.2	(i) -8.9	(j) 83.5	(k) -12.3	(l) 85.4	(m) -15.5	(n) 87.1	(o) -19.6	(p) 89.4		
(4) 11.9	(5) 10.5	(6) 9.5	(7) -4.6	(8) 67.7	(9) 5.0	(10) 1.8	(11) -8.2	(12) 69.0	(13) -11.1	(14) 70.0	(15) -13.9	(16) 71.1	(17) -17.6	(18) 72.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.8	26.7	27.9	32.4	41.0	49.4	55.9	60.5	59.1	52.4	42.9	35.4	29.1
	DBStd	13.83	9.39	8.57	7.46	6.15	6.44	4.77	4.57	4.51	5.09	6.41	7.28	9.62
	HDD50	3615	723	618	547	278	89	6	0	1	34	233	438	648
	HDD65	8127	1188	1038	1012	719	483	275	156	189	380	686	888	1113
	CDD50	986	0	0	0	8	71	183	325	283	105	11	0	0
	CDD65	24	0	0	0	0	0	2	16	6	0	0	0	0
	CDH74	321	0	0	0	0	16	49	197	58	1	0	0	0
	CDH80	31	0	0	0	0	0	5	25	1	0	0	0	0
Wind	WSAvg	4.1	4.0	4.3	4.6	4.4	4.4	4.0	3.9	3.6	4.0	4.3	4.3	3.8
Precipitation	PrecAvg	31.5	2.6	1.7	1.7	1.7	2.2	2.8	3.1	3.3	3.0	3.5	3.1	2.6
	PrecMax	45.7	5.6	3.6	3.9	3.7	3.5	5.3	8.0	6.7	6.5	9.5	8.0	4.8
	PrecMin	23.9	0.5	0.4	0.1	0.3	0.8	0.6	0.4	0.9	0.9	0.4	0.9	0.7
	PrecStd	5.0	1.2	1.0	0.9	1.0	0.8	1.3	1.9	1.5	1.6	2.0	1.5	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.2	46.4	56.6	66.6	76.2	79.5	83.1	78.6	71.1	59.3	52.2	47.5
		MCWB	42.4	41.5	46.0	52.2	58.4	61.8	65.2	63.4	61.4	54.4	50.9	45.3
	2%	DB	41.8	42.8	49.9	61.6	71.5	74.5	79.2	75.6	66.5	56.1	49.9	45.1
		MCWB	40.4	40.4	41.9	50.2	56.6	60.2	64.0	63.3	58.5	53.4	47.8	43.2
	5%	DB	40.2	40.9	45.9	56.7	67.3	70.5	75.7	72.0	63.4	54.2	48.0	43.6
		MCWB	38.9	39.0	40.0	47.4	54.7	58.1	62.5	62.0	57.3	52.1	46.4	41.9
	10%	DB	38.5	39.1	42.7	52.6	62.4	67.0	71.8	68.5	60.9	52.3	45.7	41.5
		MCWB	37.2	37.4	38.2	45.0	52.0	56.7	61.0	60.6	55.8	50.3	44.5	40.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.2	43.6	47.1	55.0	61.7	64.8	68.0	66.9	63.0	56.2	51.5	46.0
		MCDB	43.8	45.6	54.5	63.2	71.9	72.9	76.6	72.8	66.9	57.5	52.0	46.8
	2%	WB	41.0	41.2	43.3	51.0	58.4	61.9	66.1	65.0	60.7	54.2	48.6	43.9
		MCDB	41.5	42.2	48.0	58.5	67.0	70.0	75.7	71.1	64.8	55.4	49.4	44.6
	5%	WB	39.2	39.4	41.2	48.6	55.9	59.8	64.2	63.4	58.5	52.4	46.6	42.0
		MCDB	39.9	40.5	44.4	55.1	64.5	68.0	72.2	69.2	61.8	53.7	47.6	42.8
	10%	WB	37.3	37.6	39.3	46.2	53.6	58.0	62.5	61.8	56.9	50.8	44.6	40.0
		MCDB	38.3	38.9	42.1	51.7	61.1	65.1	69.6	67.0	59.8	52.1	45.5	40.8
Mean Daily Temperature Range	5% DB	MDBR	8.9	9.8	14.1	16.8	18.3	17.2	17.0	15.9	14.4	11.1	8.1	8.7
		MCDBR	9.0	10.0	19.0	24.3	26.0	24.1	24.6	21.1	18.3	11.7	10.3	8.6
		MCWBR	8.9	7.9	12.2	14.0	13.2	11.9	11.4	10.6	11.1	9.3	10.2	9.0
	5% WB	MCDBR	8.5	9.1	16.5	21.1	21.7	20.6	20.8	17.6	15.2	10.4	9.9	8.9
		MCWBR	8.6	8.2	11.4	12.8	11.8	11.3	10.8	10.2	10.3	9.0	9.8	9.1
Clear-Sky Solar Irradiance	taub	0.272	0.308	0.329	0.368	0.363	0.353	0.374	0.368	0.338	0.327	0.291	0.249	
	taud	2.225	2.315	2.378	2.339	2.420	2.469	2.468	2.441	2.514	2.448	2.296	2.146	
	Ebn at Noon	171	225	257	265	275	280	270	263	254	218	162	133	
	Edh at Noon	14	21	27	33	33	32	32	30	23	19	13	10	
All-Sky Solar Radiation	RadAvg	99	281	766	1218	1604	1837	1644	1292	863	384	130	67	
	RadStd	18	53	78	162	153	112	200	111	99	68	30	7	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (60 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page