

BLOMSKOG, Sweden

WMO: 024080

Lat: 59.2213N

Lon: 12.0754E

Elev: 171

StdP: 99.29

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.0	-14.0	-19.3	0.7	-15.6	-16.3	0.9	-12.4	6.3	2.2	5.6	1.2	0.7	300	0.566

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	25.4	17.1	23.6	16.4	21.8	15.6	18.6	22.9	17.6	21.5	16.7	20.2	2.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.1	12.5	19.5	16.2	11.7	18.7	15.3	11.1	18.0	53.2	22.9	50.2	21.6	47.5	20.2	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.3	4.7	4.2	-20.5	27.4	3.2	1.8	-22.7	28.6	-24.6	29.6	-26.4	30.6	-28.7	31.9		
(5)			-20.3	19.8	2.8	1.0	-22.3	20.6	-24.0	21.1	-25.5	21.7	-27.6	22.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.0	-3.0	-2.3	0.2	5.0	9.7	13.3	15.8	15.0	11.3	6.0	1.9	-1.6	(6)
(7)		DBStd	7.68	5.22	4.76	4.14	3.42	3.58	2.65	2.54	2.50	2.83	3.56	4.05	5.34	(7)
(8)		HDD10.0	2008	402	343	304	154	49	3	0	1	19	129	243	360	(8)
(9)		HDD18.3	4515	660	577	562	399	268	153	87	105	211	381	493	618	(9)
(10)		CDD10.0	548	0	0	0	4	39	102	181	157	58	6	0	0	(10)
(11)		CDD18.3	13	0	0	0	0	0	1	9	3	0	0	0	0	(11)
(12)		CDH23.3	178	0	0	0	0	9	27	109	32	1	0	0	0	(12)
(13)		CDH26.7	17	0	0	0	0	0	3	14	1	0	0	0	0	(13)
(14)	Wind	WSAvg	1.8	1.8	1.9	2.0	2.0	2.0	1.8	1.7	1.6	1.8	1.9	1.9	1.7	(14)
(15)	Precipitation	PrecAvg	800	65	44	42	44	55	70	79	85	75	88	80	65	(15)
(16)		PrecMax	1161	142	92	100	95	89	134	202	169	166	242	203	123	(16)
(17)		PrecMin	607	13	9	2	8	20	16	9	24	22	11	23	18	(17)
(18)		PrecStd	128	31	25	23	26	20	32	48	37	40	51	38	31	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.8	8.0	13.6	19.2	24.6	26.4	28.4	25.9	21.7	15.2	11.2	8.6	(19)
(20)			MCWB	5.8	5.3	7.8	11.2	14.7	16.5	18.4	17.4	16.3	12.4	10.5	7.4	(20)
(21)		2%	DB	5.4	6.0	9.9	16.5	22.0	23.6	26.2	24.2	19.2	13.4	9.9	7.3	(21)
(22)			MCWB	4.6	4.7	5.5	10.1	13.7	15.7	17.8	17.4	14.7	11.9	8.8	6.2	(22)
(23)		5%	DB	4.6	4.9	7.7	13.7	19.6	21.4	24.3	22.2	17.4	12.3	8.9	6.4	(23)
(24)			MCWB	3.8	3.9	4.4	8.6	12.6	14.5	16.9	16.6	14.1	11.1	8.0	5.5	(24)
(25)		10%	DB	3.6	3.9	5.9	11.4	16.9	19.5	22.1	20.3	16.0	11.3	7.6	5.3	(25)
(26)			MCWB	2.9	3.0	3.5	7.2	11.1	13.7	16.1	15.9	13.2	10.1	6.9	4.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.2	6.4	8.4	12.8	16.5	18.2	20.0	19.4	17.2	13.5	10.9	7.8	(27)
(28)			MCDWB	6.6	7.6	12.5	17.3	22.2	22.7	24.8	22.7	19.4	14.2	11.1	8.2	(28)
(29)		2%	WB	5.0	5.1	6.3	10.6	14.7	16.6	18.9	18.3	15.9	12.3	9.2	6.6	(29)
(30)			MCDWB	5.3	5.7	8.9	14.7	19.4	21.1	24.3	21.7	18.2	13.0	9.7	7.0	(30)
(31)		5%	WB	4.0	4.1	5.1	9.2	13.3	15.5	17.9	17.5	14.7	11.3	8.1	5.5	(31)
(32)			MCDWB	4.4	4.7	6.9	12.8	18.1	20.0	22.3	20.7	16.5	12.0	8.7	6.0	(32)
(33)		10%	WB	2.9	3.1	4.0	7.9	12.0	14.5	17.0	16.6	13.8	10.5	7.0	4.5	(33)
(34)			MCDWB	3.5	3.8	5.6	10.9	16.2	18.4	20.9	19.5	15.4	11.2	7.5	4.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.9	5.5	7.8	9.3	10.1	9.5	9.4	8.8	8.0	6.2	4.5	4.9	(35)
(36)			MCDBR	5.0	5.5	10.6	13.5	14.5	13.4	13.7	11.7	10.2	6.5	5.7	4.8	(36)
(37)			MCWBR	4.9	4.4	6.8	7.8	7.3	6.6	6.4	5.9	6.2	5.1	5.6	5.0	(37)
(38)		5% WB	MCDBR	4.7	5.1	9.2	11.7	12.0	11.4	11.5	9.8	8.5	5.8	5.5	5.0	(38)
(39)			MCWBR	4.8	4.6	6.4	7.1	6.6	6.3	6.0	5.7	5.7	5.0	5.4	5.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.272	0.308	0.329	0.368	0.363	0.353	0.374	0.368	0.338	0.327	0.291	0.249	(40)	
(41)		taud	2.225	2.315	2.378	2.339	2.420	2.469	2.428	2.441	2.514	2.448	2.296	2.146	(41)	
(42)		Ebn at Noon	539	710	811	835	867	882	851	829	801	686	512	420	(42)	
(43)		Edh at Noon	43	67	85	104	103	100	102	94	74	59	41	32	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.31	0.89	2.42	3.84	5.06	5.79	5.18	4.07	2.72	1.21	0.41	0.21	(44)	
(45)		RadStd	0.06	0.17	0.25	0.51	0.48	0.35	0.63	0.35	0.31	0.21	0.10	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (60 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page