

ARVIKA, Sweden

WMO: 024110

Lat: 59.6743N

Lon: 12.6354E

Elev: 216

StdP: 14.58

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.9	-2.6	-14.5	2.5	-9.8	-6.6	3.9	-2.3	15.7	33.6	13.6	34.4	0.1	270	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.5	81.4	63.7	78.0	62.7	74.5	61.2	66.7	76.2	64.8	73.3	63.2	71.1	4.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.6	88.6	69.3	61.7	82.9	67.7	60.0	77.9	66.1	31.4	75.8	29.9	73.3	28.7	71.4	73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.2	10.8	9.4	DB	-14.3	85.0	8.6	3.1	-20.5	87.2	-25.6	89.0	-30.4	90.7	-36.7	92.9	(4)
			WB	-14.1	69.8	8.1	2.3	-20.0	71.5	-24.7	72.8	-29.3	74.1	-35.2	75.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.9	23.4	24.5	31.4	40.6	49.8	57.2	61.7	59.0	51.0	41.8	34.3	26.2
	DBStd	15.41	11.65	9.71	8.23	5.84	6.72	4.83	4.98	4.77	5.56	7.10	7.78	11.72
	HDD50	4025	825	714	577	288	87	4	0	2	54	267	470	737
	HDD65	8487	1290	1134	1042	731	472	237	128	192	420	719	920	1202
	CDD50	1049	0	0	0	7	81	219	364	281	84	13	0	0
	CDD65	37	0	0	0	0	1	3	27	6	0	0	0	0
	CDH74	807	0	0	0	0	52	170	472	113	0	0	0	0
	CDH80	149	0	0	0	0	4	26	112	7	0	0	0	0
Wind	WSAvg	3.6	3.5	3.4	3.7	3.9	4.1	4.0	3.6	3.4	3.5	3.6	3.8	3.2
Precipitation	PrecAvg	28.0	2.1	1.5	1.3	1.8	2.0	2.7	3.0	3.3	2.7	2.8	2.6	2.0
	PrecMax	40.0	4.1	3.1	3.7	3.8	3.7	5.5	7.7	5.7	5.2	8.2	7.8	3.8
	PrecMin	20.5	0.6	0.5	0.1	0.3	0.3	0.4	0.7	0.6	0.8	1.0	0.5	0.5
	PrecStd	4.1	0.9	0.7	0.8	1.1	1.0	1.3	1.5	1.5	1.3	1.5	1.5	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.7	46.0	58.9	68.6	79.8	83.3	86.9	80.9	72.5	61.1	53.3	50.4
		MCWB	42.7	41.4	47.0	52.6	59.5	62.9	65.8	65.2	61.3	54.7	51.0	47.6
	2%	DB	42.5	42.4	51.9	63.7	74.3	79.0	83.3	77.3	67.9	57.8	50.6	46.8
		MCWB	39.8	38.9	43.0	50.2	57.7	60.9	65.3	63.9	58.9	53.1	48.2	44.7
	5%	DB	40.5	40.2	46.9	58.7	69.7	74.7	79.7	73.9	64.8	55.8	48.4	44.0
		MCWB	38.5	37.8	40.0	47.6	55.7	59.6	64.0	62.2	57.4	52.0	46.5	42.0
	10%	DB	37.9	37.8	43.2	54.7	64.9	70.6	75.8	70.5	61.9	53.6	45.9	41.2
		MCWB	36.0	35.8	38.1	45.0	53.2	57.4	62.6	60.8	55.7	50.5	44.2	39.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.5	42.9	48.2	54.9	63.3	65.9	69.4	68.7	62.8	56.7	51.9	48.0
		MCDB	45.4	45.2	57.7	65.6	72.9	75.2	79.9	76.5	68.1	59.7	53.2	50.2
	2%	WB	40.6	40.0	43.9	51.0	60.0	63.4	67.4	65.8	60.5	54.6	48.7	45.0
		MCDB	41.9	41.8	50.3	61.2	69.9	73.9	77.9	72.5	65.7	56.9	50.1	46.6
	5%	WB	38.6	38.1	41.2	48.6	57.3	61.3	65.8	64.0	58.5	52.6	46.6	42.1
		MCDB	40.2	39.9	45.8	57.3	66.4	71.5	75.9	70.5	63.1	54.9	48.1	43.6
	10%	WB	36.2	35.8	39.0	46.1	54.7	59.2	64.0	62.5	56.7	50.8	44.3	39.6
		MCDB	37.8	37.8	42.5	52.8	62.8	68.2	72.7	68.9	60.8	53.2	45.7	41.0
Mean Daily Temperature Range	5% DB	MDBR	13.1	15.3	19.2	22.1	22.7	21.8	21.5	20.1	19.8	15.4	11.0	12.1
		MCDBR	12.2	15.4	25.6	31.1	31.5	31.7	30.4	26.5	24.2	17.5	13.6	13.0
		MCWBR	11.5	12.5	17.3	18.5	16.5	15.6	14.3	14.5	15.6	13.1	12.5	12.0
	5% WB	MCDBR	11.7	13.8	22.6	27.6	25.2	26.3	26.1	22.3	20.6	14.6	12.6	12.6
		MCWBR	11.3	11.7	15.8	17.1	13.9	14.4	13.3	13.3	14.3	12.0	12.0	11.9
Clear-Sky Solar Irradiance	taub	0.269	0.310	0.334	0.375	0.372	0.361	0.382	0.374	0.343	0.331	0.291	0.247	
	taud	2.205	2.284	2.346	2.316	2.394	2.448	2.407	2.426	2.503	2.437	2.286	2.130	
	Ebn at Noon	166	221	253	261	272	277	267	260	251	213	157	126	
	Edh at Noon	13	22	28	34	34	32	33	30	24	19	12	10	
All-Sky Solar Radiation	RadAvg	94	281	770	1210	1559	1799	1606	1260	840	372	122	63	
	RadStd	16	56	80	159	152	109	204	129	101	71	31	7	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (60 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page