

ARVIKA, Sweden

WMO: 024110

Lat: 59.6743N

Lon: 12.6354E

Elev: 66

StdP: 100.54

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.3	-19.2	-25.8	0.4	-23.2	-21.4	0.6	-19.1	7.0	0.9	6.1	1.3	0.1	270	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	27.5	17.6	25.5	17.0	23.6	16.2	19.3	24.5	18.2	22.9	17.3	21.7	2.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.5	12.7	20.7	16.5	11.8	19.8	15.6	11.1	19.0	55.0	24.4	51.8	22.9	48.9	21.9	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	4.8	4.2	-25.7	29.4	4.8	1.7	-29.2	30.7	-32.0	31.7	-34.7	32.6	-38.2	33.8		
(5)			-25.6	21.0	4.5	1.3	-28.9	21.9	-31.5	22.7	-34.1	23.4	-37.3	24.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.5	-4.8	-4.2	-0.3	4.8	9.9	14.0	16.5	15.0	10.6	5.5	1.3	-3.2	(6)
(7)		DBStd	8.56	6.47	5.39	4.57	3.25	3.73	2.68	2.77	2.65	3.09	3.94	4.32	6.51	(7)
(8)		HDD10.0	2236	458	397	321	160	48	2	0	1	30	148	261	409	(8)
(9)		HDD18.3	4715	717	630	579	406	262	132	71	107	233	399	511	668	(9)
(10)		CDD10.0	583	0	0	0	4	45	122	202	156	47	7	0	0	(10)
(11)		CDD18.3	21	0	0	0	0	1	2	15	3	0	0	0	0	(11)
(12)		CDH23.3	448	0	0	0	0	29	94	262	63	0	0	0	0	(12)
(13)		CDH26.7	83	0	0	0	0	2	14	62	4	0	0	0	0	(13)
(14)	Wind	WSAvg	1.6	1.5	1.5	1.6	1.7	1.8	1.8	1.6	1.5	1.6	1.6	1.7	1.4	(14)
(15)	Precipitation	PrecAvg	710	53	37	34	45	50	69	76	85	68	70	67	52	(15)
(16)		PrecMax	1015	103	79	93	97	94	139	196	145	132	208	199	96	(16)
(17)		PrecMin	520	14	12	2	7	7	9	17	19	14	20	25	13	(17)
(18)		PrecStd	105	24	18	20	27	25	33	39	39	32	39	38	23	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.6	7.8	14.9	20.3	26.6	28.5	30.5	27.2	22.5	16.2	11.8	10.2	(19)
(20)			MCWB	6.0	5.2	8.3	11.4	15.3	17.1	18.8	18.5	16.3	12.6	10.6	8.6	(20)
(21)		2%	DB	5.8	5.8	11.0	17.6	23.5	26.1	28.5	25.2	19.9	14.4	10.3	8.2	(21)
(22)			MCWB	4.4	3.9	6.1	10.1	14.3	16.1	18.5	17.7	14.9	11.7	9.0	7.0	(22)
(23)		5%	DB	4.7	4.6	8.3	14.8	21.0	23.7	26.5	23.3	18.2	13.2	9.1	6.7	(23)
(24)			MCWB	3.6	3.2	4.4	8.7	13.2	15.3	17.8	16.8	14.1	11.1	8.1	5.5	(24)
(25)		10%	DB	3.3	3.2	6.2	12.6	18.3	21.4	24.4	21.4	16.6	12.0	7.7	5.1	(25)
(26)			MCWB	2.2	2.1	3.4	7.2	11.8	14.1	17.0	16.0	13.2	10.3	6.8	4.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.4	6.1	9.0	12.7	17.4	18.8	20.8	20.4	17.1	13.7	11.0	8.9	(27)
(28)			MCDWB	7.5	7.3	14.3	18.7	22.7	24.0	26.6	24.7	20.0	15.4	11.8	10.1	(28)
(29)		2%	WB	4.8	4.5	6.6	10.6	15.5	17.4	19.7	18.8	15.8	12.5	9.3	7.2	(29)
(30)			MCDWB	5.5	5.4	10.2	16.2	21.1	23.3	25.5	22.5	18.7	13.8	10.1	8.1	(30)
(31)		5%	WB	3.7	3.4	5.1	9.2	14.1	16.3	18.8	17.8	14.7	11.5	8.1	5.6	(31)
(32)			MCDWB	4.5	4.4	7.6	14.0	19.1	21.9	24.4	21.4	17.3	12.7	8.9	6.5	(32)
(33)		10%	WB	2.3	2.1	3.9	7.8	12.6	15.1	17.8	16.9	13.7	10.5	6.8	4.2	(33)
(34)			MCDWB	3.2	3.2	5.9	11.5	17.1	20.1	22.6	20.5	16.0	11.8	7.6	5.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.3	8.5	10.7	12.3	12.6	12.1	11.9	11.2	11.0	8.6	6.1	6.7	(35)
(36)			MCDBR	6.8	8.5	14.2	17.3	17.5	17.6	16.9	14.7	13.4	9.7	7.6	7.2	(36)
(37)			MCWBR	6.4	6.9	9.6	10.3	9.2	8.7	8.0	8.1	8.7	7.3	6.9	6.6	(37)
(38)		5% WB	MCDWR	6.5	7.7	12.5	15.3	14.0	14.6	14.5	12.4	11.4	8.1	7.0	7.0	(38)
(39)			MCWBR	6.3	6.5	8.8	9.5	7.7	8.0	7.4	7.4	7.9	6.7	6.7	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.269	0.310	0.334	0.375	0.372	0.361	0.382	0.374	0.343	0.331	0.291	0.247	(40)	
(41)		taud	2.205	2.284	2.346	2.316	2.394	2.448	2.407	2.426	2.503	2.437	2.286	2.130	(41)	
(42)		Ebn at Noon	523	696	799	824	857	872	841	819	791	673	494	397	(42)	
(43)		Edh at Noon	42	68	87	106	106	102	104	95	75	59	39	30	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.30	0.89	2.43	3.81	4.92	5.67	5.06	3.97	2.65	1.17	0.39	0.20	(44)	
(45)		RadStd	0.05	0.17	0.25	0.50	0.48	0.34	0.64	0.41	0.32	0.22	0.10	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (60 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page