

BRATTMON, Sweden

WMO: 024130

Lat: 60.7569N

Lon: 12.7723E

Elev: 653

StdP: 14.35

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.5	-6.6	-15.4	2.4	-11.4	-10.0	3.3	-6.6	10.8	34.9	9.6	35.4	1.8	320	0.590

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.8	80.8	63.6	77.1	62.1	73.5	60.0	65.6	76.4	63.7	73.4	62.0	70.5	4.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.0	85.1	68.2	60.1	79.5	66.4	58.4	74.6	64.8	30.7	76.8	29.3	73.4	28.1	70.7	70.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.9	8.7	7.5	-16.6	84.8	4.8	3.1	-20.0	87.0	-22.8	88.8	-25.5	90.6	-29.0	92.8		
(5)			-16.9	68.0	4.5	1.6	-20.1	69.2	-22.8	70.1	-25.3	71.1	-28.6	72.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	39.2	18.0	21.3	30.1	39.5	47.7	55.5	60.2	57.9	49.6	39.5	30.7	19.9	(6)
(7)		DBStd	16.71	12.35	9.96	8.38	5.57	6.52	5.39	4.84	4.97	5.52	7.38	8.91	13.24	(7)
(8)		HDD50	4787	992	805	618	317	123	11	0	4	73	331	579	934	(8)
(9)		HDD65	9424	1457	1225	1083	765	537	289	163	224	463	790	1029	1399	(9)
(10)		CDD50	861	0	0	0	1	51	177	317	249	60	6	0	0	(10)
(11)		CDD65	23	0	0	0	0	0	4	15	4	0	0	0	0	(11)
(12)		CDH74	660	0	0	0	0	34	185	336	104	1	0	0	0	(12)
(13)		CDH80	113	0	0	0	0	3	36	66	8	0	0	0	0	(13)
(14)	Wind	WSAvg	3.1	2.6	2.8	3.4	3.5	3.8	3.6	3.3	3.0	2.9	2.9	2.6	(14)	
(15)	Precipitation	PrecAvg	29.0	2.0	1.4	1.2	1.6	2.4	3.2	3.4	3.8	2.8	2.8	2.4	2.0	(15)
(16)		PrecMax	39.8	4.7	2.4	2.6	4.0	7.3	5.9	7.4	5.7	5.0	6.2	6.8	3.7	(16)
(17)		PrecMin	22.8	0.4	0.3	0.2	0.4	0.2	0.3	1.2	1.4	0.9	0.6	0.8	0.2	(17)
(18)		PrecStd	3.5	1.0	0.6	0.6	1.0	1.5	1.3	1.3	1.3	1.0	1.3	1.4	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.3	44.7	57.7	67.1	78.6	84.3	85.7	81.1	71.3	59.5	52.0	48.4	(19)
(20)			MCWB	40.2	40.5	45.9	51.5	60.2	64.3	65.7	63.7	58.0	52.4	49.0	44.6	(20)
(21)		2%	DB	39.5	40.5	50.9	62.6	72.6	79.6	81.9	77.0	66.6	56.7	49.3	44.3	(21)
(22)			MCWB	36.9	36.9	41.6	49.8	56.5	61.7	65.0	62.6	56.7	51.4	45.8	41.9	(22)
(23)		5%	DB	36.6	37.1	45.8	58.2	68.2	74.6	78.2	73.5	63.2	53.6	46.0	40.4	(23)
(24)			MCWB	34.8	34.3	38.8	46.5	53.9	58.7	63.1	61.0	54.6	49.8	43.6	38.2	(24)
(25)		10%	DB	33.7	34.4	41.9	53.7	62.4	70.3	74.0	69.8	60.3	51.1	43.0	36.6	(25)
(26)			MCWB	32.5	32.7	36.5	44.1	50.2	56.9	61.3	60.1	53.4	48.0	41.2	35.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.5	40.6	46.4	53.7	61.5	66.1	68.2	67.3	60.6	55.0	49.6	45.1	(27)
(28)			MCDWB	42.7	43.6	56.4	64.3	74.5	80.0	81.4	75.6	68.1	57.9	52.0	47.8	(28)
(29)		2%	WB	37.4	37.7	42.2	50.3	58.1	63.2	66.2	64.6	58.2	52.4	46.3	41.8	(29)
(30)			MCDWB	39.0	40.1	49.4	61.3	70.1	76.7	78.5	72.3	63.5	55.0	48.9	43.9	(30)
(31)		5%	WB	34.8	34.9	39.5	47.4	55.1	60.9	64.4	62.8	56.2	50.3	44.0	38.5	(31)
(32)			MCDWB	36.2	36.6	44.7	56.2	64.5	71.8	75.0	70.1	61.4	52.9	45.9	40.3	(32)
(33)		10%	WB	32.7	32.8	37.4	44.8	52.7	58.6	62.6	61.1	54.2	48.4	41.3	35.0	(33)
(34)			MCDWB	33.8	34.3	41.2	51.8	60.7	67.4	71.5	67.8	58.9	51.1	42.8	36.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.3	16.2	20.4	22.6	22.8	23.9	21.8	20.9	20.0	14.8	10.7	11.7	(35)
(36)			MCDBR	12.1	17.4	25.4	33.2	33.0	33.5	31.3	27.9	24.3	17.0	13.8	13.2	(36)
(37)			MCWBR	10.6	13.5	16.8	20.1	17.5	17.1	15.4	14.7	14.7	12.2	11.7	11.8	(37)
(38)		5% WB	MCDWB	12.0	14.4	22.4	30.5	28.6	28.8	26.3	23.9	20.9	14.8	13.0	13.3	(38)
(39)			MCWBR	10.7	11.5	15.2	19.0	15.8	15.9	13.5	13.9	13.5	11.3	11.4	12.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.238	0.284	0.312	0.352	0.355	0.347	0.368	0.358	0.326	0.311	0.259	N/A	(40)	
(41)		taud	2.178	2.275	2.302	2.345	2.425	2.471	2.429	2.450	2.528	2.479	2.269	N/A	(41)	
(42)		Ebn at Noon	167	226	258	268	276	280	270	264	255	217	158	N/A	(42)	
(43)		Edh at Noon	12	20	28	32	32	31	32	29	23	17	11	N/A	(43)	
(44)	All-Sky Solar Radiation	RadAvg	89	298	776	1236	1492	1687	1510	1182	782	350	110	52	(44)	
(45)		RadStd	13	57	84	144	146	116	209	120	96	67	31	6	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (49 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page