

GUSTAVSFORS, Sweden

WMO: 024260

Lat: 60.151N

Lon: 13.797E

Elev: 188

StdP: 99.09

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.6	-21.3	-27.0	0.3	-24.5	-23.5	0.5	-21.3	7.4	2.2	6.5	1.8	0.0	10	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	26.3	17.2	24.5	16.6	22.7	15.8	18.9	23.9	17.8	22.2	16.9	20.9	2.1	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	12.5	20.2	16.2	11.8	19.5	15.2	11.0	18.5	54.3	23.9	51.0	22.2	48.1	21.0	21.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.6	4.8	4.2	DB	-27.3	28.5	3.8	1.6	-30.0	29.7	-32.3	30.7	-34.4	31.6	-37.1	32.8	(4)
(5)			WB	-27.5	20.1	3.6	1.1	-30.1	20.8	-32.2	21.5	-34.2	22.1	-36.8	22.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.2	-6.5	-5.5	-1.8	3.7	8.7	12.9	15.3	13.7	9.4	4.4	0.0	-5.0	(6)	
	DBStd	8.77	6.65	5.39	4.98	3.31	3.77	2.91	2.80	2.70	3.12	3.75	4.51	6.87	(7)	
	HDD10.0	2572	511	436	367	191	71	7	0	3	47	176	301	463	(8)	
	HDD18.3	5183	769	669	626	439	299	164	100	144	269	431	551	722	(9)	
	CDD10.0	441	0	0	0	2	30	93	166	119	28	3	0	0	(10)	
	CDD18.3	10	0	0	0	0	0	1	7	2	0	0	0	0	(11)	
	CDH23.3	286	0	0	0	0	15	70	168	33	0	0	0	0	(12)	
	CDH26.7	38	0	0	0	0	1	8	28	1	0	0	0	0	(13)	
(14) Wind	WSAvg	1.5	1.4	1.3	1.5	1.5	1.8	1.6	1.5	1.5	1.5	1.5	1.5	1.4	(14)	
(15) Precipitation	PrecAvg	736	53	39	36	44	58	73	85	85	65	74	67	58	(15)	
	PrecMax	984	110	77	70	123	142	149	224	146	111	177	143	111	(16)	
	PrecMin	588	10	8	3	12	14	10	22	32	6	22	26	12	(17)	
	PrecStd	90	27	18	20	26	30	32	38	33	30	35	30	26	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.2	6.5	13.5	19.4	25.4	27.8	29.2	26.1	21.3	15.4	10.9	9.0	(19)	
		MCWB	5.1	4.0	7.5	10.8	14.9	16.9	18.9	18.1	15.7	12.1	10.4	8.1	(20)	
	2%	DB	4.3	4.6	9.9	16.7	22.7	25.3	27.2	24.2	18.9	13.3	9.2	6.9	(21)	
		MCWB	3.4	3.2	5.4	9.3	13.7	16.2	18.0	17.5	14.4	11.4	8.4	6.2	(22)	
	5%	DB	3.0	3.2	7.2	14.2	20.3	23.3	25.3	22.4	17.2	12.0	7.7	5.3	(23)	
		MCWB	2.4	2.2	3.6	7.9	12.7	15.3	17.2	16.7	13.5	10.6	7.1	4.6	(24)	
	10%	DB	1.7	1.9	4.9	11.7	17.4	21.0	23.1	20.4	15.6	10.8	6.4	3.5	(25)	
		MCWB	1.1	1.1	2.3	6.4	11.2	13.9	16.4	15.9	12.7	9.6	5.8	2.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	5.0	7.8	12.0	16.5	18.7	20.5	19.6	16.7	13.2	10.4	8.4	(27)	
		MCDB	5.8	5.7	12.3	18.3	22.4	23.9	25.8	23.5	19.4	14.5	10.6	9.0	(28)	
	2%	WB	3.6	3.5	5.7	10.0	15.1	17.2	19.4	18.4	15.2	11.9	8.6	6.3	(29)	
		MCDB	4.0	4.2	9.3	15.2	20.6	23.2	25.0	22.0	17.9	12.8	9.1	6.8	(30)	
	5%	WB	2.5	2.3	4.1	8.5	13.6	16.1	18.4	17.4	14.1	10.8	7.2	4.6	(31)	
		MCDB	2.9	2.9	6.3	13.3	18.3	21.6	23.6	20.8	16.3	11.8	7.7	5.0	(32)	
	10%	WB	1.2	1.1	2.9	7.1	12.1	14.9	17.3	16.5	13.1	9.7	5.8	2.9	(33)	
		MCDB	1.6	1.8	4.5	10.8	16.5	20.1	21.5	19.7	15.1	10.6	6.3	3.4	(34)	
(35) Mean Daily Temperature Range	MDBR		7.4	8.9	11.0	12.4	12.5	12.5	12.0	11.5	10.9	8.2	6.1	6.8	(35)	
	5% DB	MCDBR	6.4	8.8	14.0	18.0	18.1	18.1	16.7	15.3	13.6	9.9	7.1	7.1	(36)	
		MCWBR	6.1	7.3	9.5	11.1	10.0	9.6	8.4	9.1	9.4	7.8	6.6	7.0	(37)	
	5% WB	MCDBR	6.5	7.2	12.2	15.9	14.7	15.0	14.4	13.1	12.3	8.2	6.7	7.0	(38)	
		MCWBR	6.2	6.2	8.6	10.2	8.6	8.4	7.9	8.3	9.0	7.0	6.4	6.9	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.254	0.297	0.324	0.362	0.362	0.353	0.373	0.364	0.333	0.320	0.276	0.231	(40)	
	taud		2.200	2.288	2.349	2.352	2.413	2.462	2.422	2.442	2.519	2.460	2.280	2.112	(41)	
	Ebn at Noon		529	705	807	837	865	879	848	828	800	682	496	395	(42)	
	Edh at Noon		40	66	85	102	103	100	102	93	73	56	37	28	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.29	0.92	2.43	3.83	4.80	5.48	4.92	3.85	2.56	1.14	0.36	0.18	(44)	
	RadStd		0.05	0.17	0.27	0.48	0.47	0.35	0.64	0.41	0.32	0.22	0.10	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (53 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page