

DAGLOSEN, Sweden

WMO: 024290

Lat: 59.6612N

Lon: 14.1803E

Elev: 436

StdP: 14.47

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.4	1.0	-7.8	3.7	-3.8	-1.9	5.1	2.3	14.4	36.4	13.2	35.9	2.2	320	0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	79.2	64.0	75.9	62.6	72.6	61.2	66.8	75.2	65.0	72.3	63.1	69.6	4.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.9	90.4	69.2	62.1	84.8	67.4	60.4	79.6	66.1	31.6	74.9	30.2	72.8	28.8	69.7	72.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.0	10.4	9.3	-10.1	83.2	7.4	3.3	-15.4	85.6	-19.8	87.6	-23.9	89.5	-29.3	91.9		
			-9.8	69.4	6.8	2.4	-14.7	71.1	-18.7	72.5	-22.5	73.8	-27.5	75.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.8	24.2	24.9	30.7	40.1	49.2	56.5	60.9	58.8	51.3	41.9	34.5	27.0
	DBStd	14.88	10.45	8.87	8.13	5.91	6.54	5.03	4.96	4.64	5.39	6.88	7.34	10.86
	HDD50	3994	798	702	598	302	94	6	0	3	49	262	466	714
	HDD65	8510	1263	1122	1063	746	489	258	149	198	411	716	916	1179
	CDD50	987	0	0	0	5	70	201	337	275	88	11	0	0
	CDD65	30	0	0	0	0	0	4	21	5	0	0	0	0
	CDH74	496	0	0	0	0	24	117	284	71	0	0	0	0
	CDH80	66	0	0	0	0	0	13	50	3	0	0	0	0
Wind	WSAvg	4.0	4.3	4.1	4.4	4.4	4.4	3.8	3.4	3.3	3.5	4.0	4.5	4.2
Precipitation	PrecAvg	29.5	2.3	1.7	1.4	1.7	2.0	2.5	3.1	3.4	3.0	2.9	3.0	2.5
	PrecMax	41.0	4.8	3.7	2.6	5.3	4.3	5.1	9.4	6.7	5.3	6.5	6.5	4.4
	PrecMin	24.2	0.4	0.4	0.2	0.6	0.5	0.4	0.4	0.8	0.7	1.2	1.2	0.5
	PrecStd	3.8	1.1	0.9	0.7	1.0	1.0	1.2	1.9	1.5	1.3	1.4	1.3	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.1	44.1	57.6	67.1	77.7	81.8	84.5	79.7	70.9	60.4	52.2	48.5
		MCWB	42.8	40.5	46.4	52.6	60.0	63.7	67.0	64.3	60.9	55.3	51.2	47.4
	2%	DB	41.1	41.3	50.1	62.4	72.6	77.3	80.7	75.9	66.6	56.5	49.4	45.6
		MCWB	40.0	39.3	42.2	50.0	57.5	62.0	65.8	63.9	59.2	53.4	48.4	44.5
	5%	DB	38.9	38.7	45.4	57.3	68.3	73.7	77.2	72.5	63.4	54.3	47.1	42.8
		MCWB	37.9	37.3	39.2	46.7	55.5	60.3	64.2	62.5	57.3	52.2	46.2	41.8
	10%	DB	36.7	36.6	41.4	53.1	63.5	69.3	73.1	69.0	60.7	52.3	45.0	40.2
		MCWB	35.8	35.4	37.5	44.3	53.2	58.3	62.6	61.5	55.8	50.5	44.0	39.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.2	41.6	47.1	54.6	62.4	66.5	69.6	68.2	62.8	56.7	51.7	47.8
		MCDB	43.7	42.6	55.6	64.8	72.4	76.7	78.6	73.9	67.7	58.6	52.0	48.2
	2%	WB	40.4	39.6	43.1	50.4	59.4	64.1	67.7	66.0	60.3	54.5	48.7	44.8
		MCDB	40.8	40.8	49.0	59.8	69.6	73.8	77.7	72.3	64.6	55.8	49.2	45.6
	5%	WB	38.0	37.7	40.5	48.1	56.8	62.0	65.8	64.1	58.5	52.7	46.5	42.2
		MCDB	38.7	38.5	43.9	56.1	65.6	71.0	74.3	69.6	62.5	54.0	47.1	42.8
	10%	WB	36.0	35.5	38.4	45.4	54.4	59.8	63.9	62.5	56.7	50.9	44.3	39.7
		MCDB	36.7	36.6	41.2	51.6	61.9	68.0	70.7	67.7	60.0	52.2	45.0	40.4
Mean Daily Temperature Range	5% DB	MDBR	10.4	12.6	16.7	20.1	20.1	20.0	18.5	17.6	16.4	12.7	8.8	10.0
		MCDBR	9.7	11.7	22.7	28.5	28.7	29.0	26.9	24.0	20.1	14.0	11.0	10.5
		MCWBR	9.7	9.7	15.2	17.1	15.6	15.1	13.0	13.5	12.8	11.1	10.4	10.3
	5% WB	MCDBR	9.1	10.0	19.9	25.5	24.6	25.0	23.5	20.4	18.2	12.2	10.5	10.5
		MCWBR	9.1	8.9	14.0	16.1	14.1	14.0	12.4	12.3	12.6	10.3	10.0	10.4
Clear-Sky Solar Irradiance	taub	0.261	0.302	0.327	0.365	0.363	0.354	0.374	0.366	0.336	0.324	0.285	0.240	
	taud	2.213	2.300	2.372	2.354	2.420	2.467	2.427	2.445	2.517	2.459	2.292	2.131	
	Ebn at Noon	171	225	257	265	275	279	269	263	254	217	160	130	
	Edh at Noon	13	21	27	32	33	32	32	30	23	18	12	10	
All-Sky Solar Radiation	RadAvg	94	286	774	1221	1556	1779	1606	1260	838	374	121	63	
	RadStd	16	54	88	148	151	115	192	135	106	69	30	6	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (61 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page