

DAGLOSEN, Sweden

WMO: 024290

Lat: 59.6612N

Lon: 14.1803E

Elev: 133

StdP: 99.74

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.2	-17.2	-22.1	0.5	-19.9	-18.8	0.7	-16.5	6.4	2.4	5.9	2.2	1.0	320	0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	26.2	17.8	24.4	17.0	22.6	16.2	19.3	24.0	18.3	22.4	17.3	20.9	2.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	12.9	20.6	16.7	12.1	19.7	15.8	11.4	18.9	55.6	23.8	52.3	22.7	49.1	20.9	22.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	4.6	4.1	-23.4	28.5	4.1	1.9	-26.4	29.8	-28.8	30.9	-31.1	31.9	-34.0	33.3		
(5)			-23.2	20.8	3.8	1.3	-25.9	21.7	-28.1	22.5	-30.3	23.2	-33.0	24.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.4	-4.3	-3.9	-0.7	4.5	9.6	13.6	16.0	14.9	10.7	5.5	1.4	-2.8	(6)
(7)		DBStd	8.26	5.81	4.93	4.52	3.29	3.64	2.79	2.75	2.58	3.00	3.82	4.08	6.03	(7)
(8)		HDD10.0	2219	443	390	332	168	52	3	0	2	27	146	259	397	(8)
(9)		HDD18.3	4728	702	623	591	414	272	143	83	110	228	398	509	655	(9)
(10)		CDD10.0	548	0	0	0	3	39	112	187	153	49	6	0	0	(10)
(11)		CDD18.3	17	0	0	0	0	0	2	12	3	0	0	0	0	(11)
(12)		CDH23.3	276	0	0	0	0	13	65	158	39	0	0	0	0	(12)
(13)		CDH26.7	37	0	0	0	0	0	7	28	2	0	0	0	0	(13)
(14)	Wind	WSAvg	1.8	1.9	1.8	2.0	2.0	1.7	1.5	1.5	1.5	1.8	2.0	1.9	(14)	
(15)	Precipitation	PrecAvg	749	58	42	36	43	52	64	79	76	73	76	64	(15)	
(16)		PrecMax	1041	121	95	65	135	108	129	239	169	134	165	166	112	(16)
(17)		PrecMin	614	10	9	5	14	12	9	11	21	19	30	30	12	(17)
(18)		PrecStd	97	29	22	18	26	26	31	49	38	33	35	34	30	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.7	6.7	14.2	19.5	25.4	27.7	29.2	26.5	21.6	15.8	11.2	9.1	(19)
(20)			MCWB	6.0	4.7	8.0	11.4	15.6	17.6	19.4	17.9	16.1	13.0	10.7	8.6	(20)
(21)		2%	DB	5.0	5.1	10.1	16.9	22.5	25.2	27.1	24.4	19.2	13.6	9.7	7.5	(21)
(22)			MCWB	4.4	4.1	5.6	10.0	14.2	16.7	18.8	17.7	15.1	11.9	9.1	6.9	(22)
(23)		5%	DB	3.8	3.7	7.4	14.0	20.2	23.2	25.1	22.5	17.5	12.4	8.4	6.0	(23)
(24)			MCWB	3.3	2.9	4.0	8.2	13.1	15.7	17.9	16.9	14.1	11.2	7.9	5.4	(24)
(25)		10%	DB	2.6	2.5	5.2	11.7	17.5	20.7	22.8	20.6	16.0	11.3	7.2	4.6	(25)
(26)			MCWB	2.1	1.9	3.1	6.8	11.8	14.6	17.0	16.4	13.2	10.3	6.7	4.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.2	5.4	8.4	12.5	16.9	19.2	20.9	20.1	17.1	13.7	10.9	8.8	(27)
(28)			MCDWB	6.5	5.9	13.1	18.2	22.4	24.8	25.9	23.3	19.8	14.8	11.1	9.0	(28)
(29)		2%	WB	4.7	4.2	6.2	10.2	15.2	17.8	19.9	18.9	15.7	12.5	9.3	7.1	(29)
(30)			MCDWB	4.9	4.9	9.5	15.4	20.9	23.2	25.4	22.4	18.1	13.2	9.6	7.6	(30)
(31)		5%	WB	3.3	3.1	4.7	8.9	13.8	16.7	18.8	17.8	14.7	11.5	8.0	5.6	(31)
(32)			MCDWB	3.7	3.6	6.6	13.4	18.7	21.6	23.5	20.9	17.0	12.2	8.4	6.0	(32)
(33)		10%	WB	2.2	2.0	3.6	7.5	12.4	15.5	17.7	16.9	13.7	10.5	6.8	4.3	(33)
(34)			MCDWB	2.6	2.5	5.1	10.9	16.6	20.0	21.5	19.9	15.6	11.2	7.2	4.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.8	7.0	9.3	11.1	11.2	11.1	10.3	9.8	9.1	7.1	4.9	5.6	(35)
(36)			MCDBR	5.4	6.5	12.6	15.8	15.9	16.1	15.0	13.3	11.1	7.8	6.1	5.8	(36)
(37)			MCWBR	5.4	5.4	8.5	9.5	8.6	8.4	7.2	7.5	7.1	6.2	5.8	5.7	(37)
(38)		5% WB	MCDBR	5.0	5.6	11.1	14.2	13.6	13.9	13.1	11.3	10.1	6.8	5.8	5.8	(38)
(39)			MCWBR	5.1	4.9	7.8	9.0	7.8	7.8	6.9	6.8	7.0	5.7	5.6	5.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.261	0.302	0.327	0.365	0.363	0.354	0.374	0.366	0.336	0.324	0.285	0.240	(40)	
(41)		taud	2.213	2.300	2.372	2.354	2.420	2.467	2.427	2.445	2.517	2.459	2.292	2.131	(41)	
(42)		Ebn at Noon	538	709	809	836	866	880	849	828	800	684	504	410	(42)	
(43)		Edh at Noon	41	67	84	102	103	100	102	93	74	58	39	30	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.30	0.90	2.44	3.85	4.91	5.61	5.06	3.97	2.64	1.18	0.38	0.20	(44)	
(45)		RadStd	0.05	0.17	0.28	0.47	0.47	0.36	0.61	0.43	0.33	0.22	0.09	0.02	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (61 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page