

DALA, Sweden

WMO: 024350

Lat: 60.429N

Lon: 15.501E

Elev: 492

StdP: 14.44

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.8	(c) 3.4	(d) -6.2	(e) 4.0	(f) -0.1	(g) -1.3	(h) 5.2	(i) 4.9	(j) 25.6	(k) 38.5	(l) 23.0	(m) 36.9	(n) 3.3	(o) 270	(p) 0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	79.1	62.2	75.9	61.0	72.9	59.6	65.2	74.2	63.3	71.6	61.5	69.5	7.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.2	85.2	67.9	60.2	79.3	66.5	58.0	73.2	64.7	30.3	74.3	28.9	71.4	27.7	69.4	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.5	17.7	15.4	-6.9	83.3	7.2	3.8	-12.1	86.0	-16.3	88.2	-20.3	90.3	-25.5	93.1		
			-7.4	67.2	7.0	2.8	-12.5	69.2	-16.6	70.8	-20.5	72.4	-25.6	74.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.2	25.2	25.7	31.3	40.4	49.7	56.8	61.5	59.4	51.8	41.5	33.7	27.5		
	DBStd	14.87	9.50	9.72	8.44	6.44	6.88	5.65	5.08	5.03	5.50	6.71	7.47	9.81		
	HDD50	3924	768	681	579	294	89	7	0	2	45	272	491	696		
	HDD65	8387	1233	1101	1044	737	474	252	136	185	397	727	940	1161		
	CDD50	1057	0	0	0	7	81	212	356	293	98	10	0	0		
	CDD65	46	0	0	0	0	1	7	27	11	0	0	0	0		
	CDH74	493	0	0	0	0	23	98	264	108	0	0	0	0		
	CDH80	65	0	0	0	0	0	10	45	10	0	0	0	0		
	WSAvg	6.8	7.4	7.1	7.3	7.1	7.0	6.8	5.8	5.8	6.5	6.7	7.0	7.3		
	PrecAvg	25.7	1.7	1.3	1.3	1.5	2.0	2.9	3.3	3.1	2.1	2.4	2.2	2.0		
	PrecMax	32.3	3.2	3.0	2.2	4.5	4.4	5.9	8.0	5.6	4.8	6.1	5.5	3.5		
	PrecMin	21.4	0.3	0.2	0.2	0.2	0.6	1.1	0.8	1.1	0.3	0.6	0.9	0.5		
	PrecStd	2.7	0.8	0.6	0.6	1.1	0.9	1.2	1.6	1.2	1.3	1.3	1.2	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.4	46.2	57.2	68.0	77.2	81.5	84.8	81.0	71.3	60.5	52.2	48.5		
		MCWB	40.5	40.2	45.2	51.3	58.2	60.8	64.6	62.5	58.7	54.8	48.7	45.5		
	2%	DB	41.1	42.6	50.4	62.7	72.6	76.9	80.4	77.2	67.2	56.6	49.8	44.8		
		MCWB	38.2	38.2	41.2	49.0	56.0	59.5	63.5	62.4	57.3	52.3	46.6	42.3		
	5%	DB	39.1	40.1	46.3	57.4	67.8	73.0	76.8	73.6	64.3	53.9	46.6	42.4		
		MCWB	36.6	36.8	39.0	45.8	54.2	57.9	62.6	60.9	56.0	50.2	44.4	40.0		
	10%	DB	37.2	37.7	42.9	53.4	63.1	68.8	73.2	70.1	61.2	51.7	44.4	39.4		
		MCWB	35.3	34.9	37.4	43.9	51.4	56.1	60.9	59.6	54.7	48.5	42.5	37.3		
	0.4%	WB	41.4	41.6	45.6	53.1	61.0	64.4	68.8	67.2	61.2	55.8	49.7	45.8		
		MCDB	43.2	44.2	55.1	64.6	71.1	74.2	76.0	73.4	67.0	58.7	51.9	48.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	38.6	39.3	42.3	49.8	58.0	61.4	65.9	64.6	58.9	53.1	46.9	42.6		
		MCDB	40.3	41.6	48.7	60.4	68.9	71.4	76.1	71.9	64.4	55.6	49.2	44.4		
	5%	WB	36.9	37.1	40.1	47.2	55.2	59.5	64.1	62.9	57.3	51.1	44.5	39.8		
		MCDB	38.5	39.5	45.2	55.8	65.4	69.7	73.9	69.7	62.8	53.6	46.4	41.7		
	10%	WB	35.1	35.1	37.8	44.7	52.8	57.6	62.1	61.1	55.6	49.0	42.4	37.4		
		MCDB	36.9	37.4	42.2	51.2	62.0	67.1	70.4	68.5	60.2	51.3	43.9	39.1		
	5% DB	MDBR	9.8	11.1	14.4	17.9	18.4	17.5	17.3	17.0	15.5	11.6	8.4	9.4		
		MCDBR	8.8	10.9	18.5	26.7	26.8	24.7	24.1	23.3	19.3	13.2	10.9	9.8		
		MCWBR	8.1	8.6	11.7	14.6	13.3	11.3	10.6	10.9	11.4	9.8	9.9	9.1		
		MCWBR	8.5	9.9	17.3	23.8	23.0	20.5	20.9	19.0	16.5	11.3	10.1	9.3		
	5% WB	MCWBR	8.2	8.6	11.6	13.7	12.1	10.4	10.2	10.1	10.7	9.3	9.4	8.8		
(40) Clear-Sky Solar Irradiance	taub		0.253	0.299	0.324	0.361	0.360	0.353	0.374	0.367	0.333	0.318	0.277	N/A		
	taud		2.195	2.295	2.361	2.359	2.418	2.462	2.420	2.433	2.519	2.459	2.264	N/A		
	Ebn at Noon		165	222	256	266	275	279	269	261	253	215	153	N/A		
	Edh at Noon		12	21	27	32	32	32	32	30	23	18	12	N/A		
(44) All-Sky Solar Radiation	RadAvg		88	295	780	1230	1507	1711	1563	1215	800	362	110	54		
	RadStd		16	55	92	143	153	115	191	133	111	66	30	7		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-207	N/A	N/A	N/A

Nomenclature: See separate page