

DALA, Sweden

WMO: 024350

Lat: 60.429N

Lon: 15.501E

Elev: 150

StdP: 99.54

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.8	-15.9	-21.2	0.6	-17.8	-18.5	0.7	-15.1	11.4	3.6	10.3	2.7	1.5	270	0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	26.2	16.8	24.4	16.1	22.7	15.3	18.4	23.5	17.4	22.0	16.4	20.8	3.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	12.2	19.9	15.7	11.3	19.2	14.5	10.5	18.2	52.6	23.5	49.4	21.9	46.4	20.8	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.1	7.9	6.9	DB	-21.6	28.5	4.0	2.1	-24.5	30.0	-26.8	31.2	-29.0	32.4	-31.9	33.9	
			WB	-21.9	19.6	3.9	1.5	-24.7	20.7	-27.0	21.6	-29.2	22.4	-32.0	23.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.6	-3.8	-3.5	-0.4	4.7	9.9	13.8	16.4	15.2	11.0	5.3	0.9	-2.5
	DBStd	8.26	5.28	5.40	4.69	3.58	3.82	3.14	2.82	2.79	3.06	3.73	4.15	5.45
	HDD10.0	2180	427	378	322	163	49	4	0	1	25	151	273	387
	HDD18.3	4659	685	612	580	409	263	140	76	103	221	404	522	645
	CDD10.0	587	0	0	0	4	45	118	198	163	54	6	0	0
	CDD18.3	26	0	0	0	0	1	4	15	6	0	0	0	0
	CDH23.3	274	0	0	0	0	13	54	147	60	0	0	0	0
	CDH26.7	36	0	0	0	0	0	6	25	6	0	0	0	0
Wind	WSAvg	3.0	3.3	3.2	3.3	3.2	3.1	3.0	2.6	2.6	2.9	3.0	3.1	3.2
Precipitation	PrecAvg	653	42	32	32	38	50	74	83	79	54	60	57	50
	PrecMax	820	81	75	57	114	111	149	203	142	122	154	139	89
	PrecMin	544	7	5	5	4	15	28	21	28	8	16	23	13
	PrecStd	69	21	16	16	27	24	30	41	31	32	32	30	21
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.3	7.9	14.0	20.0	25.1	27.5	29.3	27.2	21.8	15.8	11.2	9.1
		MCWB	4.7	4.6	7.3	10.7	14.6	16.0	18.1	16.9	14.8	12.6	9.3	7.5
	2%	DB	5.1	5.9	10.2	17.0	22.6	25.0	26.9	25.1	19.6	13.7	9.9	7.1
		MCWB	3.4	3.5	5.1	9.4	13.3	15.3	17.5	16.9	14.0	11.3	8.1	5.7
	5%	DB	3.9	4.5	8.0	14.1	19.9	22.8	24.9	23.1	18.0	12.2	8.1	5.8
		MCWB	2.6	2.6	3.9	7.7	12.3	14.4	17.0	16.1	13.3	10.1	6.9	4.4
	10%	DB	2.9	3.1	6.0	11.9	17.3	20.5	22.9	21.1	16.2	11.0	6.9	4.1
		MCWB	1.8	1.6	3.0	6.6	10.8	13.4	16.0	15.4	12.6	9.2	5.8	3.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	5.3	7.6	11.7	16.1	18.0	20.4	19.6	16.2	13.2	9.8	7.6
		MCDB	6.2	6.8	12.8	18.1	21.7	23.4	24.4	23.0	19.4	14.8	11.0	8.9
	2%	WB	3.7	4.0	5.7	9.9	14.4	16.4	18.8	18.1	15.0	11.7	8.3	5.9
		MCDB	4.6	5.3	9.3	15.8	20.5	21.9	24.5	22.1	18.0	13.1	9.5	6.9
	5%	WB	2.7	2.8	4.5	8.5	12.9	15.3	17.8	17.2	14.1	10.6	6.9	4.3
		MCDB	3.6	4.2	7.3	13.2	18.5	20.9	23.3	20.9	17.1	12.0	8.0	5.4
	10%	WB	1.7	1.7	3.2	7.0	11.6	14.2	16.7	16.2	13.1	9.4	5.8	3.0
		MCDB	2.7	3.0	5.7	10.7	16.7	19.5	21.3	20.3	15.7	10.7	6.6	4.0
Mean Daily Temperature Range	5% DB	MDBR	5.5	6.1	8.0	10.0	10.2	9.7	9.6	9.4	8.6	6.4	4.7	5.2
		MCDBR	4.9	6.1	10.3	14.8	14.9	13.7	13.4	12.9	10.7	7.3	6.1	5.5
		MCWBR	4.5	4.8	6.5	8.1	7.4	6.3	5.9	6.1	6.3	5.4	5.5	5.1
	5% WB	MCDBR	4.7	5.5	9.6	13.2	12.8	11.4	11.6	10.6	9.2	6.3	5.6	5.1
		MCWBR	4.6	4.8	6.4	7.6	6.7	5.8	5.7	5.6	6.0	5.2	5.2	4.9
Clear-Sky Solar Irradiance	taub	0.253	0.299	0.324	0.361	0.360	0.353	0.374	0.367	0.333	0.318	0.277	N/A	
	taud	2.195	2.295	2.361	2.359	2.418	2.462	2.420	2.433	2.519	2.459	2.264	N/A	
	Ebn at Noon	519	699	806	837	866	878	847	823	797	679	482	N/A	
	Edh at Noon	39	65	84	101	102	100	102	93	72	56	37	N/A	
All-Sky Solar Radiation	RadAvg	0.28	0.93	2.46	3.88	4.75	5.39	4.93	3.83	2.52	1.14	0.35	0.17	
	RadStd	0.05	0.17	0.29	0.45	0.48	0.36	0.60	0.42	0.35	0.21	0.09	0.02	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-115	N/A	N/A	N/A	

Nomenclature: See separate page