

AMOT, Sweden

WMO: 024400

Lat: 60.9614N

Lon: 16.4279E

Elev: 531

StdP: 14.42

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.5	(c) -1.7	(d) -11.9	(e) 2.9	(f) -6.6	(g) -5.4	(h) 4.2	(i) -0.6	(j) 17.1	(k) 32.7	(l) 15.6	(m) 32.3	(n) 1.9	(o) 300	(p) 0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 20.5	(c) 78.7	(d) 63.7	(e) 75.2	(f) 62.4	(g) 71.8	(h) 60.5	(i) 66.2	(j) 75.2	(k) 64.2	(l) 72.2	(m) 62.2	(n) 69.3	(o) 6.4	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.1	88.2	68.9	61.0	81.9	67.5	59.1	76.2	65.6	31.2	75.3	29.7	72.3	28.2	69.3	73.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 15.6	(b) 13.6	(c) 11.9	(e) -14.9	(f) 83.4	(g) 5.2	(h) 2.9	(i) -18.7	(j) 85.5	(k) -21.8	(l) 87.2	(m) -24.7	(n) 88.9	(o) -28.5	(p) 91.0		
(a) 15.6	(b) 13.6	(c) 11.9	(e) -14.8	(f) 68.6	(g) 4.8	(h) 2.6	(i) -18.3	(j) 70.5	(k) -21.1	(l) 72.0	(m) -23.8	(n) 73.4	(o) -27.2	(p) 75.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	39.7	21.6	23.5	29.0	38.0	46.7	54.3	59.6	56.8	49.6	39.2	31.8	25.4		
	DBStd	15.06	10.70	9.65	9.02	6.25	6.29	5.61	4.94	5.10	5.75	6.83	7.68	10.55		
	HDD50	4529	880	742	650	363	141	20	1	7	75	341	545	764		
	HDD65	9249	1345	1162	1115	810	568	324	179	259	462	801	995	1229		
	CDD50	772	0	0	0	2	38	148	299	217	63	5	0	0		
	CDD65	18	0	0	0	0	0	1	13	4	0	0	0	0		
	CDH74	411	0	0	0	0	12	79	242	78	0	0	0	0		
	CDH80	47	0	0	0	0	0	6	35	6	0	0	0	0		
	WSAvg	5.0	4.6	4.7	5.6	5.4	5.6	5.4	4.9	4.4	4.8	4.7	4.7	4.7		
	PrecAvg	25.9	1.8	1.3	1.2	1.5	1.8	2.8	3.1	3.5	2.3	2.5	2.3	1.9		
	PrecMax	31.7	3.2	2.3	2.4	3.7	3.5	5.6	7.1	6.4	5.9	6.9	6.8	3.5		
(15) Precipitation	PrecMin	19.3	0.3	0.3	0.2	0.4	0.6	1.0	1.5	0.8	0.2	0.3	0.9	0.6		
	PrecStd	3.2	0.8	0.5	0.6	0.9	0.9	1.1	1.3	1.5	1.3	1.4	1.3	0.8		
	0.4%	DB	43.6	45.6	55.4	67.3	75.5	80.5	83.7	80.2	71.0	60.4	52.2	47.9		
	0.4%	MCWB	40.6	39.6	43.9	51.0	58.9	62.6	65.3	65.0	59.5	55.1	49.1	45.0		
	2%	DB	40.3	41.8	49.5	62.3	69.7	76.2	80.0	76.1	67.0	56.2	48.9	43.8		
(23) Mean Coincident Wet Bulb Temperatures	2%	MCWB	37.7	37.6	40.8	48.3	55.7	60.5	64.9	64.0	58.0	52.0	46.2	41.1		
	5%	DB	38.4	39.3	45.9	57.2	65.5	71.9	76.5	72.1	63.6	53.3	45.8	41.1		
	5%	MCWB	36.2	35.9	38.9	46.5	53.3	58.5	64.2	61.8	56.6	49.8	43.7	38.7		
	10%	DB	35.6	36.4	42.3	52.0	61.3	68.3	72.8	68.9	60.5	50.5	43.0	38.5		
	10%	MCWB	33.9	34.0	36.9	42.8	50.9	57.0	62.0	60.1	54.7	47.7	41.4	36.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.2	40.5	45.3	53.1	61.3	65.6	69.5	68.5	61.7	55.8	49.7	45.5		
	0.4%	MCDB	43.3	44.0	54.2	64.8	72.5	76.7	75.7	74.5	67.7	59.2	51.6	47.8		
	2%	WB	38.2	38.3	42.1	49.5	57.8	62.0	66.9	65.6	59.2	52.9	46.7	41.6		
	2%	MCDB	40.0	41.3	48.4	59.7	66.3	71.1	76.2	72.9	65.1	55.4	48.9	43.5		
	5%	WB	36.4	36.4	39.7	46.8	54.5	60.0	65.1	63.4	57.6	50.5	44.1	39.1		
(31) Mean Daily Temperature Range	5%	MCDB	38.1	38.8	45.0	56.8	62.9	69.8	73.8	70.1	62.5	52.8	45.7	40.9		
	10%	WB	34.1	34.2	37.3	44.0	52.0	58.1	63.3	61.4	55.8	48.2	41.8	36.7		
	10%	MCDB	35.6	36.2	41.9	50.8	59.9	67.0	71.0	67.0	59.7	50.4	43.1	38.4		
	5% DB	MDBR	12.8	14.3	17.7	21.2	21.1	20.5	20.5	20.2	18.2	14.7	10.4	11.6		
	5% DB	MCDBR	11.3	15.9	21.2	31.9	30.3	29.4	28.0	26.5	23.2	18.2	12.7	11.8		
(36) Clear-Sky Solar Irradiance	5% WB	MCWBR	10.4	12.1	13.9	19.4	17.4	15.4	14.9	15.8	15.2	14.1	11.2	10.6		
	5% WB	MCDDBR	11.1	13.8	20.3	29.3	25.9	25.5	24.2	22.6	20.8	16.1	12.0	11.3		
	5% WB	MCWBR	10.4	10.8	13.7	18.2	15.6	14.6	13.9	14.2	14.5	13.4	11.0	10.5		
	taub		0.246	0.295	0.319	0.354	0.355	0.349	0.369	0.362	0.328	0.314	0.269	0.358		
	taud		2.175	2.284	2.357	2.380	2.435	2.481	2.440	2.454	2.534	2.465	2.241	2.705		
(42) All-Sky Solar Radiation	Ebn at Noon		160	220	256	267	276	279	270	262	253	214	148	112		
	Edh at Noon		12	20	26	31	32	31	31	29	22	17	11	8		
	RadAvg		82	284	760	1227	1559	1745	1627	1256	810	367	109	49		
	RadStd		12	52	88	115	163	122	167	122	103	61	25	5		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-185	N/A	N/A	N/A

Nomenclature: See separate page