

AMOT, Sweden

WMO: 024400

Lat: 60.9614N

Lon: 16.4279E

Elev: 162

StdP: 99.39

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -22.0	(c) -18.7	(d) -24.4	(e) 0.4	(f) -21.4	(g) -20.8	(h) 0.6	(i) -18.1	(j) 7.6	(k) 0.4	(l) 7.0	(m) 0.2	(n) 0.9	(o) 300	(p) 0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.4	(c) 25.9	(d) 17.6	(e) 24.0	(f) 16.9	(g) 22.1	(h) 15.8	(i) 19.0	(j) 24.0	(k) 17.9	(l) 22.3	(m) 16.8	(n) 20.7	(o) 2.9	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.3	12.6	20.5	16.1	11.7	19.7	15.0	10.9	18.7	54.6	24.1	51.1	22.4	47.6	20.7	22.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.0	6.1	5.3	-26.1	28.5	2.9	1.6	-28.2	29.7	-29.9	30.7	-31.5	31.6	-33.6	32.8
			-26.0	20.3	2.7	1.4	-27.9	21.4	-29.5	22.2	-31.0	23.0	-32.9	24.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.3	-5.8	-4.7	-1.6	3.3	8.2	12.4	15.4	13.8	9.8	4.0	-0.1	-3.7
	DBStd	8.37	5.95	5.36	5.01	3.47	3.49	3.12	2.74	2.84	3.19	3.80	4.27	5.86
	HDD10.0	2516	489	412	361	202	78	11	4	42	189	303	424	
	HDD18.3	5138	747	646	619	450	316	180	99	144	257	445	553	683
	CDD10.0	429	0	0	0	1	21	82	166	121	35	3	0	0
	CDD18.3	10	0	0	0	0	0	1	7	2	0	0	0	0
	CDH23.3	228	0	0	0	0	7	44	134	43	0	0	0	0
	CDH26.7	26	0	0	0	0	0	3	19	3	0	0	0	0
Wind	WSAvg	2.2	2.1	2.1	2.5	2.4	2.5	2.4	2.2	2.0	2.2	2.1	2.1	2.1
Precipitation	PrecAvg	658	45	32	31	38	46	71	79	88	58	63	59	49
	PrecMax	806	82	58	61	94	90	142	180	163	149	175	173	89
	PrecMin	489	7	7	4	9	16	25	39	20	5	7	22	15
	PrecStd	81	21	13	15	24	22	27	34	37	34	35	33	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.4	7.5	13.0	19.6	24.2	27.0	28.7	26.8	21.7	15.8	11.2	8.8
		MCWB	4.8	4.2	6.6	10.5	14.9	17.0	18.5	18.4	15.3	12.9	9.5	7.2
	2%	DB	4.6	5.5	9.7	16.8	20.9	24.6	26.7	24.5	19.4	13.5	9.4	6.6
		MCWB	3.2	3.1	4.9	9.1	13.2	15.8	18.3	17.8	14.4	11.1	7.9	5.0
	5%	DB	3.5	4.1	7.7	14.0	18.6	22.2	24.7	22.3	17.6	11.8	7.7	5.1
		MCWB	2.3	2.2	3.8	8.1	11.8	14.7	17.9	16.5	13.7	9.9	6.5	3.7
	10%	DB	2.0	2.4	5.7	11.1	16.3	20.2	22.6	20.5	15.8	10.3	6.1	3.6
		MCWB	1.0	1.1	2.7	6.0	10.5	13.9	16.7	15.6	12.6	8.7	5.2	2.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.1	4.7	7.4	11.7	16.3	18.6	20.8	20.3	16.5	13.2	9.8	7.5
		MCDB	6.3	6.7	12.3	18.2	22.5	24.8	24.3	23.6	19.8	15.1	10.9	8.8
	2%	WB	3.4	3.5	5.6	9.7	14.3	16.7	19.4	18.6	15.1	11.6	8.2	5.3
		MCDB	4.5	5.2	9.1	15.4	19.1	21.7	24.6	22.7	18.4	13.0	9.4	6.4
	5%	WB	2.4	2.4	4.3	8.2	12.5	15.6	18.4	17.4	14.2	10.3	6.7	4.0
		MCDB	3.4	3.8	7.2	13.8	17.2	21.0	23.2	21.2	16.9	11.6	7.6	5.0
	10%	WB	1.2	1.2	3.0	6.7	11.1	14.5	17.4	16.4	13.2	9.0	5.4	2.6
		MCDB	2.0	2.3	5.5	10.4	15.5	19.5	21.7	19.4	15.4	10.2	6.2	3.6
Mean Daily Temperature Range	5% DB	MDBR	7.1	8.0	9.8	11.8	11.7	11.4	11.4	11.2	10.1	8.2	5.8	6.4
		MCDBR	6.3	8.8	11.8	17.7	16.9	16.3	15.5	14.7	12.9	10.1	7.1	6.5
		MCWBR	5.8	6.7	7.7	10.8	9.6	8.5	8.3	8.8	8.4	7.8	6.2	5.9
	5% WB	MCDBR	6.2	7.7	11.3	16.3	14.4	14.2	13.4	12.6	11.6	9.0	6.7	6.3
		MCWBR	5.8	6.0	7.6	10.1	8.6	8.1	7.7	7.9	8.0	7.4	6.1	5.8
Clear-Sky Solar Irradiance	taub		0.246	0.295	0.319	0.354	0.355	0.349	0.369	0.362	0.328	0.314	0.269	0.358
	taud		2.175	2.284	2.357	2.380	2.435	2.481	2.440	2.454	2.534	2.465	2.241	2.705
	Ebn at Noon		503	693	807	842	869	881	850	826	799	676	466	353
	Edh at Noon		37	64	83	98	100	98	99	91	70	54	35	25
All-Sky Solar Radiation	RadAvg		0.26	0.90	2.40	3.87	4.92	5.50	5.13	3.96	2.55	1.16	0.34	0.15
	RadStd		0.04	0.16	0.28	0.36	0.51	0.39	0.53	0.39	0.33	0.19	0.08	0.02

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-103	N/A	N/A	N/A

Nomenclature: See separate page