

MORA SILJIAN, Sweden

WMO: 024410

Lat: 60.9601N

Lon: 14.5041E

Elev: 646

StdP: 14.36

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.8	-3.3	-14.2	2.6	-8.5	-8.3	3.6	-2.5	18.4	31.5	16.6	31.5	2.2	340	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.3	79.5	62.7	76.1	61.6	72.8	60.1	65.7	74.3	63.9	71.8	62.1	69.3	7.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.7	87.2	68.3	60.9	81.8	67.1	59.0	76.4	65.8	30.9	74.5	29.4	72.0	28.2	69.4	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.9	13.7	11.9	DB	-14.7	83.2	5.5	2.6	-18.6	85.1	-21.8	86.6	-24.9	88.0	-28.9	89.9	(4)
(5)			WB	-14.8	67.9	5.4	2.0	-18.6	69.3	-21.8	70.5	-24.8	71.7	-28.7	73.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.7	21.2	22.6	29.2	39.7	49.4	57.1	61.4	58.3	50.7	40.3	32.1	24.6
	DBStd	16.18	11.77	10.90	9.40	6.06	6.89	5.74	5.18	4.95	5.61	6.90	7.88	11.45
	HDD50	4414	893	768	644	313	96	7	0	3	57	308	538	787
	HDD65	8926	1358	1188	1108	758	484	246	137	213	429	765	988	1252
	CDD50	1002	0	0	0	5	77	219	354	261	79	7	0	0
	CDD65	41	0	0	0	0	0	8	26	7	0	0	0	0
	CDH74	522	0	0	0	0	26	144	290	62	0	0	0	0
	CDH80	69	0	0	0	0	0	17	49	3	0	0	0	0
Wind	WSAvg	5.4	5.0	4.9	5.6	5.6	5.9	5.9	5.4	4.9	5.1	5.2	5.5	5.1
Precipitation	PrecAvg	24.5	1.4	1.0	1.1	1.5	2.0	3.1	3.3	3.2	2.1	2.2	2.0	1.5
	PrecMax	34.3	3.1	2.1	2.4	4.6	4.4	5.8	7.9	5.6	4.3	5.8	4.7	2.9
	PrecMin	19.4	0.3	0.1	0.1	0.2	0.3	0.3	1.4	1.5	0.7	0.7	0.8	0.4
	PrecStd	3.5	0.8	0.5	0.6	1.1	1.1	1.3	1.5	1.1	1.0	1.3	1.0	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.6	45.0	54.9	66.6	77.5	82.3	84.9	79.9	70.6	60.2	51.9	48.3
		MCWB	39.7	38.6	44.2	52.0	57.9	60.5	65.2	64.0	58.6	53.9	49.6	44.8
	2%	DB	40.3	42.0	49.6	60.7	72.7	78.2	80.7	75.4	66.3	56.5	48.8	43.8
		MCWB	37.5	37.6	40.7	48.8	56.0	60.2	64.3	63.7	56.8	51.6	46.1	40.9
	5%	DB	38.4	39.8	45.8	56.1	68.2	74.4	77.1	71.9	63.1	53.7	45.6	41.0
		MCWB	35.9	36.2	38.6	45.9	54.5	58.9	63.5	61.7	56.0	49.6	43.3	38.4
	10%	DB	35.7	36.7	42.1	52.1	63.3	70.1	73.5	68.7	60.3	51.1	42.7	38.5
		MCWB	33.4	33.9	36.4	43.3	51.8	56.9	61.8	59.7	54.1	47.7	40.9	36.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.6	40.4	45.3	55.3	60.7	65.0	68.2	67.2	61.1	55.5	49.8	44.9
		MCDB	42.4	43.6	53.0	60.2	72.5	74.8	78.6	73.4	67.1	59.0	51.2	47.8
	2%	WB	37.8	38.2	41.5	50.0	58.1	62.3	66.6	65.2	58.7	52.5	46.4	41.2
		MCDB	39.9	41.0	48.2	58.6	69.2	73.2	76.3	72.0	64.2	55.4	48.4	43.3
	5%	WB	36.0	36.3	39.3	46.6	55.3	60.1	64.8	63.3	56.9	50.3	43.6	38.7
		MCDB	38.1	39.3	44.8	54.8	64.9	70.5	73.9	69.4	61.5	53.0	45.3	40.6
	10%	WB	33.7	33.9	36.9	44.0	53.1	58.2	62.9	61.4	55.0	48.2	41.2	36.2
		MCDB	35.5	36.5	41.3	50.6	62.7	68.6	70.9	66.7	59.3	50.7	42.6	38.1
Mean Daily Temperature Range	5% DB	MDBR	11.5	12.9	16.5	18.5	19.3	19.1	18.3	17.2	15.9	12.7	9.2	10.9
		MCDBR	10.0	12.2	19.5	27.0	28.6	27.0	25.1	23.0	20.1	15.3	11.4	10.5
		MCWBR	9.2	9.1	12.8	16.0	14.6	12.9	11.6	12.6	12.8	11.3	10.1	9.5
	5% WB	MCDBR	9.7	11.4	18.1	24.8	23.2	23.2	21.5	19.1	17.8	13.0	10.8	10.3
MCWBR		9.2	9.1	12.3	15.4	12.5	11.8	11.0	11.4	12.1	10.3	9.8	9.7	
Clear-Sky Solar Irradiance	taub	0.239	0.287	0.314	0.350	0.353	0.347	0.366	0.358	0.325	0.310	0.260	0.355	
	taud	2.180	2.289	2.349	2.382	2.436	2.478	2.439	2.456	2.535	2.477	2.255	2.760	
	Ebn at Noon	164	224	258	268	276	280	271	264	255	217	154	118	
	Edh at Noon	11	20	26	31	32	31	31	29	22	17	11	8	
All-Sky Solar Radiation	RadAvg	86	299	796	1256	1497	1696	1551	1196	783	357	108	50	
	RadStd	15	55	85	138	156	122	189	120	109	62	29	6	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (49 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page