

MORA SILJIAN, Sweden

WMO: 024410

Lat: 60.9601N

Lon: 14.5041E

Elev: 197

StdP: 98.98

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.7	-19.6	-25.6	0.4	-22.5	-22.4	0.5	-19.2	8.2	-0.3	7.4	-0.3	1.0	340	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	26.4	17.1	24.5	16.4	22.7	15.6	18.7	23.5	17.7	22.1	16.7	20.7	3.1	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.1	12.5	20.2	16.1	11.7	19.5	15.0	10.9	18.8	53.9	23.6	50.6	22.2	47.6	20.8	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	6.1	5.3	-25.9	28.5	3.0	1.4	-28.1	29.5	-29.9	30.3	-31.6	31.1	-33.8	32.1		
(5)			-26.0	19.9	3.0	1.1	-28.1	20.7	-29.9	21.4	-31.5	22.0	-33.7	22.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.8	-6.0	-5.2	-1.5	4.3	9.7	13.9	16.3	14.6	10.4	4.6	0.0	-4.1	(6)
(7)		DBStd	8.99	6.54	6.05	5.22	3.37	3.83	3.19	2.88	2.75	3.12	3.83	4.38	6.36	(7)
(8)		HDD10.0	2452	496	427	358	174	53	4	0	2	32	171	299	437	(8)
(9)		HDD18.3	4959	754	660	616	421	269	137	76	118	238	425	549	696	(9)
(10)		CDD10.0	557	0	0	0	3	43	122	197	145	44	4	0	0	(10)
(11)		CDD18.3	23	0	0	0	0	0	4	14	4	0	0	0	0	(11)
(12)		CDH23.3	290	0	0	0	0	14	80	161	34	0	0	0	0	(12)
(13)		CDH26.7	38	0	0	0	0	0	9	27	2	0	0	0	0	(13)
(14)	Wind	WSAvg	2.4	2.3	2.2	2.5	2.5	2.7	2.6	2.4	2.2	2.3	2.3	2.4	2.3	(14)
(15)	Precipitation	PrecAvg	622	35	26	28	37	51	79	85	54	56	50	38		(15)
(16)		PrecMax	872	79	53	61	117	113	148	201	143	108	148	120	74	(16)
(17)		PrecMin	494	7	3	3	6	8	8	35	38	17	17	20	9	(17)
(18)		PrecStd	88	20	12	15	28	27	34	38	28	26	32	25	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.5	7.2	12.7	19.2	25.3	28.0	29.4	26.6	21.5	15.7	11.0	9.0	(19)
(20)			MCWB	4.3	3.7	6.8	11.1	14.4	15.9	18.4	17.8	14.8	12.1	9.8	7.1	(20)
(21)		2%	DB	4.6	5.6	9.8	15.9	22.6	25.7	27.1	24.1	19.0	13.6	9.3	6.6	(21)
(22)			MCWB	3.0	3.1	4.8	9.3	13.3	15.6	18.0	17.6	13.8	10.9	7.9	5.0	(22)
(23)		5%	DB	3.5	4.3	7.6	13.4	20.1	23.5	25.1	22.2	17.3	12.1	7.6	5.0	(23)
(24)			MCWB	2.1	2.3	3.7	7.7	12.5	14.9	17.5	16.5	13.3	9.8	6.3	3.5	(24)
(25)		10%	DB	2.0	2.6	5.6	11.2	17.4	21.1	23.0	20.4	15.7	10.6	5.9	3.6	(25)
(26)			MCWB	0.8	1.0	2.4	6.3	11.0	13.8	16.5	15.4	12.3	8.7	5.0	2.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.8	4.7	7.4	13.0	15.9	18.3	20.1	19.6	16.2	13.1	9.9	7.1	(27)
(28)			MCDWB	5.8	6.4	11.7	15.7	22.5	23.8	25.9	23.0	19.5	15.0	10.7	8.8	(28)
(29)		2%	WB	3.2	3.5	5.3	10.0	14.5	16.8	19.2	18.4	14.8	11.4	8.0	5.1	(29)
(30)			MCDWB	4.4	5.0	9.0	14.8	20.7	22.9	24.6	22.2	17.9	13.0	9.1	6.3	(30)
(31)		5%	WB	2.2	2.4	4.0	8.1	12.9	15.6	18.2	17.4	13.8	10.1	6.5	3.7	(31)
(32)			MCDWB	3.4	4.1	7.1	12.6	18.3	21.4	23.3	20.8	16.4	11.6	7.4	4.8	(32)
(33)		10%	WB	0.9	1.1	2.7	6.6	11.7	14.6	17.2	16.3	12.8	9.0	5.1	2.3	(33)
(34)			MCDWB	2.0	2.5	5.2	10.3	17.0	20.4	21.6	19.3	15.1	10.4	5.9	3.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.4	7.2	9.2	10.3	10.7	10.6	10.2	9.6	8.8	7.1	5.1	6.0	(35)
(36)			MCDBR	5.5	6.8	10.8	15.0	15.9	15.0	13.9	12.8	11.2	8.5	6.3	5.8	(36)
(37)			MCWBR	5.1	5.1	7.1	8.9	8.1	7.2	6.5	7.0	7.1	6.3	5.6	5.3	(37)
(38)		5% WB	MCDWB	5.4	6.3	10.1	13.8	12.9	12.9	11.9	10.6	9.9	7.2	6.0	5.7	(38)
(39)			MCWBR	5.1	5.1	6.8	8.6	7.0	6.6	6.1	6.3	6.7	5.7	5.5	5.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.239	0.287	0.314	0.350	0.353	0.347	0.366	0.358	0.325	0.310	0.260	0.355	(40)	
(41)		taud	2.180	2.289	2.349	2.382	2.436	2.478	2.439	2.456	2.535	2.477	2.255	2.760	(41)	
(42)		Ebn at Noon	518	706	812	846	871	883	853	831	803	683	485	372	(42)	
(43)		Edh at Noon	36	63	83	98	100	98	99	90	70	53	34	24	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.27	0.94	2.51	3.96	4.72	5.35	4.89	3.77	2.47	1.13	0.34	0.16	(44)	
(45)		RadStd	0.05	0.17	0.27	0.43	0.49	0.38	0.60	0.38	0.34	0.20	0.09	0.02	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (49 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page