

ENKOPING, Sweden

WMO: 024430

Lat: 59.656N

Lon: 17.112E

Elev: 26

StdP: 101.01

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.9	-15.7	-22.1	0.5	-19.9	-17.7	0.8	-15.4	6.8	1.3	6.2	1.4	0.3	320	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	27.6	19.0	25.7	17.8	24.0	17.0	20.2	25.5	19.0	24.2	17.9	22.5	2.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.2	22.3	17.1	12.3	21.1	16.0	11.4	20.1	58.2	25.4	54.1	24.1	50.6	22.5	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.0	5.3	4.7	DB	-23.5	29.4	5.5	1.7	-27.5	30.6	-30.8	31.7	-33.9	32.6	-37.9	33.9	(4)
(5)			WB	-22.2	21.1	5.9	1.9	-26.5	22.4	-30.0	23.5	-33.3	24.5	-37.7	25.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.5	-3.6	-3.2	0.1	5.5	10.9	14.7	17.6	16.0	11.7	6.2	2.5	-1.4	(6)	
	DBStd	8.40	5.59	5.56	4.42	3.61	4.01	3.23	2.99	2.72	3.05	3.52	4.00	5.47	(7)	
	HDD10.0	2006	421	368	308	142	38	3	0	0	18	126	227	354	(8)	
	HDD18.3	4377	679	602	566	386	232	115	50	82	201	376	476	612	(9)	
	CDD10.0	714	0	0	0	6	65	145	236	186	68	9	1	0	(10)	
	CDD18.3	45	0	0	0	0	1	7	27	9	1	0	0	0	(11)	
	CDH23.3	510	0	0	0	0	26	102	307	75	1	0	0	0	(12)	
	CDH26.7	96	0	0	0	0	1	9	75	11	0	0	0	0	(13)	
(14) Wind	WSAvg	2.2	2.2	2.2	2.4	2.4	2.4	2.3	2.2	2.0	2.0	2.2	2.3	2.2	(14)	
(15) Precipitation	PrecAvg	547	34	29	26	33	38	62	67	65	50	47	49	39	(15)	
	PrecMax	654	67	62	50	82	78	110	148	153	132	108	128	94	(16)	
	PrecMin	423	9	4	2	5	15	18	13	5	9	1	13	9	(17)	
	PrecStd	60	17	12	12	21	15	26	37	36	29	24	26	20	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.4	8.3	13.6	20.1	25.8	28.1	30.7	28.1	22.7	16.5	11.9	10.4	(19)	
		MCWB	5.2	5.6	9.0	11.6	15.9	17.9	20.0	21.0	16.6	13.2	10.7	8.8	(20)	
	2%	DB	5.2	6.4	10.5	17.6	23.8	26.2	28.9	25.3	20.4	14.4	10.1	8.5	(21)	
		MCWB	4.1	4.1	6.5	10.1	15.1	17.4	19.6	18.2	15.5	12.4	9.1	7.2	(22)	
	5%	DB	4.2	4.9	8.2	15.2	21.9	24.3	26.8	23.3	18.6	13.1	8.8	6.4	(23)	
		MCWB	3.4	3.5	5.0	9.3	14.2	16.7	18.8	17.3	14.5	11.3	8.0	5.2	(24)	
	10%	DB	2.8	3.7	6.1	12.6	19.3	21.9	24.7	21.8	17.2	11.9	7.7	4.9	(25)	
		MCWB	2.0	2.5	3.7	7.6	13.1	15.1	17.8	16.5	13.7	10.2	6.8	4.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.6	6.2	9.2	12.4	17.6	19.8	22.0	22.0	17.7	14.1	10.8	9.1	(27)	
		MCDB	6.0	8.0	13.1	18.6	23.6	25.3	26.8	26.6	21.2	15.7	11.5	10.1	(28)	
	2%	WB	4.2	4.6	6.9	10.7	16.3	18.3	20.7	19.5	16.1	12.7	9.2	7.2	(29)	
		MCDB	4.9	5.7	9.8	16.5	21.4	24.2	26.2	23.6	19.2	14.1	9.9	8.1	(30)	
	5%	WB	3.3	3.7	5.3	9.5	14.6	17.2	19.6	18.3	15.1	11.7	8.0	5.3	(31)	
		MCDB	4.1	4.8	7.5	14.7	20.5	22.8	25.3	21.6	18.0	12.9	8.7	6.0	(32)	
	10%	WB	2.1	2.6	4.0	8.1	13.4	16.0	18.6	17.2	14.2	10.5	7.0	4.0	(33)	
		MCDB	2.7	3.5	5.7	11.8	18.8	20.9	23.9	20.5	16.6	11.6	7.6	4.8	(34)	
(35) Mean Daily Temperature Range	MDBR		5.4	7.0	8.3	10.6	11.5	10.8	11.0	9.8	9.2	7.2	4.6	5.1	(35)	
	5% DB	MCDBR	4.7	6.6	10.4	14.9	15.8	14.8	14.7	12.3	11.1	8.0	5.6	5.4	(36)	
		MCWBR	4.5	5.1	7.1	8.7	8.5	7.6	6.7	6.3	7.0	6.0	5.1	5.1	(37)	
	5% WB	MCDBR	4.5	6.2	9.3	13.5	13.8	12.5	12.5	10.2	10.1	6.8	5.6	5.3	(38)	
		MCWBR	4.4	5.0	6.7	8.1	7.9	6.8	6.3	5.9	6.6	5.5	5.3	5.1	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.273	0.315	0.336	0.372	0.369	0.359	0.384	0.377	0.343	0.331	0.299	0.256	(40)	
	taud		2.203	2.274	2.356	2.329	2.397	2.446	2.397	2.413	2.497	2.429	2.259	2.129	(41)	
	Ebn at Noon		517	688	798	828	860	874	839	816	791	672	476	383	(42)	
	Edh at Noon		42	69	86	105	105	102	105	96	75	59	41	31	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.31	0.95	2.46	3.92	5.07	5.67	5.20	4.11	2.69	1.21	0.39	0.20	(44)	
	RadStd		0.05	0.14	0.31	0.39	0.47	0.36	0.52	0.41	0.31	0.20	0.09	0.02	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (52 neighbors)		+0.37	N/A	N/A	N/A	N/A	N/A	N/A	-119	-147	N/A	N/A

Nomenclature: See separate page