

ESKILSTUNA, Sweden

WMO: 024490

Lat: 59.3825N

Lon: 16.4522E

Elev: 41

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.5	4.4	-4.7	4.3	-1.7	1.8	6.0	5.5	22.5	37.7	19.8	37.0	2.1	210	0.580

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	81.4	64.5	77.9	63.5	74.8	62.0	67.6	75.3	65.6	73.7	63.8	72.0	6.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.2	93.3	70.2	62.9	85.8	68.3	60.7	79.4	66.7	32.0	75.2	30.4	73.4	29.1	72.2	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.2	17.3	14.8	-7.2	84.8	8.9	2.8	-13.6	86.8	-18.9	88.4	-23.9	90.0	-30.4	92.0		
			-4.7	69.5	8.6	2.3	-10.9	71.2	-15.9	72.6	-20.7	73.9	-26.9	75.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	43.9	25.4	27.6	33.7	42.0	51.6	58.4	63.5	60.8	43.7	36.6	29.5	(6)	
(7)		DBStd	14.81	10.16	9.50	7.60	6.13	6.53	5.38	4.81	4.75	5.64	6.89	7.07	9.93	(7)
(8)		HDD50	3493	763	628	504	249	59	3	0	0	33	217	402	635	(8)
(9)		HDD65	7763	1228	1048	969	691	417	208	89	145	356	661	851	1100	(9)
(10)		CDD50	1273	0	0	0	8	108	255	417	336	127	21	1	0	(10)
(11)		CDD65	69	0	0	0	0	1	10	41	16	1	0	0	0	(11)
(12)		CDH74	850	0	0	0	0	39	165	491	152	3	0	0	0	(12)
(13)		CDH80	158	0	0	0	0	1	23	115	19	0	0	0	0	(13)
(14)	Wind	WSAvg	6.4	6.4	6.7	7.2	6.7	6.4	6.7	6.1	5.6	5.9	6.3	6.4	6.7	(14)
(15)	Precipitation	PrecAvg	23.7	1.4	1.3	1.1	1.3	1.7	2.6	3.3	3.0	2.1	2.2	2.1	1.8	(15)
(16)		PrecMax	30.0	3.1	2.6	2.2	3.9	3.3	4.6	7.7	7.1	6.1	4.8	4.7	3.7	(16)
(17)		PrecMin	20.9	0.3	0.5	0.1	0.2	0.6	0.7	0.9	0.2	0.3	0.9	0.6	0.5	(17)
(18)		PrecStd	2.1	0.7	0.5	0.4	0.9	0.7	1.0	1.5	1.6	1.3	1.0	1.1	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.0	47.3	56.6	68.1	77.9	83.0	87.3	82.2	73.5	62.1	53.8	50.8	(19)
(20)			MCWB	41.5	43.5	46.8	51.9	59.2	63.6	65.2	66.6	61.8	56.0	51.3	47.7	(20)
(21)		2%	DB	41.6	43.9	51.8	63.1	74.3	78.8	83.3	78.0	69.5	58.8	50.9	47.0	(21)
(22)			MCWB	39.6	40.4	43.6	49.8	57.9	62.6	65.2	65.3	60.2	54.5	49.1	44.4	(22)
(23)		5%	DB	39.5	41.7	47.7	58.9	70.1	74.6	79.5	74.7	65.8	56.6	48.5	43.6	(23)
(24)			MCWB	38.0	39.3	41.7	48.0	56.3	60.5	64.3	63.4	58.4	53.1	46.8	41.4	(24)
(25)		10%	DB	37.4	39.6	44.1	54.6	65.4	71.0	75.9	71.5	63.0	54.2	46.5	41.1	(25)
(26)			MCWB	36.0	37.5	39.4	45.4	54.2	58.8	63.4	61.7	57.1	51.5	44.8	39.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.3	44.9	48.4	53.3	62.8	66.6	70.8	70.2	63.6	57.8	51.9	48.4	(27)
(28)			MADB	43.4	46.3	54.7	64.4	74.5	77.4	77.6	77.2	71.0	60.4	53.2	50.3	(28)
(29)		2%	WB	40.0	41.3	44.7	51.0	60.0	64.4	68.2	67.6	61.4	55.5	49.7	44.9	(29)
(30)			MADB	41.1	42.8	50.7	60.5	69.4	74.2	75.8	74.4	67.2	58.3	51.0	46.7	(30)
(31)		5%	WB	38.3	39.6	42.5	49.0	57.5	62.2	66.2	65.2	59.6	53.8	47.4	41.9	(31)
(32)			MADB	39.5	41.3	46.9	57.5	67.4	72.3	74.3	72.0	64.4	56.1	48.6	43.3	(32)
(33)		10%	WB	36.2	37.7	40.5	46.7	55.3	60.2	64.5	63.2	58.0	52.2	45.4	39.6	(33)
(34)			MADB	37.4	39.6	43.8	53.7	64.9	68.8	73.5	69.4	62.4	54.4	46.6	41.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.8	11.4	14.1	19.4	20.5	19.6	19.3	18.6	16.7	13.3	8.4	9.1	(35)
(36)			MADB	9.1	9.9	18.7	27.8	28.4	27.9	27.3	24.0	20.5	13.7	10.8	9.3	(36)
(37)			MCWBR	8.3	7.9	12.5	16.7	15.7	14.0	12.7	12.3	12.2	10.0	9.7	9.1	(37)
(38)		5% WB	MADB	8.4	9.0	17.4	24.5	24.7	23.3	21.7	20.9	18.5	12.6	10.7	9.7	(38)
(39)			MCWBR	8.2	7.5	12.0	15.0	14.2	12.7	11.4	12.0	11.5	9.8	9.9	9.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.276	0.317	0.338	0.375	0.371	0.362	0.387	0.379	0.345	0.334	0.303	0.260	(40)	
(41)		taud	2.209	2.275	2.353	2.316	2.393	2.441	2.391	2.408	2.491	2.422	2.269	2.140	(41)	
(42)		Ebn at Noon	166	219	253	262	272	277	266	259	251	213	153	125	(42)	
(43)		Edh at Noon	14	22	28	34	34	33	34	31	24	19	13	10	(43)	
(44)	All-Sky Solar Radiation	RadAvg	100	301	781	1249	1622	1813	1658	1314	865	387	127	67	(44)	
(45)		RadStd	16	44	96	123	147	109	164	131	99	63	28	7	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (54 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-218	-265	N/A	N/A

Nomenclature: See separate page