

EGGEGRUND, Sweden

WMO: 024500

Lat: 60.730N

Lon: 17.558E

Elev: 13

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.3	15.7	8.2	8.4	12.4	11.9	10.1	16.8	36.9	27.1	33.9	26.5	11.2	330	0.732

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.5	73.5	66.1	70.9	64.6	68.6	63.2	67.8	71.6	65.8	69.7	63.9	67.7	9.4	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.4	97.1	70.3	64.1	89.7	68.2	62.4	84.2	66.5	32.2	71.9	30.6	69.8	29.2	67.8	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.1	28.2	25.1	7.3	78.7	7.6	2.6	1.8	80.5	-2.6	82.0	-6.9	83.5	-12.4	85.3		
(5)			7.2	68.5	6.6	2.5	2.4	70.4	-1.4	71.8	-5.2	73.3	-10.0	75.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.1	29.4	28.7	32.2	39.0	47.5	56.3	62.6	61.6	54.6	45.3	38.1	32.8		
	DBStd	13.06	6.21	7.07	6.03	5.02	5.30	5.00	4.43	4.24	3.99	4.88	4.86	6.48		
	HDD50	3294	639	595	553	332	113	5	0	0	8	159	357	533		
	HDD65	7680	1104	1015	1018	781	543	266	103	122	312	611	807	998		
	CDD50	1140	0	0	0	2	35	193	391	360	146	13	0	0		
	CDD65	50	0	0	0	0	0	4	29	17	0	0	0	0		
	CDH74	66	0	0	0	0	0	7	41	18	0	0	0	0		
	CDH80	2	0	0	0	0	0	0	1	1	0	0	0	0		
	WSAvg	12.6	15.0	14.0	12.5	11.0	10.8	10.6	10.6	10.7	11.6	13.9	15.0	15.4		
	PrecAvg	23.0	1.5	1.3	1.1	1.3	1.7	2.5	2.7	2.8	2.1	2.1	2.2	1.8		
(15) Precipitation	PrecMax	31.0	2.9	2.8	2.4	3.5	3.1	5.5	5.4	6.8	4.7	5.2	4.4	3.7		
	PrecMin	18.7	0.2	0.2	0.1	0.2	0.5	0.2	0.9	0.4	0.4	0.1	0.7	0.4		
	PrecStd	3.0	0.7	0.6	0.6	0.9	0.7	1.3	1.4	1.4	1.1	1.1	1.0	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.0	42.5	49.2	58.2	66.7	74.4	79.1	76.4	68.8	57.6	50.9	47.7		
		MCWB	40.5	38.6	41.3	48.6	55.6	61.5	67.7	66.7	60.6	53.2	48.1	45.1		
	2%	DB	40.3	40.1	44.7	52.5	61.1	69.4	74.3	72.7	64.8	55.4	48.4	44.8		
		MCWB	38.1	37.2	39.1	46.1	52.8	61.1	66.9	65.6	58.8	52.5	45.9	42.6		
	5%	DB	38.6	38.4	41.9	48.7	57.6	66.3	71.8	70.2	62.1	53.8	46.4	42.8		
		MCWB	36.7	36.2	37.7	43.8	51.1	59.3	66.1	64.4	57.2	51.4	44.6	40.8		
	10%	DB	37.1	36.8	39.5	45.7	54.8	63.3	69.5	67.8	60.1	52.2	44.7	41.0		
		MCWB	35.5	34.9	36.2	41.7	49.5	57.7	64.5	62.9	56.3	49.8	43.2	39.2		
	0.4%	WB	40.9	40.0	42.1	50.3	57.3	64.3	70.7	69.2	61.3	54.4	48.5	45.8		
		MCDB	42.1	41.5	47.2	56.5	64.9	69.5	74.0	72.7	66.5	56.2	50.0	47.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	38.5	37.7	39.8	46.9	54.0	62.1	69.0	66.8	59.7	53.1	46.2	43.0		
		MCDB	39.7	39.2	43.5	52.5	59.5	68.6	72.4	70.8	63.5	54.9	47.8	44.5		
	5%	WB	36.9	36.3	38.0	44.5	52.1	60.1	67.2	65.2	58.2	51.9	44.6	41.2		
		MCDB	38.1	37.9	40.9	48.5	56.7	65.2	70.9	68.9	61.2	53.8	45.9	42.5		
	10%	WB	35.7	35.0	36.5	42.3	50.2	58.4	65.0	63.8	56.9	50.1	43.3	39.6		
		MCDB	36.9	36.5	38.8	45.3	54.1	62.7	68.9	67.2	59.6	52.1	44.5	40.9		
	5% DB	MDBR	6.1	6.4	7.8	8.4	8.6	8.2	7.5	7.6	7.1	5.7	4.9	5.9		
		MCDBR	6.3	7.3	11.3	14.7	14.2	13.3	11.3	11.1	10.4	7.4	6.4	6.6		
		MCWBR	5.8	5.6	7.5	9.0	7.8	6.7	5.8	6.2	6.4	5.7	6.3	6.1		
		MCWBR	6.1	6.6	10.3	14.6	13.2	11.8	9.2	8.8	9.2	6.9	6.1	6.2		
(35) Mean Daily Temperature Range	5% WB	MCWBR	5.8	5.6	7.0	9.1	8.2	6.6	5.7	5.8	6.2	5.9	6.0	6.1		
	taub		0.265	0.310	0.331	0.365	0.366	0.357	0.381	0.373	0.340	0.326	0.288	0.365		
		taud	2.194	2.284	2.360	2.352	2.418	2.479	2.433	2.451	2.525	2.433	2.236	2.635		
(42) Clear-Sky Solar Irradiance	Ebn at Noon		154	214	252	263	272	277	266	259	249	209	141	107		
		Edh at Noon	12	21	26	32	32	31	32	29	23	18	12	8		
	RadAvg		83	284	756	1225	1573	1752	1632	1268	818	369	110	50		
(45) All-Sky Solar Radiation	RadStd		11	51	88	117	162	124	164	126	102	60	26	6		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (45 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page