

SKEPPMORA, Sweden

WMO: 024720

Lat: 60.1228N

Lon: 15.1228E

Elev: 240

StdP: 98.47

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -19.2	(c) -16.3	(d) -22.2	(e) 0.5	(f) -18.0	(g) -19.2	(h) 0.7	(i) -14.6	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.7	(c) 26.6	(d) 16.9	(e) 24.6	(f) 15.9	(g) 22.8	(h) 15.1	(i) 18.4	(j) 23.8	(k) 17.4	(l) 21.8	(m) 16.5	(n) 20.5	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	12.3	19.5	15.7	11.5	18.8	14.7	10.8	18.0	53.2	24.0	49.8	22.0	47.0	20.4	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) N/A	(b) N/A	(c) N/A	(e) -20.7	(f) 29.5	(g) 4.2	(h) 1.2	(i) -23.8	(j) 30.4	(k) -26.2	(l) 31.1	(m) -28.6	(n) 31.8	(o) -31.6	(p) 32.7		
(4) N/A	(5) N/A	(6) N/A	DB	WB	-21.3	19.6	3.6	0.8	-24.0	20.1	-26.1	20.6	-28.1	21.0	-30.8	21.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.6	-4.7	-3.7	-0.1	5.0	9.7	14.1	16.6	15.4	10.8	5.4	1.1	-3.1
	DBStd	8.42	5.58	4.86	4.47	3.40	3.37	3.30	2.82	2.66	3.05	3.84	4.17	5.77
	HDD10.0	2208	456	383	314	156	48	3	0	1	27	149	266	406
	HDD18.3	4682	714	616	572	401	269	134	69	97	226	402	516	664
	CDD10.0	595	0	0	0	4	37	125	206	167	51	5	0	0
	CDD18.3	28	0	0	0	0	0	6	16	6	0	0	0	0
	CDH23.3	312	0	0	0	0	8	100	158	47	0	0	0	0
	CDH26.7	47	0	0	0	0	0	17	25	5	0	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	785	55	40	41	49	51	76	90	80	76	75	61	
	PrecMax	1105	137	110	85	121	125	246	211	231	164	180	168	158
	PrecMin	575	4	6	3	5	14	14	7	23	9	14	13	10
	PrecStd	122	30	24	22	29	26	47	40	45	38	44	35	32
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.7	6.5	14.3	19.7	24.3	28.9	29.2	27.1	21.8	15.3	10.7	8.9
		MCWB	4.3	3.7	6.7	10.2	14.5	17.2	18.1	17.8	14.5	11.2	9.3	7.6
	2%	DB	4.2	5.0	10.5	16.6	21.4	26.1	27.0	24.5	19.3	13.3	9.4	6.9
		MCWB	3.0	3.0	5.0	8.7	12.9	15.6	17.4	16.5	13.5	10.5	8.1	5.8
	5%	DB	3.1	3.7	7.7	14.1	18.9	23.8	25.1	22.8	17.5	12.0	8.1	5.5
		MCWB	2.1	2.2	3.5	7.2	11.4	14.1	16.7	16.0	12.6	10.1	6.9	4.3
	10%	DB	2.0	2.5	5.5	11.9	16.5	21.4	23.2	20.9	15.8	10.8	6.8	3.9
		MCWB	1.2	1.3	2.3	6.1	10.1	13.3	15.8	15.2	11.9	9.0	5.8	2.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.7	5.0	6.9	11.3	15.8	18.5	19.7	19.9	15.5	12.4	9.9	8.0
		MCDB	5.1	6.0	13.4	17.3	22.9	26.1	26.1	23.6	18.9	13.6	10.6	8.6
	2%	WB	3.4	3.6	5.4	9.4	13.9	16.6	18.6	18.3	14.6	11.3	8.4	6.0
		MCDB	3.9	4.5	9.5	14.7	18.7	23.5	24.8	22.0	17.9	12.7	9.3	6.8
	5%	WB	2.3	2.5	4.2	8.0	12.6	15.3	17.7	17.2	13.7	10.4	7.0	4.5
		MCDB	2.9	3.4	6.9	12.7	17.0	21.1	22.8	20.3	16.3	11.8	7.9	5.3
	10%	WB	1.2	1.2	3.1	6.9	11.1	14.3	16.8	16.2	12.8	9.4	5.9	3.0
		MCDB	1.8	2.2	5.1	10.8	15.3	19.5	21.0	19.2	14.9	10.8	6.7	3.8
Mean Daily Temperature Range	5% DB	MDBR	4.8	6.2	8.3	9.9	10.3	10.5	9.7	9.2	8.7	6.7	4.4	4.4
		MCDBR	4.5	6.7	11.1	14.2	14.9	15.0	13.3	12.6	11.1	7.5	5.7	4.9
		MCWBR	4.6	4.9	6.4	7.0	7.1	6.1	5.4	5.7	5.8	5.0	5.0	5.0
	5% WB	MCDBR	4.4	5.3	9.8	11.9	12.1	12.3	11.6	10.2	9.3	6.1	5.1	4.9
		MCWBR	4.6	4.3	5.8	6.3	6.5	5.8	5.6	5.5	5.6	4.7	4.8	5.1
Clear-Sky Solar Irradiance	taub	0.253	0.297	0.321	0.358	0.357	0.350	0.370	0.363	0.330	0.317	0.277	0.231	
	taud	2.207	2.305	2.371	2.365	2.427	2.470	2.470	2.428	2.442	2.524	2.468	2.277	2.110
	Ebn at Noon	533	709	812	841	870	883	852	829	804	687	497	396	
	Edh at Noon	40	65	83	101	102	99	101	93	72	56	37	28	
All-Sky Solar Radiation	RadAvg	0.28	0.92	2.46	3.87	4.81	5.47	4.98	3.89	2.57	1.16	0.36	0.18	
	RadStd	0.05	0.17	0.29	0.45	0.48	0.37	0.60	0.42	0.35	0.21	0.09	0.02	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-123	N/A	N/A	N/A

Nomenclature: See separate page