

SINGO, Sweden

WMO: 024740

Lat: 60.167N

Lon: 18.750E

Elev: 46

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.8	9.9	0.6	5.7	4.2	6.0	7.5	11.0	33.5	38.2	27.8	33.8	6.2	270	0.668

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	77.3	62.8	73.3	61.1	70.0	59.7	64.7	73.4	62.8	70.7	61.0	67.9	8.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.2	80.9	68.1	59.4	75.9	66.1	57.8	71.4	64.6	29.8	73.5	28.4	70.7	27.1	68.1	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.9	26.9	23.2	DB	2.9	82.4	10.9	4.2	-5.0	85.4	-11.3	87.9	-17.5	90.2	-25.4	93.3	(4)
(5)			WB	2.3	67.3	10.7	2.7	-5.4	69.3	-11.7	70.9	-17.7	72.4	-25.4	74.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.0	28.8	28.5	33.2	38.5	48.0	55.2	61.5	58.8	51.6	43.8	36.0	30.9
	DBStd	13.11	8.83	8.88	7.27	6.42	6.42	5.85	5.07	4.80	4.89	5.58	5.67	6.42
	HDD50	3521	658	603	522	352	119	15	0	1	38	201	420	592
	HDD65	8080	1123	1023	986	795	527	301	135	201	403	659	870	1057
	CDD50	959	0	0	0	8	58	170	357	273	86	7	0	0
	CDD65	41	0	0	0	0	0	6	27	8	0	0	0	0
	CDH74	284	0	0	0	0	9	56	180	37	2	0	0	0
	CDH80	42	0	0	0	0	0	1	36	5	0	0	0	0
Wind	WSAvg	9.2	10.8	9.1	9.2	8.6	7.9	8.1	8.1	8.5	9.6	10.1	10.0	11.0
Precipitation	PrecAvg	22.5	1.5	1.4	1.1	1.3	1.5	2.2	2.4	2.8	2.0	2.2	2.2	2.0
	PrecMax	29.6	2.7	2.9	2.5	3.1	2.9	4.2	6.2	6.9	5.1	4.6	4.5	3.9
	PrecMin	17.2	0.2	0.3	0.0	0.2	0.4	0.5	0.6	0.2	0.5	0.6	0.4	0.4
	PrecStd	3.0	0.7	0.6	0.6	0.9	0.7	1.1	1.5	1.5	1.1	1.1	1.0	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.5	48.6	53.1	67.2	74.8	79.2	84.8	78.6	70.4	57.3	50.8	46.2
		MCWB	41.9	44.3	45.5	54.2	57.8	64.0	65.4	64.7	60.2	50.5	47.2	42.5
	2%	DB	42.5	46.0	47.8	59.3	69.0	75.0	79.0	72.3	64.8	54.8	48.6	43.3
		MCWB	38.2	42.2	41.5	48.5	55.6	60.4	63.5	62.4	56.0	49.9	45.0	40.3
	5%	DB	40.4	42.3	44.7	53.2	65.0	70.3	74.6	68.9	61.7	53.2	45.9	41.3
		MCWB	36.9	38.3	39.6	45.4	53.2	57.6	61.8	60.1	55.3	49.6	43.5	38.8
	10%	DB	38.6	38.8	41.6	48.6	60.6	65.9	71.2	66.7	58.9	51.5	43.7	39.4
		MCWB	35.7	36.3	37.4	43.2	51.0	56.1	60.6	58.6	53.1	48.4	41.3	37.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.2	45.3	47.0	54.3	59.4	66.9	67.4	66.0	60.9	52.5	47.9	42.6
		MCDB	44.8	48.4	52.2	67.0	70.4	76.4	77.3	73.7	67.3	55.1	49.8	45.2
	2%	WB	39.3	42.7	42.6	48.8	56.8	62.2	65.3	63.9	58.7	51.3	45.7	40.8
		MCDB	41.5	45.5	46.3	57.2	67.8	71.7	74.8	70.8	63.8	53.7	47.7	43.2
	5%	WB	37.6	39.0	39.8	46.1	53.7	59.1	63.5	61.9	56.1	50.0	43.5	39.2
		MCDB	39.8	41.1	43.7	52.4	62.6	67.6	72.2	67.5	59.6	52.5	45.6	41.1
	10%	WB	36.0	36.5	37.8	43.5	51.1	56.7	61.8	60.2	54.3	48.5	41.6	37.4
		MCDB	37.9	38.3	41.1	48.4	59.6	65.0	69.8	64.8	57.8	51.2	43.5	39.4
Mean Daily Temperature Range	5% DB	MDBR	7.6	9.1	9.4	11.7	15.6	13.8	13.8	11.3	10.8	8.3	6.7	7.7
		MCDBR	8.6	10.4	13.0	20.1	23.7	21.4	19.4	14.8	14.3	10.6	8.5	8.3
		MCWBR	7.8	8.1	8.4	12.0	12.9	10.1	8.4	7.2	8.0	7.6	7.5	8.1
	5% WB	MCDBR	8.1	8.7	11.5	18.0	22.0	18.8	16.4	13.2	12.6	9.3	7.9	7.9
		MCWBR	7.9	7.6	8.1	11.7	13.1	11.0	8.5	7.7	8.2	7.3	7.4	7.9
Clear-Sky Solar Irradiance	taub	0.276	0.315	0.334	0.369	0.369	0.359	0.386	0.377	0.345	0.331	0.299	0.385	
	taud	2.203	2.283	2.347	2.340	2.409	2.475	2.421	2.441	2.515	2.421	2.236	2.662	
	Ebn at Noon	156	216	252	263	272	277	265	259	249	210	144	111	
	Edh at Noon	13	21	27	33	33	31	32	30	23	19	13	9	
All-Sky Solar Radiation	RadAvg	78	253	732	1260	1705	1905	1776	1384	862	370	107	51	
	RadStd	10	49	79	111	138	121	170	118	89	58	24	7	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (47 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-198	-234	N/A	N/A

Nomenclature: See separate page