

KERSTINBO, Sweden

WMO: 024820

Lat: 60.2683N

Lon: 16.9738E

Elev: 187

StdP: 14.60

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.2	1.0	-9.4	3.3	-4.9	-2.9	4.7	1.4	19.8	40.6	17.0	38.6	1.4	210	0.587

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	80.2	65.3	76.8	63.4	73.4	61.7	67.4	75.7	65.5	73.9	63.6	71.0	6.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.6	91.7	70.5	62.4	84.9	68.1	60.5	79.2	66.7	31.9	75.4	30.4	74.1	29.0	71.0	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.6	13.6	11.9	DB	-11.8	83.1	7.0	2.7	-16.9	85.0	-21.0	86.5	-25.0	88.0	-30.1	89.9	(4)
			WB	-11.5	69.7	6.9	2.3	-16.5	71.4	-20.5	72.8	-24.3	74.0	-29.3	75.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	42.1	24.3	25.3	31.0	40.1	49.5	57.3	61.9	59.6	51.4	41.7	34.2	27.9	(6)
		DBStd	15.10	10.52	9.33	8.72	6.25	6.39	5.67	4.94	4.95	5.77	6.96	7.27	10.35	(7)
		HDD50	3960	796	691	590	305	89	0	2	52	269	473	685		(8)
		HDD65	8401	1261	1111	1055	748	482	239	125	177	409	721	923	1150	(9)
		CDD50	1080	0	0	0	6	72	227	368	301	94	12	0	0	(10)
		CDD65	47	0	0	0	0	0	8	28	11	0	0	0	0	(11)
		CDH74	625	0	0	0	0	20	145	343	115	2	0	0	0	(12)
		CDH80	98	0	0	0	0	1	16	65	16	0	0	0	0	(13)
(14)	Wind	WSAvg	5.4	5.4	5.1	5.4	5.4	5.6	5.4	5.2	5.0	5.1	5.4	5.6	5.5	(14)
(15)	Precipitation	PrecAvg	23.7	1.5	1.0	1.3	1.3	1.4	2.8	2.7	3.0	2.3	2.4	2.2	1.9	(15)
(16)		PrecMax	28.5	2.8	2.1	2.6	3.1	3.0	5.9	5.2	6.8	4.8	5.9	4.6	4.6	(16)
(17)		PrecMin	20.5	0.1	0.0	0.2	0.3	0.4	0.4	0.8	1.3	0.3	0.8	0.9	0.5	(17)
(18)		PrecStd	2.3	0.7	0.6	0.6	0.8	0.6	1.2	1.3	1.3	1.2	1.1	1.0	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	44.6	45.8	58.2	67.7	76.7	82.5	85.9	81.9	72.3	61.1	51.9	50.2		(19)
(20)		0.4% MCWB	41.2	40.2	46.3	52.9	59.1	63.6	67.0	66.6	61.0	55.0	49.6	47.4		(20)
(21)		2% DB	41.4	42.4	51.1	62.0	72.0	78.4	81.4	77.0	67.9	57.3	49.1	45.4		(21)
(22)		2% MCWB	39.0	38.5	42.7	50.0	56.9	62.4	66.2	65.3	59.4	53.4	47.2	43.1		(22)
(23)		5% DB	39.3	39.7	46.5	57.0	66.9	74.3	78.0	73.4	64.5	54.9	46.6	42.5		(23)
(24)		5% MCWB	37.7	37.1	40.0	47.2	55.0	60.1	65.0	62.9	57.9	51.9	45.1	40.2		(24)
(25)		10% DB	36.9	37.4	42.6	52.7	63.0	70.4	74.2	70.2	61.5	52.4	44.7	39.9		(25)
(26)		10% MCWB	35.3	35.2	37.8	44.2	52.6	58.6	63.4	61.8	56.1	50.0	43.4	38.5		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	42.3	42.1	46.7	54.5	61.7	66.3	70.4	70.1	63.2	56.5	50.1	47.8		(27)
(28)		0.4% MCDB	43.9	44.2	55.8	65.0	72.5	77.8	78.0	77.0	68.5	59.6	51.5	49.9		(28)
(29)		2% WB	39.5	39.3	43.5	50.8	58.6	63.9	68.2	66.9	60.3	54.2	47.5	43.4		(29)
(30)		2% MCDB	40.8	41.6	49.8	60.3	68.0	74.7	76.9	73.1	66.1	56.4	48.8	45.0		(30)
(31)		5% WB	37.6	37.5	40.9	47.8	56.2	61.8	66.3	64.9	58.6	52.4	45.3	40.6		(31)
(32)		5% MCDB	39.0	39.5	45.6	55.9	65.3	71.8	76.0	71.2	63.3	54.5	46.4	41.8		(32)
(33)		10% WB	35.7	35.2	38.4	45.2	53.9	59.6	64.5	63.0	56.9	50.2	43.5	38.4		(33)
(34)		10% MCDB	36.9	37.1	41.9	51.1	61.7	68.3	72.9	68.6	60.6	52.0	44.5	39.6		(34)
(35)	Mean Daily Temperature Range	MDBR	10.5	12.4	15.6	18.6	19.8	19.6	19.0	18.0	16.7	12.9	8.7	9.6		(35)
(36)		5% DB MCDBR	9.7	12.5	20.8	27.3	28.6	27.9	26.8	24.1	21.3	14.8	10.9	10.0		(36)
(37)		5% WB MCWBR	9.0	9.5	13.6	16.4	16.0	14.2	13.3	13.5	13.7	11.0	9.8	9.1		(37)
(38)		5% WB MCDBR	9.5	10.8	19.1	24.7	23.6	24.6	22.3	19.7	19.0	12.8	10.3	9.8		(38)
(39)		5% WB MCWBR	9.0	8.7	12.9	15.2	14.1	13.5	11.8	12.1	12.8	10.3	9.4	9.3		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.264	0.309	0.331	0.365	0.364	0.356	0.379	0.373	0.338	0.325	0.289	N/A		(40)
(41)		taud	2.196	2.283	2.362	2.347	2.409	2.458	2.412	2.425	2.511	2.439	2.251	N/A		(41)
(42)		Ebn at Noon	161	218	253	264	274	278	267	259	251	213	148	N/A		(42)
(43)		Edh at Noon	13	21	27	32	33	32	33	30	23	18	12	N/A		(43)
(44)	All-Sky Solar Radiation	RadAvg	89	293	764	1228	1576	1751	1621	1272	830	374	115	56		(44)
(45)		RadStd	13	49	92	121	159	122	163	131	102	61	27	6		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (50 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-198	N/A	N/A	N/A

Nomenclature: See separate page