

SKARPO, Sweden

WMO: 024870

Lat: 59.345N

Lon: 18.740E

Elev: 72

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	10.0	14.7	6.0	7.5	11.8	10.4	9.4	17.1	27.0	29.8	24.7	29.2	7.4	290	0.612

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	76.8	64.9	73.9	63.3	71.3	62.0	67.5	73.2	65.6	70.8	63.9	69.1	7.3	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.5	94.3	70.1	63.6	88.1	68.2	61.7	82.6	66.6	32.0	73.4	30.5	71.0	29.2	69.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.5	20.4	17.8	5.4	80.6	8.6	2.8	-0.9	82.7	-5.9	84.3	-10.8	85.9	-17.0	87.9		
(5)			4.9	69.1	8.1	2.5	-1.0	71.0	-5.7	72.4	-10.3	73.9	-16.2	75.7	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	45.6	29.7	28.9	33.8	41.2	50.4	58.8	64.3	63.1	55.8	46.6	39.1	33.7	(6)
(7)		DBStd	13.62	7.11	7.58	6.64	5.22	5.44	4.56	4.43	4.16	4.38	5.57	5.47	6.98	(7)
(8)		HDD50	3025	630	591	503	268	62	1	0	0	6	132	326	506	(8)
(9)		HDD65	7180	1095	1011	968	715	454	191	68	85	277	569	776	971	(9)
(10)		CDD50	1400	0	0	0	3	73	265	444	407	180	28	0	0	(10)
(11)		CDD65	79	0	0	0	0	0	5	46	27	1	0	0	0	(11)
(12)		CDH74	242	0	0	0	0	1	19	155	67	0	0	0	0	(12)
(13)		CDH80	17	0	0	0	0	0	0	12	5	0	0	0	0	(13)
(14)	Wind	WSAvg	8.6	9.7	9.2	8.8	7.9	7.8	7.9	7.6	7.5	8.5	8.9	10.0	9.8	(14)
(15)	Precipitation	PrecAvg	22.0	1.6	1.3	1.1	1.2	1.4	2.2	2.1	2.4	2.2	2.1	2.0	2.2	(15)
(16)		PrecMax	26.2	3.4	2.5	2.1	3.0	2.8	4.3	4.2	5.7	5.9	4.0	3.9	4.8	(16)
(17)		PrecMin	15.5	0.3	0.3	0.0	0.3	0.4	0.5	0.5	0.1	0.4	1.0	0.5	0.4	(17)
(18)		PrecStd	2.5	0.8	0.5	0.5	0.8	0.6	1.1	1.1	1.5	1.5	0.7	1.0	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.2	46.2	53.6	60.6	71.1	76.9	81.2	80.0	71.3	60.0	51.2	49.5	(19)
(20)			MCWB	41.9	40.9	44.9	49.5	55.6	61.5	66.1	67.5	61.8	55.2	48.0	46.2	(20)
(21)		2%	DB	42.2	42.3	49.1	56.0	65.7	72.7	78.0	75.5	66.7	57.7	49.3	46.3	(21)
(22)			MCWB	40.0	38.5	42.0	47.2	54.1	59.0	65.4	64.8	59.3	54.3	47.2	43.9	(22)
(23)		5%	DB	40.4	40.0	45.4	52.8	62.4	70.0	75.3	72.4	64.3	55.9	47.9	44.4	(23)
(24)			MCWB	38.6	37.5	40.1	45.3	52.7	58.3	64.4	63.8	58.3	53.0	46.3	42.6	(24)
(25)		10%	DB	38.7	38.1	42.0	49.5	59.2	67.2	72.5	69.9	62.1	54.0	46.6	42.5	(25)
(26)			MCWB	37.0	36.2	38.0	43.4	51.0	57.5	63.4	62.3	57.0	51.5	45.0	40.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.8	41.7	45.6	51.0	58.2	64.2	71.1	70.9	62.9	56.7	49.1	47.2	(27)
(28)			MCD B	44.0	44.7	52.1	59.2	66.5	71.1	75.0	76.3	68.3	58.1	50.0	49.0	(28)
(29)		2%	WB	40.4	39.4	42.8	48.2	55.7	61.6	68.3	67.0	60.8	55.0	47.7	44.5	(29)
(30)			MCD B	41.5	41.3	48.1	55.0	63.5	69.1	74.6	71.6	64.8	56.9	48.8	45.7	(30)
(31)		5%	WB	38.8	37.8	40.6	46.2	53.6	60.0	66.5	65.3	59.4	53.5	46.5	42.9	(31)
(32)			MCD B	40.1	39.5	44.7	51.7	60.1	66.7	72.2	70.0	62.8	55.6	47.8	44.1	(32)
(33)		10%	WB	37.2	36.3	38.8	44.0	51.9	58.7	64.7	63.8	58.0	51.9	45.3	41.0	(33)
(34)			MCD B	38.6	38.1	41.4	48.5	57.9	64.8	70.2	68.4	61.2	53.6	46.4	42.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.6	7.8	9.5	11.8	12.4	12.5	11.4	10.6	8.9	7.1	5.7	6.2	(35)
(36)			MCDBR	7.3	8.6	13.8	17.2	17.5	17.1	15.0	13.5	11.3	8.4	6.7	6.6	(36)
(37)			MCWBR	6.9	6.6	8.7	9.8	8.8	7.6	5.8	5.8	5.9	5.8	6.2	6.2	(37)
(38)		5% WB	MCD BR	6.7	7.9	12.9	16.2	15.2	14.6	12.5	11.5	9.8	7.7	6.3	6.3	(38)
(39)			MCWBR	6.5	6.5	8.7	9.9	8.5	7.2	5.9	6.0	5.9	6.1	6.1	6.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.287	0.322	0.339	0.376	0.371	0.363	0.391	0.382	0.350	0.338	0.312	0.271	(40)	
(41)		taud	2.227	2.298	2.355	2.326	2.412	2.475	2.416	2.434	2.505	2.414	2.248	2.142	(41)	
(42)		Ebn at Noon	162	218	253	262	272	277	265	258	249	211	148	120	(42)	
(43)		Edh at Noon	14	22	28	34	33	31	33	30	24	19	14	10	(43)	
(44)	All-Sky Solar Radiation	RadAvg	87	256	737	1289	1736	1922	1793	1413	900	386	119	59	(44)	
(45)		RadStd	12	47	74	118	139	105	161	113	94	62	28	8	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (45 neighbors)	+0.61	N/A	N/A	N/A	N/A	N/A	-191	-232	N/A	N/A

Nomenclature: See separate page