

ORSKAR, Sweden

WMO: 024880

Lat: 60.526N

Lon: 18.373E

Elev: 21

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	13.7	17.7	8.5	8.5	15.5	12.0	10.1	19.2	44.0	31.7	39.3	32.1	13.7	220	0.826

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	75.8	65.0	72.8	63.8	70.2	62.8	67.3	72.6	65.5	70.7	63.8	68.9	11.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.3	93.7	69.9	63.4	87.3	68.0	61.7	82.2	66.7	31.7	73.0	30.3	70.8	29.1	68.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.6	35.0	31.3	DB	10.0	81.1	7.5	3.5	4.5	83.6	0.1	85.6	-4.1	87.5	-9.5	90.1	(4)
(5)			WB	9.7	68.5	6.7	2.6	4.9	70.3	1.0	71.9	-2.8	73.3	-7.6	75.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.6	29.8	29.2	32.5	39.4	48.2	56.5	63.1	62.5	55.4	46.0	38.5	33.3		
	DBStd	13.16	5.71	6.61	5.79	5.43	5.82	5.44	4.85	4.35	4.51	4.97	4.92	5.68		
	HDD50	3199	627	582	543	321	104	8	0	0	7	144	344	519		
	HDD65	7508	1092	1002	1008	768	521	260	97	102	289	591	794	984		
	CDD50	1234	0	0	0	3	48	201	405	389	170	18	0	0		
	CDD65	67	0	0	0	0	0	3	37	26	1	0	0	0		
	CDH74	178	0	0	0	0	3	8	118	49	0	0	0	0		
	CDH80	14	0	0	0	0	0	0	12	2	0	0	0	0		
	WSAvg	15.8	18.0	17.1	16.6	14.8	13.5	13.4	12.8	13.8	15.7	17.6	17.8	19.2		
	PrecAvg	18.3	1.2	1.0	0.9	1.1	1.3	2.0	2.0	2.1	1.7	1.8	1.7	1.3		
(15) Precipitation	PrecMax	27.3	2.6	1.9	1.8	3.1	2.6	4.8	4.8	6.1	3.6	4.5	3.5	2.7		
	PrecMin	12.3	0.1	0.2	0.0	0.1	0.2	0.2	0.3	0.1	0.4	0.1	0.4	0.2		
	PrecStd	3.3	0.6	0.5	0.5	0.7	0.6	1.1	1.3	1.5	0.9	1.0	0.8	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.1	42.5	50.0	61.1	70.2	75.0	81.7	78.5	71.0	59.3	51.1	47.6		
		MCWB	40.0	39.6	42.6	49.7	57.1	61.5	66.6	65.5	61.5	55.1	49.5	45.0		
	2%	DB	40.2	40.3	45.4	55.1	64.4	71.3	77.2	74.8	66.8	56.5	48.6	44.3		
		MCWB	38.5	37.9	40.1	47.1	54.0	60.3	65.8	65.5	60.2	53.4	46.9	42.3		
	5%	DB	38.6	38.6	42.3	50.8	60.3	68.2	73.9	71.8	64.1	54.6	47.1	42.4		
		MCWB	37.0	36.5	38.2	44.4	51.8	59.0	64.8	64.3	58.8	52.1	45.5	40.7		
	10%	DB	37.2	37.0	39.9	47.3	56.9	65.2	71.0	69.4	61.7	52.9	45.5	40.5		
		MCWB	35.8	35.2	36.8	42.1	49.7	57.7	63.6	63.1	57.5	50.5	44.0	38.9		
	0.4%	WB	40.8	40.4	43.2	51.8	59.5	64.1	70.1	70.0	63.0	56.0	50.2	45.6		
		MCDB	41.7	42.1	48.7	58.5	68.2	71.2	75.7	74.4	67.8	58.2	50.9	47.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	38.8	38.4	40.7	47.7	55.1	62.1	68.0	67.0	61.1	54.0	47.4	42.7		
		MCDB	39.9	39.8	44.5	54.0	62.4	68.6	73.9	71.5	65.5	56.0	48.3	44.1		
	5%	WB	37.3	36.9	38.8	44.9	52.4	60.2	66.2	65.4	59.6	52.5	45.7	40.8		
		MCDB	38.3	38.4	41.8	49.8	58.6	66.0	72.2	69.9	63.2	54.5	46.8	42.0		
	10%	WB	35.8	35.3	37.1	42.7	50.6	58.3	64.5	63.9	58.1	50.7	44.2	39.0		
		MCDB	37.0	36.7	39.6	46.5	55.9	64.2	70.3	68.3	61.2	52.5	45.4	40.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.7	6.0	7.5	9.2	10.0	9.7	9.2	9.0	7.6	5.8	4.9	5.5		
		MCDBR	5.8	6.8	11.3	15.8	16.9	15.5	14.3	12.9	11.3	7.7	6.3	6.0		
		MCWBR	5.5	5.8	7.4	9.2	9.0	8.0	6.5	6.3	6.4	5.7	6.1	5.8		
		MCDBR	5.6	6.5	10.4	14.4	14.7	13.9	12.1	10.7	10.2	7.4	6.1	5.6		
	5% WB	MCWBR	5.6	5.7	7.4	9.1	8.9	8.1	6.6	6.2	6.4	6.0	6.0	5.7		
(40) Clear-Sky Solar Irradiance	taub		0.272	0.313	0.333	0.367	0.367	0.358	0.383	0.374	0.343	0.329	0.294	0.373		
	taud		2.202	2.284	2.349	2.348	2.418	2.484	2.434	2.453	2.523	2.423	2.232	2.633		
	Ebn at Noon		154	214	252	263	272	277	266	259	249	208	141	107		
	Edh at Noon		12	21	27	32	32	31	32	29	23	18	12	9		
(44) All-Sky Solar Radiation	RadAvg		75	257	735	1248	1683	1886	1755	1361	844	364	102	48		
	RadStd		9	50	82	109	141	129	173	122	89	57	23	7		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	-144	N/A	N/A	N/A	
(47)	Regional (45 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-180	N/A	N/A	N/A	(47)

Nomenclature: See separate page