

NORDKOSTER, Sweden

WMO: 025000

Lat: 58.892N

Lon: 11.004E

Elev: 115

StdP: 14.64

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	13.6	17.1	7.0	7.9	17.4	10.5	9.4	20.6	43.7	34.6	36.3	32.6	12.0	50	0.726

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.3	75.4	64.1	72.5	63.6	70.0	62.6	66.8	72.3	65.2	70.2	63.7	68.3	9.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.6	91.6	69.9	63.1	86.9	68.2	61.7	82.4	66.5	31.4	72.4	30.2	70.4	29.0	68.3	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.2	29.1	25.7	DB	11.1	79.9	4.7	3.3	7.7	82.3	4.9	84.2	2.3	86.1	-1.2	88.5	(4)
(5)			WB	10.1	68.8	4.2	1.4	7.1	69.9	4.6	70.7	2.3	71.5	-0.7	72.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.9	32.3	31.6	35.5	43.2	52.4	58.8	63.6	63.0	56.9	47.9	40.5	35.4	(6)	
	DBStd	12.78	7.21	7.13	5.76	4.87	5.64	4.20	4.07	3.58	4.18	5.30	6.43	7.94	(7)	
	HDD50	2602	547	516	449	211	33	0	0	0	4	103	286	453	(8)	
	HDD65	6687	1012	936	914	653	393	192	76	83	245	531	734	918	(9)	
	CDD50	1456	0	0	0	8	108	265	422	404	210	37	2	0	(10)	
	CDD65	66	0	0	0	0	2	7	34	23	0	0	0	0	(11)	
	CDH74	152	0	0	0	0	10	19	100	23	0	0	0	0	(12)	
	CDH80	8	0	0	0	0	1	1	6	0	0	0	0	0	(13)	
(14) Wind	WSAvg	13.1	14.0	13.7	12.8	12.1	11.9	11.9	11.6	12.0	13.3	14.2	15.0	14.6	(14)	
(15) Precipitation	PrecAvg	30.9	2.6	2.0	1.5	1.9	1.9	3.0	2.7	3.5	3.0	3.5	3.1	2.8	(15)	
	PrecMax	39.0	5.7	5.1	5.0	3.4	3.8	6.6	5.1	6.9	7.1	7.3	6.0	6.0	(16)	
	PrecMin	21.1	0.3	0.7	0.0	0.6	0.0	0.2	0.4	0.8	0.9	0.5	0.9	0.7	(17)	
	PrecStd	4.6	1.3	1.3	1.1	0.9	1.0	1.3	1.3	1.5	1.4	1.7	1.5	1.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.4	44.7	51.2	62.9	74.6	76.6	80.8	76.5	70.0	59.4	54.2	49.5	(19)	
		MCWB	44.0	42.1	44.2	50.6	61.3	62.0	66.5	64.3	60.8	55.5	51.7	47.6	(20)	
	2%	DB	44.5	43.0	46.8	57.2	69.2	71.7	77.0	73.6	66.2	57.5	52.2	47.8	(21)	
		MCWB	42.3	41.1	41.6	48.1	56.9	60.8	64.8	64.2	59.4	54.5	50.2	45.7	(22)	
	5%	DB	43.0	41.8	44.1	53.4	64.8	68.4	73.2	71.2	64.1	56.2	50.6	46.7	(23)	
		MCWB	41.1	40.2	40.1	46.1	55.3	59.5	64.9	63.7	58.8	53.5	48.4	44.7	(24)	
	10%	DB	41.6	40.5	42.3	50.3	60.8	65.6	70.4	69.0	62.7	55.1	49.1	45.2	(25)	
		MCWB	39.8	39.1	39.5	44.9	53.5	58.1	63.7	62.9	58.1	52.6	46.8	43.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.9	43.2	44.9	52.1	61.8	64.9	68.9	68.4	64.0	57.0	52.9	48.3	(27)	
		MCDB	45.7	43.6	48.8	59.6	69.6	71.2	76.1	73.1	68.1	58.0	53.5	49.2	(28)	
	2%	WB	43.1	41.8	42.7	49.3	58.9	62.3	67.3	66.5	61.5	55.5	50.6	46.6	(29)	
		MCDB	44.0	42.4	44.5	55.0	64.1	67.8	73.5	71.2	64.1	56.6	51.7	47.6	(30)	
	5%	WB	41.5	40.7	41.3	47.5	56.2	60.7	65.8	65.1	60.2	54.3	48.9	45.2	(31)	
		MCDB	42.5	41.5	43.0	51.5	61.2	66.5	71.3	69.8	62.9	55.6	50.3	46.3	(32)	
	10%	WB	40.2	39.5	40.1	45.8	54.0	59.3	64.2	63.7	59.0	52.8	47.3	43.7	(33)	
		MCDB	41.3	40.5	41.6	49.3	58.5	63.8	68.7	68.2	61.8	54.5	48.7	45.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.9	5.8	7.1	8.6	9.1	8.6	8.3	7.8	7.3	6.2	5.5	5.8	(35)	
		MCDBR	6.1	5.0	9.1	13.1	14.9	13.0	13.4	11.1	8.9	5.9	6.1	4.6	(36)	
	5% WB	MCWBR	6.6	4.6	6.1	7.5	7.5	7.1	6.8	5.7	6.1	5.4	6.9	5.6	(37)	
		MCWBR	5.8	4.5	7.1	10.3	12.1	10.4	11.0	9.2	7.4	5.3	5.5	4.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.289	0.323	0.341	0.379	0.373	0.361	0.383	0.379	0.350	0.337	0.305	0.267	(40)	
		taud	2.242	2.321	2.367	2.315	2.410	2.469	2.428	2.431	2.498	2.423	2.287	2.168	(41)	
	Ebn at Noon	Ebn at Noon	167	221	254	261	272	278	268	259	250	214	159	131	(42)	
		Edh at Noon	14	22	27	34	33	32	32	30	24	20	14	10	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	102	284	759	1239	1663	1888	1712	1340	890	397	134	69	(44)	
	RadStd	RadStd	19	53	76	165	153	115	184	87	92	63	31	7	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (56 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page