

MASESKAR, Sweden

WMO: 025050

Lat: 58.0938N

Lon: 11.3318E

Elev: 49

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	17.0	20.5	11.0	9.7	22.0	14.3	11.4	23.5	43.0	39.7	40.0	38.8	13.7	50	0.794

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.6	73.5	65.8	71.2	64.8	69.1	63.3	67.3	71.8	65.7	70.0	64.1	68.0	10.8	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.3	93.8	70.4	63.7	88.6	68.7	62.2	83.9	66.9	31.8	72.1	30.6	70.3	29.3	68.2	71.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
38.9	34.8	31.7	15.8	76.7	5.0	3.1	12.2	78.9	9.3	80.7	6.5	82.4	2.8	84.6
			14.4	68.2	4.5	2.2	11.1	69.8	8.5	71.1	6.0	72.3	2.7	73.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.8	33.9	33.6	36.2	43.7	52.4	58.4	63.6	63.3	57.8	50.0	42.7	37.6
	DBStd	11.99	6.63	6.20	5.01	4.69	5.14	3.92	3.83	3.50	3.69	4.80	5.96	7.13
	HDD50	2286	500	461	427	200	28	0	0	0	1	61	222	386
	HDD65	6326	965	881	892	640	391	202	75	78	217	466	668	851
	CDD50	1496	0	0	0	10	104	253	420	411	235	59	4	0
	CDD65	63	0	0	0	0	2	5	31	24	1	0	0	0
	CDH74	48	0	0	0	0	3	3	33	9	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	16.2	17.9	16.9	15.7	14.2	14.1	14.3	13.9	15.4	17.0	18.2	19.0	18.4
Precipitation	PrecAvg	29.2	2.6	1.8	1.5	1.8	1.8	2.6	2.8	3.1	2.7	3.3	3.0	2.6
	PrecMax	37.8	4.8	4.4	3.9	3.5	3.2	5.6	6.1	5.6	6.7	6.9	7.6	5.4
	PrecMin	23.3	0.3	0.7	0.3	0.4	0.2	0.0	0.2	0.4	0.4	0.6	1.0	0.4
	PrecStd	4.1	1.2	1.0	0.8	0.9	0.8	1.3	1.6	1.3	1.5	1.5	1.5	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.9	44.1	47.3	62.1	71.0	73.3	77.9	75.3	68.7	59.9	54.9	49.7
		MCWB	45.1	42.5	43.1	53.2	60.6	62.9	67.0	66.9	62.5	57.0	53.0	48.2
	2%	DB	45.2	43.1	44.5	56.1	66.0	69.1	74.2	72.8	65.8	58.3	53.0	48.4
		MCWB	43.3	41.7	42.0	49.2	58.1	61.9	66.1	66.2	61.0	55.9	51.0	46.5
	5%	DB	43.8	42.2	43.1	52.9	62.5	66.5	71.6	70.9	64.2	57.1	51.7	47.4
		MCWB	41.9	40.9	40.9	47.6	56.1	60.5	65.4	65.0	59.9	54.8	49.5	45.6
	10%	DB	42.3	41.1	42.0	50.0	59.5	64.3	69.5	68.7	62.9	56.1	50.2	46.1
		MCWB	40.5	39.7	40.1	45.9	54.7	59.4	63.9	63.4	58.9	53.6	48.0	44.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.7	43.2	44.1	54.9	62.1	65.3	69.3	69.1	64.2	58.2	53.7	48.6
		MCDB	46.4	43.6	46.0	61.9	69.0	69.6	74.4	73.0	67.2	59.1	54.5	49.3
	2%	WB	43.9	42.1	42.5	50.4	59.4	62.9	67.5	67.4	62.6	56.6	51.5	47.0
		MCDB	44.8	42.8	43.6	54.3	64.1	67.2	72.4	71.5	64.8	57.6	52.7	47.8
	5%	WB	42.2	41.2	41.4	48.4	57.2	61.3	66.1	65.8	61.0	55.5	50.0	46.0
		MCDB	43.4	42.0	42.4	52.1	61.0	65.2	70.7	70.0	63.5	56.9	51.4	47.0
	10%	WB	40.8	40.0	40.5	46.5	55.1	59.9	64.6	64.0	59.6	54.2	48.4	44.6
		MCDB	42.2	40.9	41.6	49.3	58.6	63.5	68.8	67.8	62.4	55.9	50.1	45.9
Mean Daily Temperature Range	5% DB	MDBR	5.2	4.6	5.0	6.2	6.5	5.9	5.6	5.3	5.2	4.7	4.6	4.9
		MCDBR	5.5	3.8	5.1	10.2	11.0	9.0	8.6	7.7	6.4	4.2	4.5	4.1
		MCWBR	6.0	3.8	4.4	6.5	6.7	6.3	5.4	5.2	4.9	4.5	5.6	4.7
	5% WB	MCDBR	5.2	3.6	4.8	8.6	9.3	7.4	7.7	6.4	5.3	4.2	4.1	4.1
MCWBR		5.7	3.7	4.4	5.7	6.4	5.9	5.5	5.3	4.9	5.1	5.4	4.9	
Clear-Sky Solar Irradiance	taub	0.300	0.329	0.346	0.384	0.377	0.366	0.388	0.387	0.357	0.344	0.316	0.282	
	taud	2.249	2.315	2.357	2.302	2.403	2.461	2.419	2.416	2.485	2.415	2.292	2.193	
	Ebn at Noon	171	222	254	261	272	277	267	258	250	215	162	137	
	Edh at Noon	15	23	28	35	34	32	33	31	25	20	15	12	
All-Sky Solar Radiation	RadAvg	109	289	757	1274	1715	1923	1764	1374	919	416	145	75	
	RadStd	21	53	72	156	143	121	167	85	89	57	28	8	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (57 neighbors)	+0.68	N/A	N/A	N/A	N/A	N/A	-216	-274	N/A	N/A

Nomenclature: See separate page