

HUD, Sweden

WMO: 025070

Lat: 58.6608N

Lon: 11.4178E

Elev: 95

StdP: 100.19

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.2	-11.8	-16.2	0.9	-13.9	-13.8	1.1	-10.3	5.4	2.4	4.9	2.1	1.4	50	0.519

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	26.7	18.8	24.9	17.9	23.0	16.9	19.9	24.8	18.7	23.2	17.7	21.7	1.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.2	22.0	17.1	12.3	20.4	16.2	11.7	19.3	57.1	24.8	53.6	23.2	50.3	21.8	23.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.5	4.0	3.5	-17.4	29.5	2.7	1.2	-19.3	30.4	-20.9	31.1	-22.4	31.8	-24.3	32.6		
			-18.0	21.4	2.4	0.8	-19.7	22.0	-21.1	22.5	-22.5	23.0	-24.3	23.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.3	-1.8	-1.3	1.5	6.3	10.9	14.7	17.4	16.5	12.1	7.6	3.5	-0.7
	DBStd	7.67	4.85	4.09	3.75	3.13	3.31	2.66	2.53	2.53	2.76	3.59	4.04	5.26
	HDD10.0	1719	365	315	264	117	26	1	0	0	12	91	197	333
	HDD18.3	4076	623	548	522	360	231	116	51	68	187	333	446	591
	CDD10.0	723	0	0	0	7	54	141	228	203	75	16	1	0
	CDD18.3	38	0	0	0	0	1	5	21	12	1	0	0	0
	CDH23.3	337	0	0	0	0	9	79	173	74	1	0	0	0
	CDH26.7	47	0	0	0	0	0	13	28	5	0	0	0	0
Wind	WSAvg	1.7	1.8	2.0	1.9	1.7	1.7	1.5	1.4	1.4	1.6	1.6	1.8	1.7
Precipitation	PrecAvg	887	83	59	46	51	51	81	77	81	82	103	91	81
	PrecMax	1243	172	153	119	106	103	171	161	143	183	241	231	174
	PrecMin	670	15	14	4	12	0	5	8	14	33	46	29	16
	PrecStd	151	41	36	27	28	27	34	37	31	40	48	54	46
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.6	7.3	14.5	19.6	24.5	28.7	29.4	27.4	22.9	16.4	12.0	9.1
		MCWB	6.5	5.2	8.1	11.3	15.8	18.7	19.2	19.6	17.0	13.1	10.9	8.3
	2%	DB	6.3	6.1	10.5	17.2	22.4	25.5	27.4	25.5	19.6	14.5	10.7	8.0
		MCWB	5.4	4.9	6.1	10.5	14.4	16.7	19.4	18.8	15.0	12.5	9.7	6.9
	5%	DB	5.3	5.2	8.1	14.6	19.9	23.2	25.5	23.5	17.9	13.5	10.0	7.2
		MCWB	4.4	4.2	4.5	8.8	13.0	15.6	18.7	17.9	14.0	12.0	9.1	6.3
	10%	DB	4.5	4.3	6.3	12.4	17.3	20.9	23.2	21.5	16.6	12.7	9.1	6.2
		MCWB	3.7	3.4	4.0	7.5	11.4	14.5	17.7	17.2	13.6	11.3	8.2	5.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.0	6.1	8.5	12.1	17.0	19.7	21.4	21.0	17.3	14.2	11.3	8.6
		MCDB	7.4	6.6	13.7	18.2	22.6	26.3	26.3	26.0	20.7	15.2	11.7	9.1
	2%	WB	5.7	5.2	6.5	10.7	15.3	17.8	20.2	19.6	15.9	13.2	10.0	7.2
		MCDB	6.1	5.7	9.6	15.9	20.5	23.9	25.5	23.6	18.1	14.0	10.4	7.7
	5%	WB	4.7	4.4	5.5	9.4	13.8	16.3	19.2	18.5	15.1	12.4	9.3	6.4
		MCDB	5.1	5.0	7.2	13.2	18.1	21.5	23.9	22.3	17.0	13.3	9.9	7.0
	10%	WB	3.7	3.5	4.6	8.2	12.4	15.2	18.1	17.5	14.2	11.5	8.4	5.4
		MCDB	4.3	4.3	5.8	11.5	16.4	19.7	22.5	20.7	16.0	12.5	9.1	6.2
Mean Daily Temperature Range	5% DB	MDBR	4.7	5.1	7.5	9.4	9.7	9.7	8.9	8.5	7.7	6.3	4.7	4.6
		MCDBR	4.8	4.6	10.3	13.2	13.0	13.9	12.7	11.1	9.6	6.3	5.0	4.3
		MCWBR	4.8	3.8	6.3	7.4	6.5	6.4	5.9	5.4	5.5	4.7	4.9	4.5
	5% WB	MCDBR	4.6	3.9	8.9	11.2	11.2	12.1	11.1	10.2	8.1	5.7	4.7	4.2
		MCWBR	4.7	3.5	5.8	6.7	6.2	6.2	5.6	5.5	5.4	4.7	4.7	4.5
Clear-Sky Solar Irradiance	taub	0.289	0.321	0.340	0.377	0.372	0.360	0.382	0.379	0.349	0.337	0.305	0.269	
	taud	2.238	2.315	2.363	2.312	2.405	2.462	2.421	2.424	2.493	2.420	2.286	2.169	
	Ebn at Noon	534	702	803	827	861	876	845	820	791	679	508	420	
	Edh at Noon	46	69	87	108	105	101	103	96	77	62	44	34	
All-Sky Solar Radiation	RadAvg	0.33	0.90	2.39	3.95	5.33	6.04	5.51	4.30	2.85	1.27	0.43	0.22	
	RadStd	0.06	0.17	0.23	0.52	0.47	0.35	0.56	0.27	0.29	0.19	0.09	0.02	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (55 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page