

GOTEBORG SAVE, Sweden

WMO: 025120

Lat: 57.775N

Lon: 11.870E

Elev: 59

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 94-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.2	12.4	4.8	7.0	10.1	8.7	8.6	15.6	28.5	38.6	25.9	37.6	2.8	60	0.637

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	78.5	64.4	75.3	63.5	72.0	62.2	67.4	73.6	65.5	71.9	63.8	69.8	9.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.8	92.1	69.7	63.0	86.3	68.0	61.2	80.9	66.3	31.8	73.5	30.4	72.1	29.2	70.4	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.5	21.6	19.3	DB	1.3	84.2	6.2	2.5	-3.2	86.0	-6.8	87.5	-10.3	89.0	-14.8	90.8	(4)
(5)			WB	0.8	70.7	6.1	2.6	-3.6	72.6	-7.1	74.2	-10.5	75.6	-14.9	77.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.7	31.2	30.9	35.1	43.3	51.1	57.0	62.1	61.4	55.0	46.7	39.4	33.7	(6)	
	DBStd	12.92	8.43	7.59	6.43	6.21	5.87	4.57	4.33	4.58	5.23	6.56	7.25	9.19	(7)	
	HDD50	2839	583	535	461	217	55	2	0	0	18	140	322	506	(8)	
	HDD65	7107	1048	955	926	650	432	244	113	129	301	569	769	971	(9)	
	CDD50	1257	0	0	0	17	89	213	376	355	168	36	3	0	(10)	
	CDD65	49	0	0	0	0	1	5	24	18	1	0	0	0	(11)	
	CDH74	412	0	0	0	5	13	60	199	129	6	0	0	0	(12)	
	CDH80	45	0	0	0	0	0	7	31	7	0	0	0	0	(13)	
	WSAvg	8.7	9.5	9.5	9.0	8.3	8.4	8.5	7.6	7.5	8.4	9.1	9.2	9.2	(14)	
	PrecAvg	32.0	2.8	1.9	2.0	1.9	2.0	2.7	2.8	3.1	3.0	3.4	3.3	3.1	(15)	
(16) Precipitation	PrecMax	48.4	6.0	7.0	4.6	4.4	5.0	6.4	6.0	7.8	8.3	8.7	7.8	7.8	(16)	
	PrecMin	22.8	0.6	0.0	0.0	0.0	0.3	0.2	0.3	0.3	0.4	1.1	0.9	0.7	(17)	
	PrecStd	5.1	1.5	1.3	1.1	1.0	1.0	1.4	1.3	1.7	1.5	1.7	1.6	1.7	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.8	45.8	55.6	71.5	75.4	79.2	83.9	80.6	74.7	61.2	55.2	50.1	(19)	
		MCWB	45.6	43.5	46.5	55.9	61.0	62.7	66.3	65.4	63.4	57.4	53.1	48.8	(20)	
	2%	DB	44.8	43.2	48.6	62.8	71.3	75.1	79.0	77.3	69.4	59.0	52.8	48.2	(21)	
		MCWB	43.6	41.8	43.5	52.1	58.0	62.1	65.1	64.7	61.1	56.1	50.8	47.0	(22)	
	5%	DB	43.0	42.1	46.0	58.7	66.4	70.1	75.4	74.9	66.0	57.2	51.2	46.6	(23)	
		MCWB	42.0	40.8	41.9	49.3	56.0	59.5	64.0	64.1	59.5	54.6	49.3	45.4	(24)	
	10%	DB	41.3	40.8	43.2	53.9	62.5	66.4	72.0	71.3	63.0	55.6	49.6	44.9	(25)	
		MCWB	40.4	39.6	40.5	47.2	54.0	58.6	62.9	63.2	58.4	53.1	48.1	43.7	(26)	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.0	44.2	47.6	57.5	63.5	66.5	69.9	69.5	65.1	59.0	53.6	48.8	(27)	
		MCDB	46.4	44.7	53.6	68.4	73.0	73.7	78.2	74.9	71.6	60.4	54.8	49.2	(28)	
	2%	WB	43.6	42.2	44.5	52.9	60.1	63.3	67.5	67.5	62.4	56.9	51.3	47.0	(29)	
		MCDB	44.1	42.8	47.1	60.3	67.8	70.8	74.4	72.9	66.5	58.5	52.6	47.5	(30)	
	5%	WB	42.0	40.7	42.6	50.6	57.3	61.3	65.7	65.7	60.6	55.3	49.5	45.5	(31)	
		MCDB	42.5	41.4	44.4	56.3	63.6	68.0	72.4	71.4	64.4	56.9	50.5	46.2	(32)	
	10%	WB	40.4	39.3	41.1	48.4	55.1	59.5	64.0	63.9	59.3	53.8	47.8	43.8	(33)	
		MCDB	41.1	40.1	42.6	53.2	60.9	65.2	70.1	69.3	62.8	55.5	48.8	44.7	(34)	
(36) Mean Daily Temperature Range	5% DB	MDBR	8.7	9.5	12.2	15.4	15.7	14.3	14.4	14.4	13.8	11.3	9.0	8.7	(35)	
		MCDBR	7.6	7.4	15.7	23.3	23.5	23.2	22.3	21.6	18.2	10.9	8.0	7.1	(36)	
		MCWBR	7.7	6.6	11.0	13.8	13.1	12.7	12.1	11.8	11.4	8.7	7.9	7.2	(37)	
	5% WB	MCDBR	6.6	6.8	12.2	19.5	19.4	18.5	18.2	17.4	14.5	9.9	8.1	6.9	(38)	
		MCWBR	6.9	6.5	9.6	12.6	12.1	11.4	11.1	11.1	10.4	8.7	8.3	7.2	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.302	0.330	0.347	0.386	0.380	0.369	0.391	0.391	0.359	0.346	0.320	0.287	(40)	
	taud		2.252	2.312	2.352	2.296	2.387	2.444	2.401	2.400	2.474	2.410	2.302	2.202	(41)	
	Ebn at Noon		173	223	254	261	271	276	266	257	249	216	165	140	(42)	
	Edh at Noon		16	23	29	35	34	33	34	32	25	21	15	12	(43)	
(44) All-Sky Solar Radiation	RadAvg		114	298	760	1263	1680	1861	1702	1333	905	415	150	79	(44)	
	RadStd		23	52	73	157	142	124	180	101	96	61	27	9	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (59 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	-232	-320	N/A	N/A	

Nomenclature: See separate page