

GOTEBORG, Sweden

WMO: 025130

Lat: 57.7156N

Lon: 11.9924E

Elev: 10

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 11.3	(c) 16.0	(d) 5.9	(e) 7.5	(f) 15.5	(g) 9.7	(h) 9.1	(i) 20.3	(j) 24.0	(k) 42.9	(l) 20.9	(m) 43.3	(n) 3.9	(o) 40	(p) 0.538

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	80.7	64.6	77.7	63.7	74.6	62.3	67.5	76.2	65.8	73.9	64.2	71.5	7.4	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.5	90.9	71.3	62.8	85.5	69.3	61.2	80.9	67.6	31.9	76.2	30.6	74.0	29.4	71.7	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)			(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.3	15.9	13.9	DB		7.1	85.6	5.1	2.8	3.4	87.6	0.4	89.2	-2.5	90.8	-6.2	92.8
			WB		6.3	70.7	5.0	2.1	2.7	72.3	-0.3	73.5	-3.1	74.7	-6.7	76.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.8	32.6	33.0	37.3	45.5	53.8	60.3	64.7	64.0	57.3	48.2	41.3	35.1
	DBStd	13.14	7.69	7.04	6.45	5.98	6.34	4.89	4.62	4.31	4.92	6.28	6.74	8.59
	HDD50	2438	539	476	393	160	28	0	0	0	6	106	267	463
	HDD65	6384	1004	896	858	585	353	160	62	71	235	520	712	928
	CDD50	1649	0	0	0	25	146	308	457	434	224	51	4	0
	CDD65	122	0	0	0	1	6	18	54	40	3	0	0	0
	CDH74	770	0	0	0	4	58	143	358	194	13	0	0	0
	CDH80	115	0	0	0	0	7	20	71	17	0	0	0	0
Wind	WSAvg	6.4	6.5	6.3	6.4	6.4	6.7	6.7	6.3	6.0	6.5	6.2	6.6	6.2
Precipitation	PrecAvg	32.0	2.8	1.9	2.0	1.9	2.0	2.7	2.8	3.1	3.0	3.4	3.3	3.1
	PrecMax	48.4	6.0	7.0	4.6	4.4	5.0	6.4	6.0	7.8	8.3	8.7	7.8	7.8
	PrecMin	22.8	0.6	0.0	0.0	0.0	0.3	0.2	0.3	0.3	0.4	1.1	0.9	0.7
	PrecStd	5.1	1.5	1.3	1.1	1.0	1.0	1.4	1.3	1.7	1.5	1.7	1.6	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.5	47.6	58.6	71.1	80.1	82.8	85.9	82.4	75.7	64.0	55.8	50.7
		MCWB	45.3	43.8	47.1	56.3	61.5	65.5	67.5	65.8	62.7	57.3	53.5	49.1
	2%	DB	45.5	45.0	51.6	64.0	74.6	78.1	81.8	79.0	70.8	59.9	53.4	48.7
		MCWB	43.6	42.7	44.9	52.1	58.4	62.3	66.1	64.6	61.1	56.0	51.3	47.0
	5%	DB	43.9	43.7	47.8	59.8	70.2	74.0	78.1	75.8	67.6	58.1	51.9	47.4
		MCWB	42.0	41.8	42.4	49.6	57.0	60.9	64.6	63.9	59.7	54.7	49.6	45.7
	10%	DB	42.3	42.3	45.3	55.6	65.6	69.8	74.5	72.2	64.9	56.5	50.2	45.8
		MCWB	40.4	40.5	41.4	47.5	54.5	58.8	63.2	63.0	58.8	53.4	48.0	44.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.3	44.9	48.6	57.5	64.5	68.0	70.1	69.8	65.3	59.0	53.9	49.5
		MCDB	47.0	46.2	56.3	67.8	74.2	78.1	80.2	76.8	71.8	61.3	55.1	50.4
	2%	WB	44.0	43.5	45.8	53.3	61.2	64.4	68.0	67.2	62.5	56.9	51.7	47.5
		MCDB	45.0	44.6	50.1	61.6	70.7	73.1	77.7	74.0	68.1	59.4	53.1	48.6
	5%	WB	42.2	42.2	43.8	50.8	58.2	62.2	66.4	65.4	61.0	55.3	50.0	45.9
		MCDB	43.5	43.5	46.9	57.5	67.1	70.0	75.2	72.3	66.0	57.5	51.5	47.2
	10%	WB	40.6	40.6	42.2	48.5	55.7	60.3	64.7	63.9	59.6	53.8	48.3	44.3
		MCDB	42.2	42.1	44.8	54.3	63.3	67.8	72.6	70.3	64.0	56.1	50.1	45.8
Mean Daily Temperature Range	5% DB	MDBR	7.8	8.1	11.2	13.3	14.2	12.8	12.8	12.4	12.0	9.8	7.6	7.3
		MCDBR	7.8	7.4	14.5	20.6	22.1	20.9	20.1	18.8	16.1	10.1	6.6	6.7
		MCWBR	7.6	6.1	9.3	11.4	10.6	10.1	8.4	8.6	8.7	7.3	6.4	6.8
	5% WB	MCDBR	7.2	6.3	12.4	17.3	19.4	16.8	16.7	14.6	12.9	8.7	6.7	6.7
		MCWBR	7.3	5.7	8.7	10.5	10.5	9.3	8.3	8.5	8.3	7.2	6.6	6.9
Clear-Sky Solar Irradiance	taub	0.303	0.331	0.348	0.387	0.381	0.370	0.392	0.392	0.360	0.347	0.322	0.288	
	taud	2.253	2.310	2.348	2.293	2.382	2.439	2.396	2.395	2.470	2.407	2.304	2.204	
	Ebn at Noon	173	223	254	261	271	276	266	257	249	215	165	140	
	Edh at Noon	16	23	29	35	35	33	34	32	25	21	15	12	
All-Sky Solar Radiation	RadAvg	115	301	760	1257	1667	1839	1682	1319	900	413	150	80	
	RadStd	23	51	74	158	144	124	186	105	98	62	27	9	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (61 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	-223	-319	N/A	N/A

Nomenclature: See separate page