

GOTEBORG, Sweden

WMO: 025130

Lat: 57.7156N

Lon: 11.9924E

Elev: 3

StdP: 101.29

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.5	-8.9	-14.5	1.1	-9.2	-12.4	1.3	-6.5	10.7	6.1	9.3	6.3	1.7	40	0.538

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.1	27.1	18.1	25.4	17.6	23.7	16.8	19.7	24.6	18.8	23.3	17.9	22.0	3.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.0	21.8	17.1	12.2	20.7	16.2	11.6	19.8	56.4	24.5	53.3	23.3	50.5	22.1	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.1	6.2	-13.8	29.8	2.8	1.6	-15.9	30.9	-17.6	31.8	-19.2	32.7	-21.2	33.8		
(5)			-14.3	21.5	2.8	1.2	-16.3	22.4	-17.9	23.1	-19.5	23.7	-21.5	24.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	0.3	0.6	3.0	7.5	12.1	15.7	18.2	17.8	14.0	9.0	5.1	1.7
	DBStd	7.30	4.27	3.91	3.58	3.32	3.52	2.72	2.57	2.39	2.73	3.49	3.75	4.77
	HDD10.0	1354	299	264	218	89	16	0	0	0	3	59	148	257
	HDD18.3	3547	558	498	477	325	196	89	34	39	131	289	396	516
	CDD10.0	916	0	0	0	14	81	171	254	241	124	28	2	0
	CDD18.3	68	0	0	0	1	3	10	30	22	2	0	0	0
	CDH23.3	428	0	0	0	2	32	79	199	108	7	0	0	0
	CDH26.7	64	0	0	0	0	4	11	39	9	0	0	0	0
(14) Wind	WSAvg	2.9	2.9	2.8	2.9	2.9	3.0	3.0	2.8	2.7	2.9	2.8	3.0	2.8
(15) Precipitation	PrecAvg	813	72	48	50	47	51	68	71	79	76	87	85	79
	PrecMax	1229	152	179	118	111	126	162	152	198	210	220	198	197
	PrecMin	580	15	1	1	0	7	4	8	7	10	28	23	18
	PrecStd	129	39	33	28	26	26	36	34	44	38	43	41	42
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.6	8.6	14.8	21.7	26.7	28.2	30.0	28.0	24.3	17.8	13.2	10.4
		MCWB	7.4	6.5	8.4	13.5	16.4	18.6	19.7	18.8	17.0	14.0	12.0	9.5
	2%	DB	7.5	7.2	10.9	17.8	23.6	25.6	27.6	26.1	21.6	15.5	11.9	9.3
		MCWB	6.4	5.9	7.2	11.2	14.7	16.8	19.0	18.1	16.2	13.3	10.7	8.3
	5%	DB	6.6	6.5	8.8	15.4	21.2	23.4	25.6	24.3	19.8	14.5	11.0	8.6
		MCWB	5.5	5.4	5.8	9.8	13.9	16.0	18.1	17.7	15.4	12.6	9.8	7.6
	10%	DB	5.7	5.7	7.4	13.1	18.7	21.0	23.6	22.3	18.3	13.6	10.1	7.7
		MCWB	4.7	4.7	5.2	8.6	12.5	14.9	17.3	17.2	14.9	11.9	8.9	6.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	7.2	9.2	14.2	18.0	20.0	21.1	21.0	18.5	15.0	12.2	9.7
		MCDB	8.4	7.9	13.5	19.9	23.4	25.6	26.8	24.9	22.1	16.3	12.8	10.2
	2%	WB	6.7	6.4	7.7	11.9	16.2	18.0	20.0	19.6	17.0	13.8	10.9	8.6
		MCDB	7.2	7.0	10.1	16.5	21.5	22.8	25.4	23.3	20.0	15.2	11.7	9.2
	5%	WB	5.7	5.7	6.5	10.4	14.6	16.8	19.1	18.5	16.1	13.0	10.0	7.7
		MCDB	6.4	6.4	8.3	14.2	19.5	21.1	24.0	22.4	18.9	14.1	10.8	8.5
	10%	WB	4.8	4.8	5.7	9.2	13.2	15.7	18.1	17.7	15.3	12.1	9.1	6.8
		MCDB	5.7	5.6	7.1	12.4	17.4	19.9	22.5	21.3	17.8	13.4	10.1	7.6
(35) Mean Daily Temperature Range	5% DB	MDBR	4.3	4.5	6.2	7.4	7.9	7.1	7.1	6.9	6.7	5.4	4.2	4.1
		MCDBR	4.3	4.1	8.1	11.5	12.3	11.6	11.2	10.4	8.9	5.6	3.7	3.7
		MCWBR	4.2	3.4	5.1	6.3	5.9	5.6	4.7	4.8	4.8	4.1	3.6	3.8
	5% WB	MCDBR	4.0	3.5	6.9	9.6	10.8	9.4	9.3	8.1	7.2	4.9	3.7	3.7
		MCWBR	4.1	3.2	4.8	5.8	5.8	5.2	4.6	4.7	4.6	4.0	3.7	3.8
(40) Clear-Sky Solar Irradiance	taub		0.303	0.331	0.348	0.387	0.381	0.370	0.392	0.392	0.360	0.347	0.322	0.288
	taud		2.253	2.310	2.348	2.293	2.382	2.439	2.396	2.395	2.470	2.407	2.304	2.204
	Ebn at Noon		546	704	801	822	854	869	838	810	785	679	519	441
	Edh at Noon		49	72	90	111	109	104	107	100	80	65	47	38
(44) All-Sky Solar Radiation	RadAvg		0.36	0.95	2.40	3.96	5.26	5.80	5.30	4.16	2.84	1.30	0.47	0.25
	RadStd		0.07	0.16	0.23	0.50	0.45	0.39	0.59	0.33	0.31	0.20	0.09	0.03

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (61 neighbors)		+0.41	N/A	N/A	N/A	N/A	N/A	-124	-177	N/A

Nomenclature: See separate page