

NIDINGEN, Sweden

WMO: 025180

Lat: 57.3036N

Lon: 11.9049E

Elev: 13

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	19.2	22.2	9.7	9.0	22.3	14.7	11.6	24.3	41.3	38.6	38.2	37.7	14.4	70	0.774

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.5	73.8	66.8	71.7	65.8	69.8	64.6	67.9	72.1	66.4	70.4	64.9	68.8	9.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.1	96.3	71.0	64.6	91.1	69.4	63.1	86.4	68.0	32.3	72.4	31.1	70.6	29.9	69.0	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.9	33.2	30.1	17.4	76.5	4.9	3.7	13.9	79.2	11.0	81.4	8.2	83.4	4.6	86.1		
(5)			15.7	69.6	4.5	2.6	12.5	71.4	9.9	73.0	7.4	74.4	4.1	76.3	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.2	33.7	33.6	36.4	44.0	52.5	58.7	64.2	63.9	58.4	50.3	43.5	37.9	(6)
(7)		DBStd	11.96	5.63	5.42	4.64	4.55	4.81	3.77	3.97	3.65	3.60	4.55	5.26	6.34	(7)
(8)		HDD50	2226	504	459	421	188	25	0	0	0	0	53	200	376	(8)
(9)		HDD65	6219	969	879	886	629	389	192	66	65	200	457	646	841	(9)
(10)		CDD50	1561	0	0	0	9	103	262	439	432	251	61	4	0	(10)
(11)		CDD65	78	0	0	0	0	1	4	39	33	1	0	0	0	(11)
(12)		CDH74	52	0	0	0	0	2	2	32	16	0	0	0	0	(12)
(13)		CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0	(13)
(14)	Wind	WSAvg	15.8	17.8	16.4	15.2	13.5	13.5	14.1	13.1	14.4	16.4	18.1	18.6	18.2	(14)
(15)	Precipitation	PrecAvg	29.5	2.7	1.9	1.6	2.0	1.9	2.4	2.7	3.2	2.5	3.2	2.9	3.1	(15)
(16)		PrecMax	38.1	4.5	3.4	3.4	3.7	3.4	4.6	5.1	6.9	7.3	5.9	5.5	6.4	(16)
(17)		PrecMin	19.6	0.2	0.9	0.4	0.8	0.5	0.2	0.4	1.5	0.6	2.0	0.9	0.6	(17)
(18)		PrecStd	4.9	1.2	0.8	0.8	1.0	0.7	1.1	1.3	1.5	1.6	1.2	1.4	1.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.0	43.5	47.8	59.8	69.8	72.3	77.3	76.0	68.7	60.2	54.3	49.0	(19)
(20)			MCWB	42.0	41.8	43.5	52.7	61.3	64.3	68.7	67.0	62.9	55.9	52.4	47.3	(20)
(21)		2%	DB	42.9	42.3	44.9	55.8	64.8	68.9	74.3	73.8	66.4	58.5	52.6	47.6	(21)
(22)			MCWB	41.3	41.0	42.1	50.0	58.3	62.7	67.7	66.2	61.8	54.7	50.7	46.0	(22)
(23)		5%	DB	41.8	41.3	43.2	52.5	61.8	66.4	72.0	71.9	64.8	57.3	51.5	46.6	(23)
(24)			MCWB	40.2	40.1	40.9	48.2	56.6	61.5	66.4	65.7	60.7	54.5	49.5	45.0	(24)
(25)		10%	DB	40.7	40.2	41.8	50.0	59.0	64.4	70.2	69.8	63.5	56.2	50.0	45.2	(25)
(26)			MCWB	39.2	39.0	39.9	46.7	54.6	60.2	65.2	64.5	59.6	53.4	47.9	43.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.0	42.4	44.6	54.0	61.6	65.6	70.4	69.1	64.5	58.3	53.1	47.9	(27)
(28)			MCDWB	43.5	42.8	46.8	58.6	66.4	69.5	75.1	73.2	67.2	59.3	54.1	48.7	(28)
(29)		2%	WB	41.6	41.4	43.0	50.6	58.5	63.4	68.7	67.4	62.8	56.4	51.2	46.5	(29)
(30)			MCDWB	42.3	42.0	44.8	53.8	61.9	67.0	73.1	71.5	65.6	57.9	52.4	47.3	(30)
(31)		5%	WB	40.4	40.5	41.5	48.7	56.4	61.8	67.2	66.1	61.5	55.3	49.9	45.3	(31)
(32)			MCDWB	41.2	41.2	42.9	51.6	59.5	65.1	71.3	70.3	64.3	57.0	51.4	46.2	(32)
(33)		10%	WB	39.4	39.4	40.4	47.1	54.6	60.4	65.6	64.7	60.2	53.9	48.4	43.9	(33)
(34)			MCDWB	40.2	40.3	41.6	49.8	57.5	63.6	69.5	68.7	63.0	55.7	49.9	45.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.7	4.5	5.1	6.3	6.9	6.4	6.5	6.0	5.6	4.8	4.2	4.5	(35)
(36)			MCDBR	4.5	3.7	6.2	10.2	10.6	8.8	8.8	8.5	7.1	4.8	3.7	3.7	(36)
(37)			MCWBR	4.8	3.4	5.2	6.9	6.9	6.2	5.8	5.8	5.5	4.4	4.1	4.2	(37)
(38)		5% WB	MCDWB	4.5	3.6	5.9	8.1	8.7	7.7	8.2	7.3	6.0	4.2	3.7	3.6	(38)
(39)			MCWBR	4.7	3.3	5.0	6.0	6.1	5.9	6.2	5.6	5.5	4.4	4.3	4.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.307	0.333	0.350	0.388	0.382	0.372	0.394	0.395	0.364	0.350	0.326	0.294	(40)	
(41)		taud	2.259	2.312	2.346	2.298	2.391	2.447	2.401	2.398	2.469	2.406	2.306	2.218	(41)	
(42)		Ebn at Noon	175	225	254	261	271	276	266	257	249	216	167	144	(42)	
(43)		Edh at Noon	16	23	29	35	34	33	34	32	26	21	16	13	(43)	
(44)	All-Sky Solar Radiation	RadAvg	119	305	758	1266	1675	1830	1682	1321	908	423	156	83	(44)	
(45)		RadStd	24	52	73	156	144	134	181	104	97	61	27	10	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (56 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	-234	-329	N/A	N/A

Nomenclature: See separate page