

NIDINGEN, Sweden

WMO: 025180

Lat: 57.3036N

Lon: 11.9049E

Elev: 4

StdP: 101.28

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.1	-5.4	-12.4	1.3	-5.4	-9.6	1.7	-4.3	18.5	3.7	17.1	3.2	6.4	70	0.774

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.6	23.2	19.3	22.1	18.8	21.0	18.1	19.9	22.3	19.1	21.3	18.3	20.5	4.3	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	13.8	21.7	18.1	13.0	20.8	17.3	12.3	20.0	57.1	22.4	54.4	21.4	51.8	20.6	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.5	14.9	13.4	DB	-8.1	24.7	2.7	2.1	-10.1	26.2	-11.7	27.4	-13.2	28.6	-15.2	30.1	(4)
(5)			WB	-9.1	20.9	2.5	1.4	-10.9	21.9	-12.3	22.8	-13.7	23.6	-15.5	24.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.0	1.0	0.9	2.5	6.7	11.4	14.9	17.9	17.7	14.6	10.1	6.4	3.3	(6)	
	DBStd	6.64	3.13	3.01	2.58	2.53	2.67	2.09	2.21	2.03	2.00	2.53	2.92	3.52	(7)	
	HDD10.0	1237	280	255	234	104	14	0	0	0	0	29	111	209	(8)	
	HDD18.3	3455	538	488	492	349	216	107	37	36	111	254	359	467	(9)	
	CDD10.0	867	0	0	0	5	57	146	244	240	139	34	2	0	(10)	
	CDD18.3	43	0	0	0	0	1	2	22	18	1	0	0	0	(11)	
	CDH23.3	29	0	0	0	0	1	1	18	9	0	0	0	0	(12)	
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0	(13)	
	WSAvg	7.1	8.0	7.3	6.8	6.0	6.0	6.3	5.8	6.5	7.3	8.1	8.3	8.1	(14)	
(15) Precipitation	PrecAvg	750	69	49	40	51	48	61	69	81	63	81	73	79	(15)	
	PrecMax	968	115	86	87	94	86	116	130	176	186	151	140	162	(16)	
	PrecMin	497	6	23	9	21	12	5	11	39	14	52	23	16	(17)	
	PrecStd	124	31	20	21	26	18	28	33	39	40	30	36	41	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.7	6.4	8.8	15.5	21.0	22.4	25.2	24.4	20.4	15.6	12.4	9.5	(19)	
		MCWB	5.6	5.4	6.4	11.5	16.3	17.9	20.4	19.5	17.2	13.3	11.4	8.5	(20)	
	2%	DB	6.0	5.7	7.2	13.2	18.2	20.5	23.5	23.2	19.1	14.7	11.4	8.7	(21)	
		MCWB	5.2	5.0	5.6	10.0	14.6	17.1	19.8	19.0	16.6	12.6	10.4	7.8	(22)	
	5%	DB	5.4	5.2	6.2	11.4	16.5	19.1	22.2	22.2	18.2	14.0	10.8	8.1	(23)	
		MCWB	4.6	4.5	5.0	9.0	13.6	16.4	19.1	18.7	16.0	12.5	9.7	7.2	(24)	
	10%	DB	4.8	4.6	5.4	10.0	15.0	18.0	21.2	21.0	17.5	13.4	10.0	7.4	(25)	
		MCWB	4.0	3.9	4.4	8.2	12.5	15.7	18.4	18.1	15.3	11.9	8.9	6.5	(26)	
	0.4%	WB	6.1	5.8	7.0	12.2	16.4	18.7	21.3	20.6	18.1	14.6	11.7	8.8	(27)	
		MCDB	6.4	6.0	8.2	14.8	19.1	20.8	24.0	22.9	19.5	15.2	12.3	9.3	(28)	
(29) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	5.3	5.2	6.1	10.3	14.7	17.5	20.4	19.7	17.1	13.5	10.7	8.0	(29)	
		MCDB	5.7	5.6	7.1	12.1	16.6	19.4	22.8	21.9	18.7	14.4	11.4	8.5	(30)	
	5%	WB	4.7	4.7	5.3	9.3	13.6	16.6	19.5	18.9	16.4	12.9	10.0	7.4	(31)	
		MCDB	5.1	5.1	6.1	10.9	15.3	18.4	21.9	21.3	17.9	13.9	10.8	7.9	(32)	
	10%	WB	4.1	4.1	4.7	8.4	12.6	15.8	18.7	18.2	15.7	12.2	9.1	6.6	(33)	
		MCDB	4.6	4.6	5.3	9.9	14.1	17.5	20.9	20.4	17.2	13.2	9.9	7.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.6	2.5	2.8	3.5	3.8	3.6	3.6	3.4	3.1	2.7	2.3	2.5	(35)	
		MCDBR	2.5	2.1	3.5	5.7	5.9	4.9	4.9	4.7	3.9	2.7	2.0	2.1	(36)	
		MCWBR	2.7	1.9	2.9	3.8	3.8	3.5	3.2	3.2	3.0	2.5	2.3	2.3	(37)	
	5% WB	MCDBR	2.5	2.0	3.3	4.5	4.8	4.3	4.6	4.1	3.3	2.3	2.0	2.0	(38)	
		MCWBR	2.6	1.8	2.8	3.3	3.4	3.3	3.4	3.1	3.0	2.5	2.4	2.3	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.307	0.333	0.350	0.388	0.382	0.372	0.394	0.395	0.364	0.350	0.326	0.294	(40)	
	taud		2.259	2.312	2.346	2.298	2.391	2.447	2.401	2.398	2.469	2.406	2.306	2.218	(41)	
	Ebn at Noon		553	708	801	823	855	869	837	809	784	682	525	454	(42)	
	Edh at Noon		51	73	91	111	108	104	107	100	81	67	49	40	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.38	0.96	2.39	3.99	5.28	5.77	5.30	4.17	2.86	1.33	0.49	0.26	(44)	
	RadStd		0.08	0.16	0.23	0.49	0.46	0.42	0.57	0.33	0.31	0.19	0.09	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (56 neighbors)		+0.45	N/A	N/A	N/A	N/A	N/A	-130	-183	N/A	N/A

Nomenclature: See separate page