

GOTEBORG LANDVETTER, Sweden

WMO: 025260

Lat: 57.663N

Lon: 12.280E

Elev: 154

StdP: 99.49

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.6	-10.1	-15.3	1.0	-10.2	-13.2	1.2	-7.9	13.2	4.9	12.0	4.6	3.2	30	0.652

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	26.0	17.0	24.2	16.4	22.6	15.8	18.7	23.1	17.7	22.1	16.8	20.8	4.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	12.4	20.1	16.1	11.7	19.1	15.1	10.9	18.1	53.6	23.0	50.5	22.1	47.7	20.8	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	10.9	9.6	8.5	DB	-15.0	29.0	3.1	1.6	-17.3	30.2	-19.0	31.1	-20.8	32.0	-23.0	33.2
(5)				WB	-15.6	20.6	3.0	1.1	-17.8	21.4	-19.6	22.0	-21.3	22.7	-23.5	23.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-1.2	-1.1	1.4	6.3	10.7	13.9	16.6	16.0	12.4	7.7	3.3	0.3	(6)
(7)		DBStd	7.29	4.30	4.10	3.56	3.68	3.73	2.88	2.86	2.74	2.65	3.20	3.69	4.53	(7)
(8)		HDD10.0	1678	348	309	267	123	34	2	0	0	9	84	202	301	(8)
(9)		HDD18.3	4084	606	543	525	361	237	138	71	83	180	330	451	559	(9)
(10)		CDD10.0	671	0	0	0	12	57	119	204	187	79	12	1	0	(10)
(11)		CDD18.3	35	0	0	0	0	1	4	17	12	1	0	0	0	(11)
(12)		CDH23.3	253	0	0	0	3	12	42	128	67	1	0	0	0	(12)
(13)		CDH26.7	28	0	0	0	0	1	4	18	4	0	0	0	0	(13)
(14)	Wind	WSAvg	4.2	4.6	4.7	4.4	4.1	4.0	4.0	3.6	3.7	4.1	4.4	4.5	4.6	(14)
(15)	Precipitation	PrecAvg	1042	101	68	62	58	62	86	97	106	94	110	94	101	(15)
(16)		PrecMax	1293	189	146	132	117	105	154	190	194	217	229	176	225	(16)
(17)		PrecMin	668	8	29	20	17	15	3	7	25	27	35	39	21	(17)
(18)		PrecStd	167	47	35	28	32	23	36	45	44	48	47	41	58	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.2	7.2	13.9	22.1	25.0	26.9	28.8	27.1	22.9	16.2	11.5	8.9	(19)
(20)		MCWB	6.6	6.0	7.5	12.8	15.7	16.7	18.4	17.2	15.9	12.7	10.4	8.4	(20)	
(21)		2%	DB	6.1	6.1	9.9	17.8	22.4	24.3	26.4	25.2	19.9	14.0	10.2	7.9	(21)
(22)		MCWB	5.5	5.3	6.1	10.6	13.9	15.7	17.7	16.8	14.9	12.2	9.3	7.4	(22)	
(23)		5%	DB	5.1	5.1	7.7	15.1	20.1	22.1	24.6	23.2	18.0	13.0	9.2	7.0	(23)
(24)		MCWB	4.6	4.4	4.8	9.1	12.9	14.9	16.9	16.5	14.0	11.4	8.5	6.5	(24)	
(25)		10%	DB	4.1	4.1	6.0	12.8	17.7	19.8	22.6	21.1	16.6	12.1	8.2	6.0	(25)
(26)		MCWB	3.6	3.4	4.1	8.0	11.9	13.8	16.3	16.2	13.5	10.7	7.5	5.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	6.5	8.0	13.9	17.1	18.7	20.0	19.7	17.2	13.7	10.9	8.4	(27)
(28)		MDCB	6.9	6.8	11.6	20.8	22.3	23.1	25.3	22.8	19.8	14.8	11.4	8.5	(28)	
(29)		2%	WB	5.5	5.5	6.7	11.3	15.3	16.8	18.9	18.5	15.7	12.6	9.6	7.3	(29)
(30)		MDCB	5.7	5.8	8.8	15.8	20.2	21.9	23.9	22.0	18.6	13.7	10.1	7.6	(30)	
(31)		5%	WB	4.6	4.5	5.4	9.9	13.8	15.7	18.0	17.5	14.8	11.7	8.6	6.4	(31)
(32)		MDCB	4.9	4.9	6.8	13.8	18.5	20.3	22.8	21.3	17.3	12.8	9.1	6.7	(32)	
(33)		10%	WB	3.6	3.5	4.4	8.5	12.4	14.6	17.1	16.6	14.0	11.0	7.6	5.4	(33)
(34)		MDCB	3.9	3.9	5.5	11.8	16.7	18.7	21.3	20.3	16.0	12.1	8.1	5.8	(34)	
(35)	Mean Daily Temperature Range	MDBR	4.2	4.6	6.4	8.4	8.8	7.9	8.0	7.5	6.7	5.3	4.1	4.0	(35)	
(36)		5% DB	MCDBR	4.2	4.4	9.0	12.3	12.5	11.9	11.9	10.8	8.9	5.6	4.2	3.9	(36)
(37)		MCWBR	4.2	3.9	5.8	6.8	6.2	5.7	5.2	4.8	5.0	4.2	4.2	4.1	(37)	
(38)		5% WB	MCDBR	3.9	3.9	7.3	10.5	11.0	9.7	9.9	8.7	7.5	5.0	4.0	3.8	(38)
(39)		MCWBR	4.1	3.7	5.3	6.2	6.0	5.5	5.2	4.8	4.8	4.2	4.2	4.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.294	0.322	0.339	0.376	0.372	0.362	0.383	0.382	0.352	0.339	0.313	0.280	(40)	
(41)		taud	2.267	2.332	2.370	2.320	2.397	2.448	2.405	2.408	2.482	2.426	2.318	2.209	(41)	
(42)		Ebn at Noon	564	718	813	834	864	878	847	821	796	692	535	458	(42)	
(43)		Edh at Noon	48	71	88	108	107	103	106	99	79	64	46	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.37	0.97	2.40	3.92	5.16	5.64	5.16	4.06	2.80	1.29	0.47	0.26	(44)	
(45)		RadStd	0.07	0.16	0.24	0.52	0.46	0.38	0.63	0.37	0.33	0.21	0.09	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (56 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	-129	-186	N/A	N/A

Nomenclature: See separate page