

SKOVDE, Sweden

WMO: 025350

Lat: 58.456N

Lon: 13.973E

Elev: 99

StdP: 100.14

Time Zone: 1.00 (EUC)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-16.0	-12.8	-18.0	0.8	-15.5	-14.8	1.0	-11.6	9.4	4.0	8.7	3.5	1.0	180	0.607

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	26.9	17.4	25.0	16.6	23.1	16.1	19.2	23.7	18.2	22.7	17.2	21.3	3.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	13.0	20.5	16.8	12.1	19.7	15.8	11.4	18.9	54.8	23.5	51.6	22.4	48.7	20.9	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.9	7.1	-18.4	29.6	2.7	2.1	-20.4	31.0	-22.0	32.3	-23.5	33.4	-25.4	34.9		
(5)			-19.5	20.8	3.4	1.2	-22.0	21.6	-24.0	22.3	-25.9	23.0	-28.5	23.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.9	-1.6	-1.9	1.5	6.0	10.8	13.8	16.4	15.2	11.7	7.1	3.3	0.2
	DBStd	7.45	5.20	5.00	4.18	3.79	4.00	2.95	2.61	2.49	3.01	3.58	4.04	5.20
	HDD10.0	1756	361	332	265	128	39	3	0	1	17	104	202	303
	HDD18.3	4187	619	566	523	370	236	138	73	102	199	349	451	561
	CDD10.0	629	0	0	1	8	63	118	198	161	68	12	1	0
	CDD18.3	20	0	0	0	0	1	3	12	4	1	0	0	0
	CDH23.3	362	0	0	0	1	33	84	197	44	3	0	0	0
	CDH26.7	59	0	0	0	0	2	13	39	6	0	0	0	0
Wind	WSAvg	3.2	3.5	3.3	3.4	3.2	3.0	3.1	2.8	2.9	3.1	3.3	3.5	3.5
Precipitation	PrecAvg	687	44	40	31	39	54	84	86	78	63	61	56	50
	PrecMax	809	94	76	57	103	88	154	172	177	145	124	109	93
	PrecMin	531	9	2	4	3	14	9	14	16	9	9	11	17
	PrecStd	76	22	17	12	28	19	38	42	41	40	25	27	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.2	9.2	14.9	21.8	26.2	28.2	30.0	26.9	23.0	17.8	12.8	11.0
		MCWB	6.6	5.7	9.0	13.2	15.9	16.7	18.0	18.0	17.2	14.3	11.1	9.5
	2%	DB	7.0	7.1	11.9	18.9	24.0	25.9	27.2	24.2	20.2	15.0	11.1	9.8
		MCWB	5.9	5.3	7.4	11.2	14.1	15.8	18.0	17.6	15.5	12.7	9.7	8.4
	5%	DB	6.0	6.0	9.2	16.2	22.0	23.2	25.8	22.2	18.8	13.8	10.0	8.1
		MCWB	4.8	4.7	5.8	10.0	14.3	15.7	17.4	16.5	14.6	11.7	8.9	6.9
	10%	DB	4.9	4.9	7.8	14.0	19.1	21.1	23.2	20.8	17.0	12.2	8.9	6.9
		MCWB	3.8	3.6	5.3	8.6	13.0	14.6	17.0	16.2	13.5	10.5	8.0	5.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.0	7.0	9.6	13.6	18.0	19.0	20.8	20.3	18.1	14.8	11.5	9.8
		MCDB	7.7	8.2	13.6	20.2	23.0	24.5	25.0	23.2	21.3	16.4	12.5	10.6
	2%	WB	5.8	5.6	7.9	12.1	16.4	17.4	19.5	18.7	16.3	13.1	10.1	8.2
		MCDB	6.5	6.6	10.6	17.7	21.2	22.4	24.4	22.0	19.3	14.7	10.9	9.2
	5%	WB	4.8	4.5	6.5	10.6	15.0	16.2	18.5	17.7	15.1	12.1	9.0	6.9
		MCDB	5.6	5.6	8.5	15.1	19.2	21.8	23.7	20.8	17.8	13.5	9.7	7.7
	10%	WB	3.6	3.3	5.3	9.3	13.7	15.1	17.6	16.8	14.1	11.0	7.8	5.5
		MCDB	4.5	4.4	7.0	13.3	18.3	20.1	22.4	19.8	16.4	12.4	8.5	6.3
Mean Daily Temperature Range	5% DB	MDBR	5.5	6.2	8.1	11.8	11.9	11.3	10.7	10.0	9.1	7.3	5.0	5.1
		MCDBR	5.3	6.9	10.8	16.1	16.4	16.1	15.7	12.9	11.6	7.8	5.2	4.9
		MCWBR	5.1	5.5	7.2	9.7	8.6	8.5	7.5	7.3	7.4	6.0	4.7	4.9
	5% WB	MCDBR	5.2	6.4	9.3	14.0	12.8	13.5	13.1	10.8	10.3	7.3	5.2	4.9
		MCWBR	5.3	5.3	6.7	8.9	7.6	7.8	7.2	7.1	7.1	5.9	4.9	5.0
Clear-Sky Solar Irradiance	taub	0.275	0.311	0.331	0.370	0.367	0.356	0.378	0.371	0.342	0.331	0.299	0.259	
	taud	2.240	2.310	2.369	2.331	2.398	2.448	2.405	2.423	2.494	2.444	2.313	2.173	
	Ebn at Noon	563	719	815	837	866	880	849	828	802	693	529	447	
	Edh at Noon	46	69	87	106	106	103	105	96	77	61	43	35	
All-Sky Solar Radiation	RadAvg	0.35	0.94	2.46	3.95	5.16	5.79	5.17	4.09	2.78	1.26	0.45	0.24	
	RadStd	0.06	0.16	0.26	0.47	0.45	0.29	0.63	0.40	0.36	0.20	0.08	0.02	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (59 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-131	-164	N/A		

Nomenclature: See separate page