

AXSTAL, Sweden

WMO: 025450

Lat: 58.572N

Lon: 14.557E

Elev: 305

StdP: 14.53

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.8	16.1	9.4	9.0	14.9	12.6	10.6	18.7	37.3	39.9	33.8	36.4	10.9	40	0.722

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	73.8	65.5	71.0	63.7	68.5	62.6	67.3	71.4	65.4	69.3	63.7	67.4	6.9	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.7	96.0	69.8	63.8	89.6	67.7	62.1	84.3	65.9	31.9	71.4	30.4	69.2	29.2	67.5	73.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.3	27.8	25.2	11.5	78.3	7.6	3.8	6.0	81.0	1.6	83.2	-2.7	85.3	-8.2	88.1		
(5)			11.0	68.4	7.6	2.9	5.6	70.5	1.2	72.2	-3.1	73.8	-8.6	75.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	45.7	30.5	30.8	34.7	42.0	50.6	58.2	62.8	61.2	55.6	46.9	40.1	34.2	(6)
(7)		DBStd	12.70	6.86	7.36	6.12	4.62	6.05	4.70	4.55	3.20	4.03	4.72	5.81	7.23	(7)
(8)		HDD50	2838	606	539	475	242	64	1	0	0	6	118	298	489	(8)
(9)		HDD65	7090	1071	959	939	691	448	210	100	125	284	561	748	954	(9)
(10)		CDD50	1271	0	0	0	2	82	248	397	347	173	22	0	0	(10)
(11)		CDD65	47	0	0	0	0	1	7	32	7	0	0	0	0	(11)
(12)		CDH74	97	0	0	0	0	5	13	73	6	0	0	0	0	(12)
(13)		CDH80	8	0	0	0	0	0	0	8	0	0	0	0	0	(13)
(14)	Wind	WSAvg	12.7	14.5	13.9	13.0	10.6	10.3	10.8	10.6	10.9	12.9	14.5	15.6	14.7	(14)
(15)	Precipitation	PrecAvg	28.0	1.9	1.7	1.3	1.7	2.1	3.3	3.2	3.1	2.5	2.5	2.4	2.1	(15)
(16)		PrecMax	34.5	3.6	3.2	2.2	4.0	4.4	6.1	6.8	5.1	5.5	5.3	4.6	4.3	(16)
(17)		PrecMin	21.7	0.4	0.3	0.2	0.4	0.6	0.2	0.8	0.6	0.4	0.3	0.7	0.6	(17)
(18)		PrecStd	3.7	0.9	0.7	0.5	0.9	0.9	1.4	1.4	1.3	1.6	1.2	1.1	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.7	46.1	53.1	58.1	73.3	75.7	80.8	73.8	67.7	59.2	52.1	50.0	(19)
(20)			MCWB	42.4	43.0	47.0	49.4	58.8	62.9	68.2	66.8	61.7	55.9	50.3	47.8	(20)
(21)		2%	DB	42.6	43.1	48.0	54.4	67.6	71.3	75.5	70.4	65.1	57.1	50.4	48.1	(21)
(22)			MCWB	40.8	40.2	43.1	47.2	57.1	61.6	67.5	64.5	60.4	54.3	48.9	46.5	(22)
(23)		5%	DB	40.9	41.3	44.9	51.6	62.8	68.1	72.3	68.1	63.0	55.3	48.6	45.3	(23)
(24)			MCWB	39.3	39.2	40.9	45.4	55.3	60.9	65.6	62.9	58.9	53.1	47.3	43.7	(24)
(25)		10%	DB	39.3	39.6	42.3	48.9	59.0	65.2	69.6	66.4	61.2	53.6	47.1	42.7	(25)
(26)			MCWB	37.8	38.1	39.3	44.0	53.1	59.0	64.1	61.8	57.6	51.5	45.8	41.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.0	43.5	47.2	51.2	61.8	65.3	70.6	68.0	63.6	56.7	50.7	48.5	(27)
(28)			MCDB	44.1	45.4	52.3	56.0	68.3	71.1	75.8	71.6	66.5	58.1	51.5	49.5	(28)
(29)		2%	WB	41.1	41.2	43.9	48.3	58.7	63.6	68.8	66.1	61.3	55.0	49.2	46.5	(29)
(30)			MCDB	42.2	42.3	47.3	52.7	65.7	69.1	73.5	69.1	64.1	56.5	50.1	47.9	(30)
(31)		5%	WB	39.4	39.5	41.7	46.3	56.3	62.0	66.7	64.3	59.8	53.6	47.5	43.9	(31)
(32)			MCDB	40.6	40.7	44.1	50.7	62.1	66.7	70.9	67.0	62.2	54.9	48.4	44.9	(32)
(33)		10%	WB	37.9	38.2	39.6	44.5	54.0	60.1	64.9	62.8	58.3	51.9	46.1	41.5	(33)
(34)			MCDB	39.1	39.6	41.6	48.0	58.6	64.2	69.0	65.3	60.6	53.2	47.1	42.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.2	6.5	8.4	11.2	11.9	10.5	9.8	8.5	8.0	6.7	5.3	5.8	(35)
(36)			MCDBR	7.5	7.6	11.2	15.2	17.1	14.3	13.6	10.5	10.0	7.5	6.2	7.5	(36)
(37)			MCWBR	7.1	6.0	7.6	9.0	9.7	8.3	7.3	6.4	6.2	6.0	5.8	7.5	(37)
(38)		5% WB	MCDBR	7.5	7.1	10.5	14.7	16.7	13.5	12.6	9.8	9.2	6.8	6.3	7.6	(38)
(39)			MCWBR	7.1	5.8	7.8	9.3	10.3	8.4	7.4	6.8	6.3	6.2	5.9	7.6	(39)
(40)		Clear-Sky Solar Irradiance	taub	0.275	0.313	0.334	0.373	0.369	0.358	0.381	0.373	0.343	0.333	0.302	0.260	(40)
(41)	taud		2.226	2.291	2.358	2.325	2.398	2.449	2.404	2.423	2.494	2.434	2.301	2.163	(41)	
(42)	Ebn at Noon		176	226	257	264	274	279	268	262	253	218	165	139	(42)	
(43)	Edh at Noon		15	22	28	34	34	32	33	30	24	20	14	11	(43)	
(44)	All-Sky Solar Radiation	RadAvg	110	305	787	1265	1633	1827	1635	1297	878	398	141	75	(44)	
(45)		RadStd	16	51	89	142	143	89	192	138	120	66	26	8	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47)	Regional (56 neighbors)	+0.77	N/A	N/A	N/A	N/A	-230	-286	N/A	N/A

Nomenclature: See separate page