

VISINGSO, Sweden

WMO: 025480

Lat: 58.0948N

Lon: 14.4058E

Elev: 312

StdP: 14.53

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	14.8	18.1	9.1	8.8	16.8	12.1	10.3	20.0	32.5	33.5	29.9	32.6	12.2	50	0.662

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	75.4	64.4	72.5	63.6	69.9	62.0	66.5	72.2	64.8	70.1	63.3	68.4	7.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.1	90.7	69.4	62.6	85.8	68.0	61.0	81.0	66.7	31.3	72.3	30.0	70.0	28.9	68.5	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.5	25.3	22.5	14.4	80.6	4.7	1.7	11.0	81.9	8.2	82.9	5.6	83.9	2.2	85.1
			13.3	69.2	4.5	1.3	10.1	70.2	7.5	70.9	5.0	71.6	1.7	72.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.8	31.3	31.2	34.9	42.2	49.8	57.5	62.6	61.8	55.5	46.9	39.9	34.9
	DBStd	12.46	6.75	6.65	6.38	5.01	4.85	4.66	4.50	3.92	4.44	5.54	5.77	7.02
	HDD50	2780	579	525	468	239	61	2	0	0	8	126	303	469
	HDD65	7056	1044	945	933	684	472	230	103	112	285	562	752	934
	CDD50	1249	0	0	0	5	54	228	391	367	174	29	1	0
	CDD65	50	0	0	0	0	0	6	30	14	0	0	0	0
	CDH74	150	0	0	0	0	2	38	85	25	0	0	0	0
	CDH80	9	0	0	0	0	0	2	5	2	0	0	0	0
	WSAvg	11.2	13.8	12.8	11.4	9.7	9.0	8.4	8.3	9.0	11.0	12.5	14.1	14.1
	PrecAvg	23.5	1.4	1.2	1.1	1.3	1.9	3.0	3.3	2.7	2.2	2.1	1.9	1.6
(15) Precipitation	PrecMax	30.1	2.7	2.4	1.9	3.6	3.2	6.1	6.7	6.2	5.9	5.2	2.9	2.8
	PrecMin	18.6	0.4	0.1	0.1	0.2	0.4	0.2	0.7	0.5	0.4	0.3	0.4	0.4
	PrecStd	2.7	0.7	0.5	0.4	0.9	0.7	1.5	1.5	1.3	1.5	1.0	0.7	0.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.1	46.0	53.3	63.3	69.9	78.8	79.9	76.7	70.8	60.6	53.0	50.1
		MCWB	43.7	43.0	45.2	51.1	58.6	63.4	66.6	65.8	61.2	55.2	50.7	48.0
	2%	DB	43.7	43.5	48.8	57.2	64.2	72.7	76.4	73.3	67.0	57.5	51.0	47.4
		MCWB	41.5	40.6	42.9	48.4	54.8	61.3	65.3	64.6	59.8	54.0	48.8	45.5
	5%	DB	41.8	41.7	45.4	53.2	60.8	68.9	73.5	70.8	64.4	55.8	49.3	45.5
		MCWB	39.7	39.4	41.0	45.8	53.0	59.3	64.5	63.2	58.1	52.8	47.2	43.4
	10%	DB	40.0	40.0	42.6	50.0	57.7	66.0	70.7	68.6	62.0	54.2	47.7	43.5
		MCWB	38.1	37.9	39.5	44.0	51.3	57.7	63.2	61.9	57.0	51.5	45.8	41.5
	0.4%	WB	44.1	43.6	46.8	53.0	60.1	65.2	69.0	68.3	63.2	56.4	51.2	48.2
		MCDB	45.7	45.5	51.6	60.9	68.0	72.2	76.5	73.9	68.2	58.7	52.5	49.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.9	41.1	43.6	49.1	56.5	62.6	67.0	66.3	60.9	54.6	49.1	45.8
		MCDB	43.4	42.9	47.8	55.4	62.3	71.6	73.5	71.0	65.6	57.0	50.7	47.4
	5%	WB	40.0	39.6	41.4	46.6	54.2	60.4	65.6	64.4	59.1	53.2	47.4	43.6
		MCDB	41.6	41.5	44.6	52.0	59.2	67.3	71.3	69.1	63.0	55.5	49.1	45.2
	10%	WB	38.1	38.0	39.8	44.6	52.1	58.8	64.0	62.9	57.6	51.7	45.9	41.6
		MCDB	39.8	39.9	42.4	49.4	56.5	64.9	69.0	67.4	61.4	54.0	47.6	43.3
	5% DB	MDBR	5.7	6.2	9.0	12.3	13.1	13.5	12.2	11.4	9.6	7.1	5.5	5.6
		MCDBR	7.1	7.4	13.3	18.0	18.0	18.6	16.4	14.7	13.0	8.6	6.6	6.9
		MCWBR	6.9	6.1	8.8	10.7	10.8	9.9	8.6	7.9	7.4	6.5	6.3	6.8
		MCDBR	6.8	6.9	12.4	16.1	16.2	17.0	14.4	12.9	12.0	8.4	6.5	6.9
	5% WB	MCWBR	6.7	5.9	8.7	10.4	10.6	10.0	8.4	7.8	7.6	6.7	6.4	6.8
(40) Clear-Sky Solar Irradiance	taub	0.280	0.315	0.336	0.375	0.371	0.361	0.384	0.377	0.347	0.337	0.307	0.266	
	taud	2.240	2.300	2.357	2.322	2.394	2.447	2.400	2.417	2.487	2.431	2.315	2.183	
	Ebn at Noon	180	227	258	264	274	278	268	261	253	219	168	144	
	Edh at Noon	15	23	28	34	34	33	34	31	25	20	14	11	
(44) All-Sky Solar Radiation	RadAvg	113	309	785	1260	1630	1797	1614	1290	877	401	146	79	
	RadStd	18	54	87	154	148	90	197	134	120	68	27	8	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (55 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-238	-297	N/A	N/A

Nomenclature: See separate page