

JONKOPING, Sweden

WMO: 025500

Lat: 57.758N

Lon: 14.069E

Elev: 226

StdP: 98.64

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.5	-12.8	-18.3	0.8	-15.8	-14.8	1.1	-11.0	12.2	4.3	11.0	3.8	1.1	240	0.654

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	26.1	16.8	24.3	16.3	22.6	15.6	18.6	23.2	17.6	22.0	16.6	20.9	3.8	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	12.5	19.9	16.0	11.7	19.1	15.0	10.9	17.9	53.5	22.9	50.4	21.8	47.4	20.8	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.0	8.9	8.0	-21.4	29.0	3.5	1.8	-23.9	30.3	-25.9	31.4	-27.8	32.4	-30.4	33.7		
			-21.6	20.3	3.4	1.1	-24.1	21.1	-26.1	21.7	-28.1	22.3	-30.6	23.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.1	-2.5	-2.3	0.1	4.9	9.5	13.2	15.7	14.9	11.0	6.4	2.2	-0.9
	DBStd	7.51	4.78	4.80	4.36	3.63	3.54	2.93	2.74	2.70	3.05	3.62	3.89	4.86
	HDD10.0	1968	387	344	308	159	52	5	0	1	24	118	233	337
	HDD18.3	4492	645	577	567	404	276	157	91	109	219	369	483	595
	CDD10.0	536	0	0	0	5	36	101	177	155	55	7	0	0
	CDD18.3	17	0	0	0	0	1	2	9	4	0	0	0	0
	CDH23.3	270	0	0	0	1	11	53	142	62	2	0	0	0
	CDH26.7	37	0	0	0	0	0	7	24	5	0	0	0	0
Wind	WSAvg	3.8	4.1	4.2	4.0	3.7	3.7	3.3	3.3	3.6	3.9	4.0	4.1	
Precipitation	PrecAvg	749	57	44	36	42	55	84	84	80	69	74	64	63
	PrecMax	947	125	94	63	102	114	161	183	170	164	164	108	131
	PrecMin	585	8	9	8	6	18	4	12	21	10	11	26	11
	PrecStd	91	29	19	15	27	20	41	43	38	44	33	22	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.2	8.0	13.1	20.2	24.8	27.7	29.5	27.0	22.8	16.5	11.1	9.0
		MCWB	6.5	6.0	7.2	11.8	14.6	16.5	18.5	17.5	15.8	13.1	10.1	8.5
	2%	DB	5.7	6.1	10.4	17.3	22.1	24.8	26.8	25.1	20.2	14.0	9.9	7.2
		MCWB	5.1	5.1	6.2	10.1	13.4	15.6	17.4	17.0	14.9	12.1	8.9	6.7
	5%	DB	4.2	4.9	7.8	14.8	19.7	22.3	24.9	23.1	18.0	12.8	8.7	6.2
		MCWB	3.6	4.1	5.0	8.9	12.5	14.5	16.8	16.4	14.0	11.3	8.0	5.7
	10%	DB	3.2	3.8	5.9	12.0	17.1	20.1	22.8	21.1	16.2	11.5	7.5	5.1
		MCWB	2.7	2.9	3.9	7.4	11.3	13.7	16.3	15.8	13.1	10.1	6.9	4.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.6	6.5	8.2	13.2	16.6	18.4	20.2	19.9	17.4	14.1	10.6	8.5
		MCDB	6.9	7.4	11.4	18.5	22.1	23.6	25.1	23.7	20.5	15.5	11.1	8.8
	2%	WB	5.0	5.3	6.7	11.0	14.9	16.9	18.9	18.4	15.6	12.6	9.0	6.9
		MCDB	5.4	5.8	9.3	15.2	19.6	22.3	23.9	22.4	18.7	13.6	9.5	7.1
	5%	WB	3.7	4.1	5.3	9.4	13.4	15.6	17.9	17.4	14.5	11.5	7.9	5.7
		MCDB	4.1	4.6	7.1	13.4	17.7	20.6	22.5	21.2	17.2	12.6	8.4	6.0
	10%	WB	2.7	2.9	4.2	8.1	11.9	14.4	16.9	16.4	13.6	10.4	6.9	4.5
		MCDB	3.1	3.6	5.7	11.5	16.3	19.0	21.6	20.0	15.9	11.4	7.4	4.9
Mean Daily Temperature Range	5% DB	MDBR	5.0	5.8	7.9	10.3	11.0	10.5	10.4	10.0	8.7	6.4	4.5	4.6
		MCDBR	4.4	5.8	10.8	15.8	16.0	15.2	14.9	14.2	12.0	7.4	4.9	4.6
		MCWBR	4.4	4.8	7.1	9.3	8.4	7.5	7.0	7.5	7.4	5.5	4.7	4.6
	5% WB	MCDBR	4.2	4.9	9.2	13.3	12.8	12.8	12.1	11.3	10.1	6.6	4.6	4.5
		MCWBR	4.2	4.3	6.6	8.3	7.5	7.1	6.4	6.6	6.7	5.5	4.5	4.6
Clear-Sky Solar Irradiance	taub	0.281	0.314	0.333	0.371	0.368	0.358	0.380	0.375	0.345	0.334	0.306	0.267	
	taud	2.266	2.325	2.363	2.326	2.394	2.445	2.398	2.412	2.484	2.434	2.328	2.204	
	Ebn at Noon	581	727	819	839	867	881	849	827	802	698	544	471	
	Edh at Noon	47	70	88	107	107	103	106	98	79	63	45	37	
All-Sky Solar Radiation	RadAvg	0.36	0.98	2.45	3.93	5.11	5.57	5.04	4.03	2.76	1.27	0.47	0.26	
	RadStd	0.07	0.17	0.26	0.52	0.48	0.32	0.64	0.41	0.36	0.22	0.09	0.03	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.59	N/A	N/A	N/A	N/A	N/A	-184	-211	N/A	N/A
(47)	Regional (62 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-128	-159	N/A	N/A

Nomenclature: See separate page