

KYMBO V, Sweden

WMO: 025530

Lat: 58.0794N

Lon: 13.7850E

Elev: 728

StdP: 14.31

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.8	(c) 5.8	(d) -4.9	(e) 4.3	(f) -1.7	(g) 2.5	(h) 6.4	(i) 8.7	(j) 28.6	(k) 41.0	(l) 25.3	(m) 40.4	(n) 0.9	(o) 230	(p) 0.646

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 18.0	(c) 78.4	(d) 63.1	(e) 75.3	(f) 62.2	(g) 71.9	(h) 60.8	(i) 65.8	(j) 73.9	(k) 64.1	(l) 71.7	(m) 62.4	(n) 69.2	(o) 7.5	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.0	88.6	68.5	61.1	82.6	66.9	59.4	77.7	65.2	31.0	74.6	29.7	71.7	28.4	69.6	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 22.1	(b) 19.6	(c) 17.6	(e) -12.0	(f) 83.6	(g) 8.4	(h) 3.2	(i) -18.1	(j) 85.9	(k) -23.0	(l) 87.7	(m) -27.7	(n) 89.5	(o) -33.8	(p) 91.9		
(a) 22.1	(b) 19.6	(c) 17.6	(e) -12.3	(f) 68.6	(g) 8.4	(h) 2.3	(i) -18.4	(j) 70.2	(k) -23.3	(l) 71.5	(m) -28.1	(n) 72.8	(o) -34.2	(p) 74.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.0	26.4	27.3	32.4	42.0	50.1	55.9	60.4	58.9	51.3	43.3	36.7	29.9		
	DBStd	13.85	10.02	8.79	8.81	6.00	5.47	4.93	4.50	4.39	5.35	7.13	7.53	9.90		
	HDD50	3529	731	634	547	249	64	7	0	2	49	222	400	624		
	HDD65	8066	1196	1054	1012	690	463	278	157	194	413	671	849	1089		
	CDD50	961	0	0	0	9	67	183	322	277	86	16	1	0		
	CDD65	21	0	0	0	0	0	4	13	4	0	0	0	0		
	CDH74	386	0	0	0	0	10	91	210	75	0	0	0	0		
	CDH80	36	0	0	0	0	0	8	23	5	0	0	0	0		
	WSAvg	8.5	9.5	9.3	9.0	8.3	8.5	7.8	7.2	7.0	8.5	8.5	9.4	9.2		
	PrecAvg	28.9	1.9	1.6	1.5	1.6	2.2	3.3	3.6	3.2	2.4	2.6	2.6	2.4		
(15) Precipitation	PrecMax	34.5	4.5	2.8	2.3	3.3	3.9	5.7	6.7	7.6	4.3	5.6	5.4	4.8		
	PrecMin	21.2	0.4	0.2	0.6	0.1	0.9	1.2	0.7	0.5	0.5	0.2	0.6	0.7		
	PrecStd	3.5	1.0	0.7	0.5	1.1	0.8	1.3	1.6	1.9	1.3	1.3	1.1	1.0		
	PrecStd	3.5	1.0	0.7	0.5	1.1	0.8	1.3	1.6	1.9	1.3	1.3	1.1	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.8	46.3	57.4	68.2	74.9	80.8	83.1	79.1	71.4	60.6	52.9	49.2		
		MCWB	43.1	44.1	46.8	53.2	60.1	62.6	67.0	62.7	58.9	54.3	50.9	47.7		
	2%	DB	42.2	42.4	51.0	62.8	70.1	76.5	79.5	76.1	67.4	57.2	50.4	46.5		
		MCWB	40.8	40.2	43.2	49.9	55.8	61.0	64.9	62.4	57.8	54.0	48.6	45.3		
	5%	DB	40.3	40.4	46.3	58.3	66.3	72.5	76.2	72.6	63.7	55.2	48.6	44.0		
		MCWB	39.0	38.5	41.0	47.5	54.1	59.3	63.7	61.6	55.5	52.5	46.9	42.5		
	10%	DB	38.3	38.3	42.8	54.0	62.1	68.7	72.5	69.0	60.5	53.2	46.7	41.9		
		MCWB	37.0	36.6	39.4	44.8	52.3	57.5	62.6	60.2	54.7	50.8	45.3	40.4		
	0.4%	WB	43.5	44.1	47.4	54.3	62.8	65.7	69.8	68.8	60.9	57.0	51.5	48.2		
		MCDB	44.4	45.6	54.7	64.4	71.2	75.1	79.0	74.4	68.1	58.3	52.7	49.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.1	41.1	43.9	51.4	58.7	63.0	66.6	64.9	58.8	54.8	49.0	45.4		
		MCDB	41.9	42.3	49.2	60.5	65.2	72.6	75.5	70.8	64.0	56.4	50.3	46.4		
	5%	WB	39.1	38.7	41.8	48.6	56.0	60.6	64.8	63.1	57.3	52.9	47.2	42.7		
		MCDB	40.1	40.1	45.6	55.7	62.3	70.1	73.3	68.5	62.0	54.8	48.4	44.0		
	10%	WB	37.1	36.6	39.9	46.3	53.6	58.3	63.3	61.4	55.7	51.1	45.3	40.5		
		MCDB	38.2	38.1	42.5	52.3	61.0	66.5	71.0	67.0	59.4	53.2	46.6	41.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.3	9.9	14.1	17.9	18.1	18.3	18.0	16.9	15.7	12.1	8.2	8.4		
		MCDBR	7.9	8.4	18.9	26.3	26.4	27.5	26.7	24.5	21.1	12.9	8.4	8.2		
		MCWBR	7.5	7.2	12.4	14.6	14.4	14.1	14.2	12.7	12.5	9.4	7.7	7.8		
		MCDBR	7.9	7.4	17.0	21.3	20.5	23.9	22.9	18.7	18.3	11.0	7.8	8.3		
	5% WB	MCWBR	7.6	6.8	11.6	13.1	12.8	13.7	13.3	11.6	11.8	8.7	7.3	8.0		
		MCWBR	7.6	6.8	11.6	13.1	12.8	13.7	13.3	11.6	11.8	8.7	7.3	8.0		
(40) Clear-Sky Solar Irradiance	taub		0.277	0.311	0.330	0.368	0.366	0.355	0.377	0.371	0.342	0.330	0.301	0.262		
	taud		2.260	2.326	2.368	2.330	2.394	2.443	2.399	2.414	2.487	2.439	2.321	2.191		
	Ebn at Noon		183	230	260	266	275	280	270	263	255	222	171	147		
	Edh at Noon		15	22	28	34	34	33	34	31	25	20	14	11		
	RadAvg		113	303	773	1244	1628	1800	1621	1284	879	401	146	78		
(45) All-Sky Solar Radiation	RadStd		21	51	79	159	145	102	206	125	111	66	27	9		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (58 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	-223	-275	N/A	N/A

Nomenclature: See separate page