

WMO: 025540

WBAN: 99999

(1)	1	-14.0	-11.4	-16.3	0.9	-11.9	-14.0	1.1	-9.7	9.3	0.2	8.4	0.4	2.0	350	0.588	(1)
-----	---	-------	-------	-------	-----	-------	-------	-----	------	-----	-----	-----	-----	-----	-----	-------	-----

(2)	7	7.1	25.5	17.1	23.7	16.4	22.0	15.6	18.7	22.8	17.7	21.5	16.7	20.3	2.8	290	(2)
-----	---	-----	------	------	------	------	------	------	------	------	------	------	------	------	-----	-----	-----

(3)	17.2	12.7	19.8	16.3	11.9	19.2	15.2	11.1	18.4	53.8	22.9	50.6	21.7	47.8	20.3	23.2	(3)
-----	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	-----

(4)	7.4	6.5	5.9	DB	-15.1	27.5	3.5	1.7	-17.6	28.7	-19.7	29.7	-21.7	30.6	-24.3	31.8	(4)
(5)				WB	-15.4	20.2	3.3	1.3	-17.8	21.1	-19.7	21.8	-21.5	22.5	-23.9	23.4	(5)

(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	-2.8	-2.4	0.7	5.8	10.6	14.5	17.0	15.9	11.5	6.6	2.4	-0.5	(6)
(7)		DBStd	7.78	4.28	4.21	4.01	3.54	3.64	3.07	3.05	2.56	2.77	3.43	3.74	4.63	(7)
(8)		HDD10.0	1886	396	348	288	134	34	2	0	1	16	113	229	326	(8)
(9)		HDD18.3	4303	654	581	547	377	239	123	66	84	206	364	479	584	(9)
(10)		CDD10.0	664	0	0	0	7	54	136	216	184	61	7	0	0	(10)
(11)		CDD18.3	39	0	0	0	0	1	7	23	9	0	0	0	0	(11)
(12)		CDH23.3	183	0	0	0	0	6	38	113	27	0	0	0	0	(12)
(13)	CDH26.7	16	0	0	0	0	0	1	12	3	0	0	0	0	(13)	
(14)	Wind	WSAvg	3.1	3.3	3.2	3.3	3.1	3.0	2.9	2.7	2.7	3.0	3.3	3.6	3.4	(14)
(15)	Precipitation	PrecAvg	639	43	37	31	37	46	65	83	71	59	59	59	49	(15)
(16)		PrecMax	829	80	72	52	92	82	124	186	169	145	130	118	104	(16)
(17)		PrecMin	505	16	11	6	8	16	3	24	15	13	23	19	13	(17)
(18)		PrecStd	78	20	16	11	22	20	30	42	35	36	27	26	23	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.7	7.1	12.7	18.2	24.1	26.4	28.1	25.8	20.7	15.4	10.9	9.0	(19)
(20)			MCWB	4.9	5.2	7.6	10.4	15.0	16.7	18.3	17.8	15.4	12.9	9.9	8.2	(20)
(21)		2%	DB	4.4	5.4	9.7	16.1	21.7	24.3	26.2	23.7	18.5	13.2	9.5	7.5	(21)
(22)			MCWB	3.7	4.1	5.6	9.6	13.6	15.9	17.6	17.3	14.4	11.6	8.6	6.8	(22)
(23)		5%	DB	3.5	4.3	7.5	13.7	19.5	22.2	24.4	21.8	16.8	12.2	8.4	6.2	(23)
(24)			MCWB	2.8	3.2	4.5	8.2	12.7	14.8	17.0	16.4	13.6	10.9	7.6	5.4	(24)
(25)	10%	DB	2.6	3.1	5.8	11.6	17.0	20.1	22.4	20.2	15.4	11.1	7.2	5.1	(25)	
(26)		MCWB	2.0	2.3	3.5	6.8	11.2	13.8	16.3	15.6	12.8	10.1	6.6	4.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	6.0	7.8	12.0	16.5	18.2	20.2	19.8	16.2	13.2	10.1	8.4	(27)
(28)			MCDB	5.5	6.6	11.7	17.2	21.8	23.2	25.0	23.1	19.2	14.3	10.5	8.9	(28)
(29)		2%	WB	3.9	4.5	6.1	9.9	15.1	16.8	19.0	18.5	14.9	12.1	8.8	6.8	(29)
(30)			MCDB	4.2	5.1	8.5	14.4	19.5	22.4	23.6	21.8	17.4	12.9	9.2	7.4	(30)
(31)		5%	WB	2.9	3.4	5.0	8.7	13.5	15.6	18.1	17.3	14.0	11.1	7.7	5.5	(31)
(32)			MCDB	3.3	4.1	7.0	12.7	17.6	20.9	22.4	20.1	16.2	12.0	8.2	6.0	(32)
(33)	10%	WB	2.1	2.3	3.9	7.5	12.1	14.6	17.2	16.5	13.2	10.2	6.7	4.4	(33)	
(34)		MCDB	2.5	3.1	5.4	10.9	16.2	19.0	21.1	19.1	15.0	11.1	7.2	5.0	(34)	
(35)	Mean Daily Temperature Range		MDBR	3.6	4.0	5.5	7.5	8.1	7.7	7.1	6.4	5.6	4.5	3.5	3.4	(35)
(36)		5% DB	MCDBR	4.2	4.3	7.7	10.3	10.9	10.4	9.7	8.6	7.3	4.9	4.3	3.9	(36)
(37)			MCWBR	4												

(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47)	Regional (59 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	-128	-152	N/A	N/A	(47)

Nomenclature: See separate page