

HAGSHULT, Sweden

WMO: 025560

Lat: 57.292N

Lon: 14.137E

Elev: 170

StdP: 99.31

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.9	-14.4	-20.4	0.6	-13.7	-16.5	0.9	-13.0	10.9	5.2	9.3	4.3	0.4	50	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	27.2	17.8	25.4	17.3	23.6	16.5	19.8	24.4	18.6	22.9	17.6	21.6	3.6	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.3	13.4	21.1	17.2	12.5	20.0	16.2	11.7	18.8	57.3	24.6	53.4	22.8	50.2	21.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.2	6.4	DB	-20.7	29.9	3.7	1.5	-23.4	31.0	-25.5	31.8	-27.6	32.7	-30.3	33.7	(4)
(5)			WB	-20.6	21.1	3.6	1.1	-23.1	21.9	-25.2	22.5	-27.2	23.2	-29.8	23.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.4	-2.5	-2.3	0.6	5.5	9.9	13.4	15.9	14.8	11.0	6.7	3.0	-0.4	(6)	
	DBStd	7.50	5.16	4.79	4.25	3.66	3.69	3.10	2.94	2.70	3.00	3.81	4.00	5.12	(7)	
	HDD10.0	1887	386	346	291	142	47	6	0	1	24	112	210	321	(8)	
	HDD18.3	4391	644	579	549	386	263	151	87	113	219	360	459	579	(9)	
	CDD10.0	558	0	0	0	6	43	108	183	151	56	11	1	0	(10)	
	CDD18.3	19	0	0	0	0	1	3	12	4	0	0	0	0	(11)	
	CDH23.3	442	0	0	0	2	26	95	248	68	3	0	0	0	(12)	
	CDH26.7	73	0	0	0	0	1	13	51	8	0	0	0	0	(13)	
	WSAvg	2.9	3.0	3.0	3.0	2.9	2.9	2.9	2.7	2.6	2.8	2.9	3.0	2.9	(14)	
(15) Precipitation	PrecAvg	822	63	50	41	46	61	81	90	90	73	81	73	67	(15)	
	PrecMax	957	136	123	90	113	138	156	206	192	170	178	134	133	(16)	
	PrecMin	628	3	6	9	7	16	0	8	19	6	9	27	11	(17)	
	PrecStd	100	36	26	19	27	28	37	48	44	45	37	27	30	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.2	9.2	14.5	21.9	25.8	28.6	30.2	27.3	23.0	17.1	11.7	9.7	(19)	
		MCWB	6.3	6.7	8.4	13.6	16.3	17.7	19.8	19.0	16.4	13.9	10.0	9.2	(20)	
	2%	DB	5.8	6.5	11.6	18.3	23.7	26.1	28.1	25.2	20.5	14.5	10.4	8.3	(21)	
		MCWB	5.1	5.4	7.1	11.1	14.8	16.7	18.9	17.9	15.6	13.0	9.1	7.9	(22)	
	5%	DB	4.7	5.3	8.5	15.8	21.4	23.8	26.2	23.2	18.3	13.3	9.2	7.1	(23)	
		MCWB	4.1	4.5	5.7	9.8	13.5	16.0	17.9	17.1	14.7	12.2	8.1	6.7	(24)	
	10%	DB	3.7	4.0	6.4	13.1	18.6	21.2	24.2	21.1	16.6	12.2	8.3	6.0	(25)	
		MCWB	3.3	3.3	4.7	8.3	12.3	14.8	17.3	16.6	13.7	11.2	7.6	5.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	7.6	9.5	14.9	17.7	20.1	21.2	20.9	18.2	14.6	11.4	9.4	(27)	
		MCDB	7.0	8.8	12.8	20.3	23.9	25.4	26.5	25.2	20.8	15.8	11.5	9.6	(28)	
	2%	WB	5.3	5.9	7.6	11.9	16.2	18.2	20.2	19.2	16.3	13.5	9.7	8.0	(29)	
		MCDB	5.6	6.2	10.1	17.0	20.9	22.8	25.3	22.5	19.0	14.1	10.1	8.2	(30)	
	5%	WB	4.2	4.6	6.2	10.3	14.6	16.9	19.2	18.1	15.2	12.5	8.7	6.8	(31)	
		MCDB	4.5	5.1	8.1	14.5	19.2	21.2	24.0	21.3	17.6	13.1	9.1	7.0	(32)	
	10%	WB	3.3	3.4	5.0	9.0	13.0	15.7	18.0	17.2	14.2	11.5	7.8	5.7	(33)	
		MCDB	3.7	4.0	6.3	12.3	17.6	20.2	22.7	20.1	16.1	12.1	8.1	6.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.4	6.5	8.8	11.9	12.7	12.0	12.0	10.6	10.0	7.4	4.9	4.9	(35)	
		MCDBR	4.6	7.1	13.0	17.6	18.2	17.5	16.9	14.9	13.4	8.0	4.7	4.7	(36)	
	5% WB	MCWBR	4.5	5.6	8.7	10.6	9.7	8.9	8.3	8.1	8.7	6.2	4.5	4.6	(37)	
		MCWBR	4.5	5.8	10.9	14.6	14.2	13.9	13.9	11.6	11.6	7.2	4.6	4.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.288	0.319	0.338	0.375	0.372	0.362	0.385	0.382	0.352	0.340	0.314	0.276	(40)	
		taud	2.279	2.328	2.359	2.326	2.392	2.442	2.394	2.404	2.478	2.430	2.341	2.230	(41)	
	Edn at Noon		587	728	817	837	864	878	846	823	798	697	549	484	(42)	
		Edh at Noon	49	71	90	108	108	104	107	99	80	65	47	38	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.38	1.00	2.44	3.94	5.12	5.49	5.00	4.02	2.77	1.29	0.48	0.27	(44)	
	RadStd		0.07	0.18	0.26	0.54	0.50	0.34	0.64	0.40	0.36	0.23	0.09	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (61 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-152	N/A	N/A

Nomenclature: See separate page