

GLADHAMMAR, Sweden

WMO: 025590

Lat: 57.7068N

Lon: 16.4526E

Elev: 115

StdP: 14.64

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.8	11.9	1.8	6.1	6.9	7.7	8.2	14.6	23.1	36.9	19.5	40.3	2.0	350	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.8	80.9	65.3	77.3	63.8	74.5	62.7	68.0	75.4	66.2	73.3	64.5	71.7	7.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.6	94.8	70.8	63.6	88.4	69.0	61.8	82.9	67.5	32.4	75.4	30.9	73.5	29.7	71.8	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.6	14.6	12.7	DB	-2.0	86.3	9.1	3.6	-8.6	88.9	-13.9	91.0	-19.0	93.1	-25.7	95.7	(4)
(5)			WB	-2.3	70.7	8.8	2.0	-8.7	72.2	-13.8	73.3	-18.8	74.5	-25.2	75.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.3	29.2	30.1	34.8	42.2	50.7	58.8	63.4	61.8	54.6	45.6	38.6	32.9	(6)	
	DBStd	13.56	8.13	8.07	7.49	6.17	6.01	5.04	4.78	4.47	4.86	6.26	6.22	8.40	(7)	
	HDD50	3037	644	558	471	244	65	3	0	0	15	163	344	530	(8)	
	HDD65	7251	1109	978	935	683	444	193	89	120	312	601	793	994	(9)	
	CDD50	1329	0	0	1	11	87	267	416	365	154	27	1	0	(10)	
	CDD65	68	0	0	0	0	0	7	40	20	1	0	0	0	(11)	
	CDH74	766	0	0	0	1	16	154	428	159	8	0	0	0	(12)	
	CDH80	139	0	0	0	0	2	28	86	23	0	0	0	0	(13)	
(14) Wind	WSAvg	5.8	6.4	6.2	6.5	5.9	5.8	5.8	5.3	5.0	5.5	5.6	6.0	6.1	(14)	
(15) Precipitation	PrecAvg	24.5	1.5	1.5	1.1	1.4	1.8	2.4	3.1	2.5	2.6	2.2	2.6	2.1	(15)	
	PrecMax	34.4	2.9	2.8	2.3	3.1	3.5	4.8	7.3	5.4	6.0	6.4	9.3	4.1	(16)	
	PrecMin	19.1	0.2	0.4	0.2	0.1	0.4	0.1	0.5	0.0	0.7	0.7	0.2	0.4	(17)	
	PrecStd	3.7	0.7	0.7	0.5	0.8	0.8	1.2	1.7	1.2	1.7	1.4	1.9	1.0	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.3	50.3	60.2	68.1	75.8	83.9	86.6	83.1	75.1	64.4	54.9	52.8	(19)	
		MCWB	44.7	44.2	48.1	54.5	59.6	63.9	66.9	67.5	62.0	57.4	51.5	49.3	(20)	
	2%	DB	44.9	46.2	54.3	62.8	71.0	78.1	82.3	78.0	70.3	60.2	51.7	48.8	(21)	
		MCWB	41.9	41.5	45.1	51.1	57.4	62.6	65.2	65.1	60.2	55.1	48.9	45.8	(22)	
	5%	DB	42.3	43.3	49.5	58.9	67.2	74.5	78.7	74.8	66.9	57.3	49.5	45.8	(23)	
		MCWB	39.7	39.9	42.7	48.6	55.3	60.9	65.2	63.6	58.6	53.5	47.2	43.4	(24)	
	10%	DB	39.8	40.9	45.8	54.5	63.7	71.1	75.4	72.0	64.0	54.9	47.4	43.0	(25)	
		MCWB	37.6	37.8	40.8	45.9	53.7	59.2	63.8	62.8	57.1	51.6	45.5	41.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.7	45.5	49.3	55.8	62.2	67.6	71.0	70.7	64.4	58.5	52.2	49.4	(27)	
		MCDB	47.8	49.0	57.6	65.6	72.6	75.6	79.8	78.1	71.1	62.2	54.0	52.0	(28)	
	2%	WB	42.2	42.4	45.8	52.6	59.4	64.6	68.6	67.4	61.8	56.1	49.4	46.3	(29)	
		MCDB	44.2	45.2	52.8	60.6	66.8	74.6	76.7	73.8	67.5	59.3	51.1	48.6	(30)	
	5%	WB	39.9	40.3	43.3	49.5	56.9	62.3	66.9	65.7	59.8	54.0	47.5	43.6	(31)	
		MCDB	42.0	43.1	48.3	57.2	64.5	71.3	74.8	71.5	64.7	56.7	49.0	45.2	(32)	
	10%	WB	37.7	38.1	41.3	46.7	54.7	60.4	65.2	64.2	58.1	52.2	45.7	41.3	(33)	
		MCDB	39.5	40.7	45.6	53.3	62.3	69.1	72.9	70.2	62.6	54.5	47.1	42.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.3	11.0	14.5	18.5	19.8	19.6	18.8	18.0	16.4	12.8	8.9	8.5	(35)	
		MCDBR	10.6	13.1	20.8	26.2	26.0	26.9	25.1	22.4	21.3	15.3	11.0	10.2	(36)	
	5% WB	MCWBR	9.2	9.6	13.2	15.2	14.2	13.1	11.2	11.5	12.3	10.8	9.2	8.9	(37)	
		MCWBR	10.5	12.3	18.9	23.3	22.0	23.4	20.6	19.2	18.8	14.3	10.3	9.9	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.293	0.325	0.341	0.379	0.376	0.366	0.394	0.386	0.354	0.344	0.321	0.282	(40)	
		taud	2.281	2.321	2.363	2.322	2.398	2.457	2.397	2.415	2.485	2.423	2.309	2.222	(41)	
	Ebn at Noon	Ebn at Noon	180	226	257	263	272	277	265	259	251	218	165	145	(42)	
		Edh at Noon	15	23	28	34	34	32	34	31	25	20	15	12	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	113	295	776	1318	1748	1912	1740	1396	943	419	152	81	(44)	
	RadStd	RadStd	18	61	73	145	136	90	167	122	109	67	29	12	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (48 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	-223	-295	N/A	N/A	

Nomenclature: See separate page